Lead in School Drinking Water Report

Sky Valley Education Center - Post-remediation Revisit

Date(s) collected: 2024-03-28, 2024-05-22
Date(s) analyzed: 2024-04-15, 2024-06-17

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
390976	Building 2 - Annex	Sink	Room A	3 of 3	Tap	5
391267	Building 4 - Technology Education	Sink	Wood Shop Room	1 of 5	Tap	5
391475	Building 2 - Annex	Sink	Room A	2 of 3	Tap	5
391478	Building 5 - Pods/Library	Sink	Pod	Between rooms 8 and 9	Tap	1
390977	Building 2 - Annex	Sink	Room C	3 of 3	Tap	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**

Lead in School Drinking Water Report

Sky Valley Education Center - Post-remediation Revisit

Date(s) collected: 2024-05-22
Date(s) analyzed: 2024-06-17

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
391267	Building 4 - Technology Education	Sink	Wood Shop Room	1 of 5	Tap	center	5

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**