Lead in School Drinking Water Report

Sky Valley Education Center Revisit

Date(s) collected: 2024-03-28, 2024-05-22
Date(s) analyzed: 2024-04-15, 2024-06-17

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
390978	Building 3 - Gymnasium	Sink	Music Room	1 of 1	Tap	left	9
390974	Building 2 - Annex	Sink	Rmd	1 of 1	Tap	center	5
390975	Building 1 - Office	Sink	Copy Room	1 of 1	Tap	center	5
391477	Building 2 - Annex	Sink	Rme Laundry	1 of 1	Tap	center	5
391766	Building 2 - Annex	Sink	Rmd	1 of 1	Tap	center	5
391476	Building 2 - Annex	Sink	Rma	Art sink	Tap	center	4
390979	Building 5 - Pods/Library	Sink	Library	1 of 1	Tap	left	3
391474	Building 1 - Office	Sink	Staff Lounge	1 of 1	Tap	left	1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**