Lead in School Drinking Water Report

Maltby Elementary School - Post-remediation Revisit

Date(s) collected: 2024-03-26
Date(s) analyzed: 2024-04-15

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
390973	Building A	Sink	Room A3	1 of 1	Water Fountain	3
391472	Building A	Sink	Room A5	1 of 1	Water Fountain	2
391473	Building C	Sink	Room C10	1 of 1’	Water Fountain	2
390972	Building A	Sink	Room A6	1 of 1	Water Fountain	1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**