Lead in School Drinking Water Report

Frank Wagner Elementary School - Post-remediation Revisit

Date(s) collected: 2024-03-26
Date(s) analyzed: 2024-04-22

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
391465	Classroom wing	Sink - Multi-Compartment	Room 216	Only sink	Water Fountain	39
391468	Classroom wing	Fountain	Hallway	Between rooms 201 and 202	Water Fountain	29
390968	Classroom wing	Sink	Room 202	Only sink	Water Fountain	18
391467	Classroom wing	Sink - Multi-Compartment	Room 201	Only sink	Water Fountain	14
390965	Classroom wing	Sink - Multi-Compartment	Room 155	Only sink	Water Fountain	12
390966	Multipurpose	Sink	Kitchen	By exit door	Sprayer	11
390963	Classroom wing	Sink - Multi-Compartment	Room 132	Only sink	Water Fountain	9
390967	Classroom wing	Sink - Multi-Compartment	Room 206	Only sink	Water Fountain	4
391466	Multipurpose	Sink	Kitchen	By the walk in fridge	Tap	4

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
390962	Classroom wing	Sink - Multi-Compartment	Room 131	Only sink	Tap	1
390964	Classroom wing	Sink - Multi-Compartment	Room 139	Only sink	Tap	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**