Lead in School Drinking Water Report

Sky Valley Education Center1 - Post-remediation

Date(s) collected: 2023-11-22
Date(s) analyzed: 2023-12-14, 2024-01-03

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
377622	Building 4 - Technology Education	Sink	Wood Shop Room	1 of 5	Tap	998
377123	Building 5 - Pods/Library	Sink	Room 16a	1 of 1	Tap	46
377121	Building 2 - Annex	Sink	Room C	3 of 3	Tap	8
377120	Building 2 - Annex	Sink	Room A	2 of 3	Tap	7
377124	Building 5 - Pods/Library	Sink	Pod	Between rooms 8 and 9	Tap	7
377620	Building 2 - Annex	Sink	Room A	3 of 3	Tap	7
377122	Building 4 - Technology Education	Sink	Art Room	Kiln room 1 of 1	Tap	5

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
377621	Building 2 - Annex	Sink	Room F	1 of 1 by eye wash station	Tap	4
377623	Building 5 - Pods/Library	Sink	Pod	1 of 2 in between rooms 12 and 13	Tap	3

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**