Lead in School Drinking Water Report

Frank Wagner Elementary School - Post-remediation

Date(s) collected: 2023-09-30
Date(s) analyzed: 2023-10-16

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
374069	Classroom wing	Sink - Multi-Compartment	Room 131	Only sink	Tap	137
374071	Classroom wing	Sink - Multi-Compartment	Room 132	Only sink	Water Fountain	101
374074	Classroom wing	Sink - Multi-Compartment	Room 216	Only sink	Water Fountain	51
374066	Multipurpose	Sink	Kitchen	By the walk in fridge	Tap	36
374072	Classroom wing	Sink - Multi-Compartment	Room 139	Only sink	Tap	21
374073	Classroom wing	Sink - Multi-Compartment	Room 155	Only sink	Water Fountain	19
374079	Classroom wing	Sink	Room 202	Only sink	Water Fountain	17
374077	Classroom wing	Sink - Multi-Compartment	Room 206	Only sink	Water Fountain	8
374080	Classroom	Sink - Multi-	Room	Only sink	Water	8

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
	wing	Compartment	201		Fountain	
374082	Classroom wing	Fountain	Hallway	Between rooms 201 and 202	Water Fountain	7
374068	Multipurpose	Sink	Kitchen	By exit door	Sprayer	6
374067	Multipurpose	Sink	Kitchen	By exit door	Tap	5
374076	Classroom wing	Sink - Multi-Compartment	Room 211	Only sink	Water Fountain	5
374078	Classroom wing	Sink - Multi-Compartment	Room 204	Only sink	Water Fountain	4
374081	Classroom wing	Sink - Multi-Compartment	Room 201	Only sink	Tap	4
374070	Classroom wing	Fountain	Hallway	Between rooms 131 and 132	Water Fountain	3
374075	Classroom wing	Sink - Multi-Compartment	Room 216	Only sink	Tap	2

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**