

# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 5052711

Springfield Public Schools  
 1890 42nd Street  
 Springfield, OR 97477

Project: Lead Testing  
 Project #: Springfield School District 19  
 Thurston Elementary  
 Client Contact: Jody Olson

Date Reported: 06/20/25  
 Date Received: 05/27/25 11:30  
 Sampled By: Mario Rodriguez

### Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5052711-01	Sample Location: 20831000-051CF									
Lead (⊘)		1030	3.1	ppb	1.0	15	05/23/25 05:33	06/12/25	DST	
5052711-02	Sample Location: 20831000-052DW									
Lead (⊘)		1030	2.0	ppb	1.0	15	05/23/25 05:33	06/12/25	DST	
5052711-03	Sample Location: 20831000-053CF									
Lead (⊘)		1030	2.1	ppb	1.0	15	05/23/25 05:35	06/12/25	DST	
5052711-04	Sample Location: 20831000-055BF									
Lead (⊘)		1030	ND	ppb	1.0	15	05/23/25 05:35	06/12/25	DST	
5052711-05	Sample Location: 20831000-056SF									
Lead (⊘)		1030	ND	ppb	1.0	15	05/23/25 05:37	06/12/25	DST	
5052711-06	Sample Location: 20831000-057SF									
Lead (⊘)		1030	ND	ppb	1.0	15	05/23/25 05:37	06/12/25	DST	
5052711-07	Sample Location: 20831000-058CF									
Lead (⊘)		1030	5.7	ppb	1.0	15	05/23/25 05:38	06/12/25	DST	
5052711-08	Sample Location: 20831000-059DW									
Lead (⊘)		1030	3.6	ppb	1.0	15	05/23/25 05:38	06/12/25	DST	
5052711-09	Sample Location: 20831000-060BF									
Lead (⊘)		1030	2.2	ppb	1.0	15	05/23/25 05:40	06/12/25	DST	
5052711-10	Sample Location: 20831000-061KF									
Lead (⊘)		1030	ND	ppb	1.0	15	05/23/25 05:41	06/12/25	DST	
5052711-11	Sample Location: 20831000-062KF									
Lead (⊘)		1030	ND	ppb	1.0	15	05/23/25 05:41	06/12/25	DST	
5052711-12	Sample Location: 20831000-063KF									
Lead (⊘)		1030	ND	ppb	1.0	15	05/23/25 05:42	06/12/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 5052711

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5052711-13	Sample Location: 20831000-064KF									
Lead (⊕)		1030	ND	ppb	1.0	15	05/23/25 05:43	06/12/25	DST	
5052711-14	Sample Location: 20831000-065KF									
Lead (⊕)		1030	ND	ppb	1.0	15	05/23/25 05:43	06/12/25	DST	
5052711-15	Sample Location: 20831000-066KF									
Lead (⊕)		1030	4.9	ppb	1.0	15	05/23/25 05:43	06/12/25	DST	
5052711-16	Sample Location: 20831000-067CF									
Lead (⊕)		1030	3.0	ppb	1.0	15	05/23/25 05:47	06/12/25	DST	
5052711-17	Sample Location: 20831000-068DW									
Lead (⊕)		1030	2.2	ppb	1.0	15	05/23/25 05:47	06/12/25	DST	
5052711-18	Sample Location: 20831000-069BF									
Lead (⊕)		1030	ND	ppb	1.0	15	05/23/25 05:48	06/12/25	DST	
5052711-19	Sample Location: 20831000-070CF									
Lead (⊕)		1030	6.1	ppb	1.0	15	05/23/25 05:50	06/12/25	DST	
5052711-20	Sample Location: 20831000-071DW									
Lead (⊕)		1030	2.6	ppb	1.0	15	05/23/25 05:50	06/12/25	DST	
5052711-21	Sample Location: 20831000-072CF									
Lead (⊕)		1030	2.9	ppb	1.0	15	05/23/25 05:51	06/13/25	DST	
5052711-22	Sample Location: 20831000-073DW									
Lead (⊕)		1030	1.6	ppb	1.0	15	05/23/25 05:51	06/13/25	DST	
5052711-23	Sample Location: 20831000-074CF									
Lead (⊕)		1030	2.0	ppb	1.0	15	05/23/25 05:52	06/13/25	DST	
5052711-24	Sample Location: 20831000-075DW									
Lead (⊕)		1030	2.4	ppb	1.0	15	05/23/25 05:52	06/13/25	DST	
5052711-25	Sample Location: 20831000-076CF									
Lead (⊕)		1030	5.2	ppb	1.0	15	05/23/25 05:53	06/13/25	DST	
5052711-26	Sample Location: 20831000-077DW									
Lead (⊕)		1030	1.6	ppb	1.0	15	05/23/25 05:53	06/13/25	DST	
5052711-27	Sample Location: 20831000-078DW									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 5052711

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:55	06/13/25	DST	
5052711-28	Sample Location: 20831000-079DW									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:55	06/13/25	DST	
5052711-29	Sample Location: 20831000-080BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:56	06/13/25	DST	
5052711-30	Sample Location: 20831000-081BF									
Lead (±)		1030	1.0	ppb	1.0	15	05/23/25 05:56	06/13/25	DST	
5052711-31	Sample Location: 20831000-082BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:56	06/13/25	DST	
5052711-32	Sample Location: 20831000-083BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:57	06/13/25	DST	
5052711-33	Sample Location: 20831000-084BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 05:59	06/13/25	DST	
5052711-34	Sample Location: 20831000-085BF									
Lead (±)		1030	1.2	ppb	1.0	15	05/23/25 05:59	06/13/25	DST	
5052711-35	Sample Location: 20831000-086BF									
Lead (±)		1030	1.2	ppb	1.0	15	05/23/25 05:59	06/13/25	DST	
5052711-36	Sample Location: 20831000-087BF									
Lead (±)		1030	1.3	ppb	1.0	15	05/23/25 05:59	06/17/25	DST	
5052711-37	Sample Location: 20831000-088DW									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 06:00	06/17/25	DST	
5052711-38	Sample Location: 20831000-089DW									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 06:00	06/17/25	DST	
5052711-39	Sample Location: 20831000-090BF									
Lead (±)		1030	ND	ppb	1.0	15	05/23/25 06:01	06/17/25	DST	
5052711-40	Sample Location: 20831000-091CF									
Lead (±)		1030	3.0	ppb	1.0	15	05/23/25 06:02	06/17/25	DST	
5052711-41	Sample Location: 20831000-092DW									
Lead (±)		1030	2.6	ppb	1.0	15	05/23/25 06:02	06/17/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 5052711

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
5052711-42	Sample Location: 20831000-093CF									
Lead (♯)		1030	1.9	ppb	1.0	15	05/23/25 06:04	06/17/25	DST	
5052711-43	Sample Location: 20831000-094DW									
Lead (♯)		1030	1.7	ppb	1.0	15	05/23/25 06:05	06/17/25	DST	
5052711-44	Sample Location: 20831000-095CF									
Lead (♯)		1030	1.5	ppb	1.0	15	05/23/25 06:06	06/17/25	DST	
5052711-45	Sample Location: 20831000-096DW									
Lead (♯)		1030	2.2	ppb	1.0	15	05/23/25 06:06	06/17/25	DST	
5052711-46	Sample Location: 20831000-097CF									
Lead (♯)		1030	3.7	ppb	1.0	15	05/23/25 06:07	06/17/25	DST	
5052711-47	Sample Location: 20831000-098DW									
Lead (♯)		1030	1.4	ppb	1.0	15	05/23/25 06:07	06/17/25	DST	
5052711-48	Sample Location: 20831000-099CF									
Lead (♯)		1030	3.5	ppb	1.0	15	05/23/25 06:08	06/17/25	DST	
5052711-49	Sample Location: 20831000-100DW									
Lead (♯)		1030	1.5	ppb	1.0	15	05/23/25 06:08	06/17/25	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 5052711

### Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

---

Dan Phillips, Laboratory Manager