

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521210**LIMS Reference ID:** AD21210**EMSL Customer ID:** TTIE54**Attention:** Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / 90 Delaware Avenue

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

05/13/2025 09:00

Reported:

05/28/2025 19:33

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-1/Behind security desk 1st floor (Hydration System)-Water Fountain									
			Lims Reference ID:		AD21210-01	Matrix: Drinking Water		Sampled: 05/10/25 06:50:00	
Metals									
Lead	ND		1	1.00	µg/L	05/23/25 18:57	05/27/25 19:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-1/Cafeteria Serving Area 1st floor-Sink Faucet									
			Lims Reference ID:		AD21210-02	Matrix: Drinking Water		Sampled: 05/10/25 06:45:00	
Metals									
Lead	1.46		1	1.00	µg/L	05/23/25 18:57	05/28/25 08:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-2/Cafeteria Prep Area 1st floor-Sink Faucet									
			Lims Reference ID:		AD21210-03	Matrix: Drinking Water		Sampled: 05/10/25 06:46:00	
Metals									
Lead	ND		1	1.00	µg/L	05/23/25 18:57	05/28/25 08:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-3/Cafeteria Kitchen Area 1st floor-Sink Faucet									
			Lims Reference ID:		AD21210-04	Matrix: Drinking Water		Sampled: 05/10/25 06:47:00	
Metals									
Lead	1.58		1	1.00	µg/L	05/23/25 18:57	05/28/25 08:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-4/Cafeteria Kitchen Area 1st floor-Sink Faucet									
			Lims Reference ID:		AD21210-05	Matrix: Drinking Water		Sampled: 05/10/25 06:48:00	
Metals									
Lead	ND		1	1.00	µg/L	05/23/25 18:57	05/28/25 08:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-5/Legal Department Kitchen 2nd floor-Sink Faucet									
			Lims Reference ID:		AD21210-06	Matrix: Drinking Water		Sampled: 05/10/25 06:52:00	
Metals									
Lead	1.27		1	1.00	µg/L	05/23/25 18:57	05/28/25 08:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-2/By Stairway #1 2nd floor (Hydration System)-Water Fountain									
			Lims Reference ID:		AD21210-07	Matrix: Drinking Water		Sampled: 05/10/25 06:53:00	
Metals									
Lead	ND		1	1.00	µg/L	05/23/25 18:57	05/28/25 08:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-6/Kitchen 2nd floor-Sink Faucet									
			Lims Reference ID:		AD21210-08	Matrix: Drinking Water		Sampled: 05/10/25 06:55:00	
Metals									
Lead	ND		1	1.00	µg/L	05/23/25 18:57	05/28/25 08:18	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521210
LIMS Reference ID: AD21210
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477 / 90 Delaware Avenue

Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/13/2025 09:00
Reported: 05/28/2025 19:33

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SF-6/Kitchen 2nd floor-Sink Faucet (Continued) Lims Reference ID: AD21210-08 Matrix: Drinking Water Sampled: 05/10/25 06:55:00									
Metals (Continued)									
Sample: SF-7/Kitchen 3rd floor-Sink Faucet Lims Reference ID: AD21210-09 Matrix: Drinking Water Sampled: 05/10/25 06:57:00									
Metals									
Lead	ND		1	1.00	µg/L	05/28/25 09:44	05/28/25 12:18	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WF-3/Outside restrooms 3rd floor (Hydration System)-Water Fountain Lims Reference ID: AD21210-10 Matrix: Drinking Water Sampled: 05/10/25 06:58:00									
Metals									
Lead	ND		1	1.00	µg/L	05/28/25 09:44	05/28/25 12:24	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: SF-8/Kitchen 4th floor-Sink Faucet Lims Reference ID: AD21210-11 Matrix: Drinking Water Sampled: 05/10/25 07:00:00									
Metals									
Lead	ND		1	1.00	µg/L	05/28/25 09:44	05/28/25 12:26	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WF-4/Outside restrooms 4th floor (Hydration System)-Water Fountain Lims Reference ID: AD21210-12 Matrix: Drinking Water Sampled: 05/10/25 07:02:00									
Metals									
Lead	ND		1	1.00	µg/L	05/28/25 09:44	05/28/25 12:28	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WBF/Behind security desk 1st floor-Bottle Filler Lims Reference ID: AD21210-13 Matrix: Drinking Water Sampled: 05/10/25 06:50:00									
Metals									
Lead	ND		1	1.00	µg/L	05/28/25 09:44	05/28/25 12:30	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WBF/By Stairway #1 2nd floor-Bottle Filler Lims Reference ID: AD21210-14 Matrix: Drinking Water Sampled: 05/10/25 06:54:00									
Metals									
Lead	ND		1	1.00	µg/L	05/28/25 09:44	05/28/25 12:36	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: ICE M./Cafeteria-Ice Machine Lims Reference ID: AD21210-15 Matrix: Drinking Water Sampled: 05/10/25 06:49:00									
Metals									
Lead	ND		1	1.00	µg/L	05/28/25 09:44	05/28/25 12:38	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WBF/Outside restrooms 3rd floor-Bottle Filler Lims Reference ID: AD21210-16 Matrix: Drinking Water Sampled: 05/10/25 06:58:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521210**LIMS Reference ID:** AD21210**EMSL Customer ID:** TTIE54**Attention:** Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / 90 Delaware Avenue

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

05/13/2025 09:00

Reported:

05/28/2025 19:33

Analytical Results**(Continued)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	-----------------------	-----------------------	---------------------	----------------------------

Sample: WBF/Outside restrooms 3rd floor-Bottle
Filler (Continued)

Lims Reference ID: AD21210-16 Matrix: Drinking Water

Sampled: 05/10/25 06:58:00

Metals

Lead	ND	1	1.00	µg/L	05/28/25 09:44	05/28/25 12:39	JW1	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	-----	--------------------------

Sample: WBF/Outside restrooms 4th floor-Bottle
Filler

Lims Reference ID: AD21210-17 Matrix: Drinking Water

Sampled: 05/10/25 07:02:00

Metals

Lead	ND	1	1.00	µg/L	05/28/25 09:44	05/28/25 12:41	JW1	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	-----	--------------------------