

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517577**LIMS Reference ID:** AD17577**EMSL Customer ID:** TTIE54**Attention:** Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Ann Landoli Early Learning Center

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/19/2025 06:15

Reported:

05/06/2025 10:30

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-1/1st Floor Halfway by Room #3 Lims Reference ID: AD17577-01 Matrix: Drinking Water Sampled: 04/17/25 07:20:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 14:58	04/29/25 08:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-1B/1st Floor Halfway by Room #3 Lims Reference ID: AD17577-02 Matrix: Drinking Water Sampled: 04/17/25 07:21:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 14:58	04/29/25 08:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-1/Nurse Restroom Lims Reference ID: AD17577-03 Matrix: Drinking Water Sampled: 04/17/25 07:27:00									
Metals									
Lead	3.04		1	1.00	µg/L	04/28/25 14:58	04/29/25 08:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-2/Kitchen Dish Wash Sink Right Lims Reference ID: AD17577-04 Matrix: Drinking Water Sampled: 04/17/25 07:28:00									
Metals									
Lead	1.09		1	1.00	µg/L	04/28/25 14:58	04/29/25 08:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-3/Kitchen Dish Wash Sink Left Lims Reference ID: AD17577-05 Matrix: Drinking Water Sampled: 04/17/25 07:28:00									
Metals									
Lead	1.09		1	1.00	µg/L	04/28/25 14:58	04/29/25 08:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-4/Kitchen Back Door Exit Hand Wash Lims Reference ID: AD17577-06 Matrix: Drinking Water Sampled: 04/17/25 07:29:00									
Metals									
Lead	3.13		1	1.00	µg/L	04/28/25 14:58	04/29/25 09:04	PL	EPA 200.8 (DA)/EPA 200.8