

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012520717
LIMS Reference ID: AD20717
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477 / Warehouse - 200 Sheridan Avenue

Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 05/13/2025 09:00
Reported: 05/29/2025 18:29

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 1 - WFB-1/By Water Main - Bottle Filler Lims Reference ID: AD20717-01 Matrix: Drinking Water Sampled: 05/10/25 06:18:00									
Metals									
Lead	ND		1	1.00	µg/L	05/28/25 14:58	05/28/25 20:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 2 - SF-2/Food Services Offices - Sink Faucet Lims Reference ID: AD20717-02 Matrix: Drinking Water Sampled: 05/10/25 06:20:00									
Metals									
Lead	5.75		1	1.00	µg/L	05/28/25 14:58	05/28/25 21:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 3 - SF-3/Facilities Break Room - Sink Faucet Lims Reference ID: AD20717-03 Matrix: Drinking Water Sampled: 05/10/25 06:26:00									
Metals									
Lead	ND		1	1.00	µg/L	05/28/25 14:58	05/28/25 21:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 4 - WF-1/By Water Main - Water Fountain Lims Reference ID: AD20717-04 Matrix: Drinking Water Sampled: 05/10/25 06:19:00									
Metals									
Lead	ND		1	1.00	µg/L	05/28/25 14:54	05/29/25 15:23	JW1	EPA 200.8 (Dig)/EPA 200.8