

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517691
LIMS Reference ID: AD17691
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / International High School
(Baccalaureate World High School)-

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/02/2025 12:47

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 1 - WF-1/1st Fl. Hallway by 107 Lims Reference ID: AD17691-01 Matrix: Drinking Water Sampled: 04/17/25 07:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:34	04/30/25 09:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 2 - WF-2/1st Fl. Hallway by 107 Lims Reference ID: AD17691-02 Matrix: Drinking Water Sampled: 04/17/25 07:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 3 - WFB-2/1st Fl. Hallway by 107 Lims Reference ID: AD17691-03 Matrix: Drinking Water Sampled: 04/17/25 07:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 4 - WF-3/1st Fl. Hallway by Main Gym Lims Reference ID: AD17691-04 Matrix: Drinking Water Sampled: 04/17/25 07:02:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 5 - WF-4/1st Fl. Hallway by Main Gym Lims Reference ID: AD17691-05 Matrix: Drinking Water Sampled: 04/17/25 07:02:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 6 - WF-5/1st Fl. Hallway by Main Gym Lims Reference ID: AD17691-06 Matrix: Drinking Water Sampled: 04/17/25 07:02:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 7 - WFB-5/1st Fl. Hallway by Main Gym Lims Reference ID: AD17691-07 Matrix: Drinking Water Sampled: 04/17/25 07:02:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 8 - WF-6/1st Fl. Hallway by Main Gym Lims Reference ID: AD17691-08 Matrix: Drinking Water Sampled: 04/17/25 07:02:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 9 - WF-7/2nd Fl. by Staircase 1 Lims Reference ID: AD17691-09 Matrix: Drinking Water Sampled: 04/17/25 07:05:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:20	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517691
LIMS Reference ID: AD17691
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / International High School
(Baccalaureate World High School)-

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/02/2025 12:47

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 10 - WF-8/2nd Fl. by Staircase 1 Lims Reference ID: AD17691-10 Matrix: Drinking Water Sampled: 04/17/25 07:05:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 11 - SF-1/Room 210 Lims Reference ID: AD17691-11 Matrix: Drinking Water Sampled: 04/17/25 07:06:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12 - SF-2/Room 210 Lims Reference ID: AD17691-12 Matrix: Drinking Water Sampled: 04/17/25 07:06:00									
Metals									
Lead	1.39		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 13 - WF-9/2nd Fl. Cafeteria Lims Reference ID: AD17691-13 Matrix: Drinking Water Sampled: 04/17/25 07:10:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 14 - WF-10/2nd Fl. Cafeteria Lims Reference ID: AD17691-14 Matrix: Drinking Water Sampled: 04/17/25 07:10:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 15 - SF-3/Teachers Room 212 Lims Reference ID: AD17691-15 Matrix: Drinking Water Sampled: 04/17/25 07:10:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 16 - SF-4/2nd Fl. Kitchen Lims Reference ID: AD17691-16 Matrix: Drinking Water Sampled: 04/17/25 07:11:00									
Metals									
Lead	1.51		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 17 - SF-5/2nd Fl. Kitchen Lims Reference ID: AD17691-17 Matrix: Drinking Water Sampled: 04/17/25 07:12:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 18 - SF-6/2nd Fl. Kitchen Lims Reference ID: AD17691-18 Matrix: Drinking Water Sampled: 04/17/25 07:13:00									
Metals									
Lead	6.29		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:45	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517691**LIMS Reference ID:** AD17691**EMSL Customer ID:** TTIE54**Attention:** Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / International High School
(Baccalaureate World High School)-

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/02/2025 12:47

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 19 - SF-7/2nd Fl. Kitchen Lims Reference ID: AD17691-19 Matrix: Drinking Water Sampled: 04/17/25 07:14:00									
Metals									
Lead	1.45		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 20 - SF-8/2nd Fl. Kitchen Lims Reference ID: AD17691-20 Matrix: Drinking Water Sampled: 04/17/25 07:15:00									
Metals									
Lead	27.2		1	1.00	µg/L	04/29/25 14:34	04/30/25 10:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 21 - SF-9/2nd Fl. Kitchen Lims Reference ID: AD17691-21 Matrix: Drinking Water Sampled: 04/17/25 07:15:00									
Metals									
Lead	9.13		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 22 - SF-10/2nd Fl. Kitchen Lims Reference ID: AD17691-22 Matrix: Drinking Water Sampled: 04/17/25 07:16:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 23 - WF-11/2nd Fl. by Staircase 2 Lims Reference ID: AD17691-23 Matrix: Drinking Water Sampled: 04/17/25 07:20:00									
Metals									
Lead	2.95		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 24 - WF-12/2nd Fl. by Staircase 2 Lims Reference ID: AD17691-24 Matrix: Drinking Water Sampled: 04/17/25 07:20:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 25 - WFB-12/2nd Fl. by Staircase 2 Lims Reference ID: AD17691-25 Matrix: Drinking Water Sampled: 04/17/25 07:20:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 26 - SF-11/2nd Fl. Nurse Office Lims Reference ID: AD17691-26 Matrix: Drinking Water Sampled: 04/17/25 07:20:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 27 - SF-12/3rd Fl. Teachers Room 311 Lims Reference ID: AD17691-27 Matrix: Drinking Water Sampled: 04/17/25 07:22:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:21	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517691
LIMS Reference ID: AD17691
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / International High School
(Baccalaureate World High School)-

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/02/2025 12:47

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 28 - WF-13/3rd Fl. by Staircase 1 Lims Reference ID: AD17691-28 Matrix: Drinking Water Sampled: 04/17/25 07:25:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 29 - WF-14/3rd Fl. by Staircase 1 Lims Reference ID: AD17691-29 Matrix: Drinking Water Sampled: 04/17/25 07:25:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 30 - WF-15/3rd Fl. by Staircase 2 Lims Reference ID: AD17691-30 Matrix: Drinking Water Sampled: 04/17/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 31 - WFB15/3rd Fl. by Staircase 2 Lims Reference ID: AD17691-31 Matrix: Drinking Water Sampled: 04/17/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 32 - WF16/3rd Fl. by Staircase 2 Lims Reference ID: AD17691-32 Matrix: Drinking Water Sampled: 04/17/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 33 - WF-17/4th Fl. by Staircase 2 Lims Reference ID: AD17691-33 Matrix: Drinking Water Sampled: 04/17/25 07:40:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 34 - WF18/4th Fl. by Staircase 2 Lims Reference ID: AD17691-34 Matrix: Drinking Water Sampled: 04/17/25 07:41:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 35 - SF-13/4th Fl. Teachers Room 411 Lims Reference ID: AD17691-35 Matrix: Drinking Water Sampled: 04/17/25 07:42:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 36 - WF-19/4th Fl. by Staircase 1 Lims Reference ID: AD17691-36 Matrix: Drinking Water Sampled: 04/17/25 07:45:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:46	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517691**LIMS Reference ID:** AD17691**EMSL Customer ID:** TTIE54**Attention:** Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / International High School
(Baccalaureate World High School)-

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/02/2025 12:47

Analytical Results**(Continued)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 37 - WF-20/4th Fl. by Staircase 1 Lims Reference ID: AD17691-37 Matrix: Drinking Water Sampled: 04/17/25 07:50:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 38 - WFB20/4th Fl. by Staircase 1 Lims Reference ID: AD17691-38 Matrix: Drinking Water Sampled: 04/17/25 07:50:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 39 - WFB-8/2nd Fl. by Staircase 1 Lims Reference ID: AD17691-39 Matrix: Drinking Water Sampled: 04/17/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 40 - Blank Lims Reference ID: AD17691-40 Matrix: Drinking Water Sampled: 04/17/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 14:35	04/30/25 11:53	PL	EPA 200.8 (DA)/EPA 200.8