

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517696
LIMS Reference ID: AD17696
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477 / Dr. Hani Awadallah School

Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/18/2025 09:00
Reported: 05/02/2025 12:49

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-1/Lobby L Lims Reference ID: AD17696-01 Matrix: Drinking Water Sampled: 04/17/25 07:18:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 09:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-2/Lobby R Lims Reference ID: AD17696-02 Matrix: Drinking Water Sampled: 04/17/25 07:18:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 09:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-3/Boy's Locker Room Lims Reference ID: AD17696-03 Matrix: Drinking Water Sampled: 04/17/25 07:22:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 09:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-4/Girl's Locker Room Lims Reference ID: AD17696-04 Matrix: Drinking Water Sampled: 04/17/25 07:23:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 09:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-5/Outside Gym L Lims Reference ID: AD17696-05 Matrix: Drinking Water Sampled: 04/17/25 07:24:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 10:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-6/Outside Gym R Lims Reference ID: AD17696-06 Matrix: Drinking Water Sampled: 04/17/25 07:24:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 10:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-1/Kitchen Lims Reference ID: AD17696-07 Matrix: Drinking Water Sampled: 04/17/25 07:28:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 10:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-2/Kitchen Lims Reference ID: AD17696-08 Matrix: Drinking Water Sampled: 04/17/25 07:28:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 10:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-3/Kitchen Lims Reference ID: AD17696-09 Matrix: Drinking Water Sampled: 04/17/25 07:29:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 10:12	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517696**LIMS Reference ID:** AD17696**EMSL Customer ID:** TTIE54**Attention:** Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Dr. Hani Awadallah School

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/02/2025 12:49

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SF-4/Kitchen Lims Reference ID: AD17696-10 Matrix: Drinking Water Sampled: 04/17/25 07:29:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 10:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-5/Kitchen Lims Reference ID: AD17696-11 Matrix: Drinking Water Sampled: 04/17/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 10:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-6/Kitchen Lims Reference ID: AD17696-12 Matrix: Drinking Water Sampled: 04/17/25 07:31:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 10:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-7/Kitchen Lims Reference ID: AD17696-13 Matrix: Drinking Water Sampled: 04/17/25 07:31:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 10:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-8/Kitchen Lims Reference ID: AD17696-14 Matrix: Drinking Water Sampled: 04/17/25 07:32:00									
Metals									
Lead	2.10		1	1.00	µg/L	04/28/25 15:06	04/29/25 10:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-9/Kitchen Lims Reference ID: AD17696-15 Matrix: Drinking Water Sampled: 04/17/25 07:32:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 10:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-7/K-128 Lims Reference ID: AD17696-16 Matrix: Drinking Water Sampled: 04/17/25 07:36:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 10:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-8/K-126 Lims Reference ID: AD17696-17 Matrix: Drinking Water Sampled: 04/17/25 07:37:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 10:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-9/K-124 Lims Reference ID: AD17696-18 Matrix: Drinking Water Sampled: 04/17/25 07:38:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 10:36	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517696
LIMS Reference ID: AD17696
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477 / Dr. Hani Awadallah School

Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/18/2025 09:00
Reported: 05/02/2025 12:49

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-10/K-122 Lims Reference ID: AD17696-19 Matrix: Drinking Water Sampled: 04/17/25 07:39:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 10:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-10/Nurse 123-2 Lims Reference ID: AD17696-20 Matrix: Drinking Water Sampled: 04/17/25 07:40:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:06	04/29/25 10:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-11/Outside 109 L Lims Reference ID: AD17696-21 Matrix: Drinking Water Sampled: 04/17/25 07:41:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:07	04/29/25 10:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-12/Outside 109 R Lims Reference ID: AD17696-22 Matrix: Drinking Water Sampled: 04/17/25 07:42:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:07	04/29/25 10:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-13/Outside Media L Lims Reference ID: AD17696-23 Matrix: Drinking Water Sampled: 04/17/25 07:43:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:07	04/29/25 10:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-14/Outside Media R Lims Reference ID: AD17696-24 Matrix: Drinking Water Sampled: 04/17/25 07:44:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:07	04/29/25 11:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-15/By Room 210 L Lims Reference ID: AD17696-25 Matrix: Drinking Water Sampled: 04/17/25 07:45:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:07	04/29/25 11:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-16/By Room 210 R Lims Reference ID: AD17696-26 Matrix: Drinking Water Sampled: 04/17/25 07:46:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:07	04/29/25 11:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-17/By Stair 4 L Lims Reference ID: AD17696-27 Matrix: Drinking Water Sampled: 04/17/25 07:48:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:07	04/29/25 11:10	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517696
LIMS Reference ID: AD17696
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Dr. Hani Awadallah School

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/02/2025 12:49

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-18/By Stair 4 R Lims Reference ID: AD17696-28 Matrix: Drinking Water Sampled: 04/17/25 07:49:00									
Metals									
Lead	ND	1	1.00		µg/L	04/28/25 15:07	04/29/25 11:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-11/Faculty Room Lims Reference ID: AD17696-29 Matrix: Drinking Water Sampled: 04/17/25 07:34:00									
Metals									
Lead	ND	1	1.00		µg/L	04/28/25 15:07	04/29/25 11:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-1B/Main Lobby Left Bottle Filler Lims Reference ID: AD17696-30 Matrix: Drinking Water Sampled: 04/17/25 07:18:00									
Metals									
Lead	ND	1	1.00		µg/L	04/28/25 15:07	04/29/25 11:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-11B/Outside 109 Left Bottle Filler Lims Reference ID: AD17696-31 Matrix: Drinking Water Sampled: 04/17/25 07:41:00									
Metals									
Lead	ND	1	1.00		µg/L	04/28/25 15:07	04/29/25 11:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-15B/By Room 210 Left Bottle Filler Lims Reference ID: AD17696-32 Matrix: Drinking Water Sampled: 04/17/25 07:45:00									
Metals									
Lead	ND	1	1.00		µg/L	04/28/25 15:07	04/29/25 11:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-17B/By Stair 4 Left Bottle Filler Lims Reference ID: AD17696-33 Matrix: Drinking Water Sampled: 04/17/25 07:50:00									
Metals									
Lead	ND	1	1.00		µg/L	04/28/25 15:07	04/29/25 11:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB/Outside Gym - Left Lims Reference ID: AD17696-34 Matrix: Drinking Water Sampled: 04/17/25 07:40:00									
Metals									
Lead	ND	1	1.00		µg/L	04/28/25 15:07	04/29/25 11:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF/Nurse Office Lims Reference ID: AD17696-35 Matrix: Drinking Water Sampled: 04/17/25 07:41:00									
Metals									
Lead	ND	1	1.00		µg/L	04/28/25 15:07	04/29/25 11:33	PL	EPA 200.8 (DA)/EPA 200.8