

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517694
LIMS Reference ID: AD17694
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Eastside High School

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

04/30/2025 20:04

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: Sink-1/Kitchen - Sink Faucet Lims Reference ID: AD17694-01 Matrix: Drinking Water Sampled: 04/15/25 07:00:00									
Metals									
Lead	2.02		1	1.00	µg/L	04/23/25 16:19	04/24/25 17:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Sink-2/Kitchen - Sink Faucet Lims Reference ID: AD17694-02 Matrix: Drinking Water Sampled: 04/15/25 07:01:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:19	04/24/25 17:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Sink-3/Kitchen - Sink Faucet Lims Reference ID: AD17694-03 Matrix: Drinking Water Sampled: 04/15/25 07:02:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:19	04/24/25 17:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Sink-4/Kitchen - Sink Faucet Lims Reference ID: AD17694-04 Matrix: Drinking Water Sampled: 04/15/25 07:03:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:19	04/24/25 17:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Sink-5/Kitchen - Sink Faucet Lims Reference ID: AD17694-05 Matrix: Drinking Water Sampled: 04/15/25 07:04:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:19	04/24/25 17:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Sink-6/Kitchen - Sink Faucet Lims Reference ID: AD17694-06 Matrix: Drinking Water Sampled: 04/15/25 07:05:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:19	04/24/25 17:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Sink-7/Cafeteria Serving Area - Sink Faucet Lims Reference ID: AD17694-07 Matrix: Drinking Water Sampled: 04/15/25 07:06:00									
Metals									
Lead	2.99		1	1.00	µg/L	04/23/25 16:19	04/24/25 17:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Sink-8/Cafeteria Serving Area - Sink Faucet Lims Reference ID: AD17694-08 Matrix: Drinking Water Sampled: 04/15/25 07:08:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:19	04/24/25 17:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-2/By Room 19 - Bottle Filler Lims Reference ID: AD17694-09 Matrix: Drinking Water Sampled: 04/15/25 07:11:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:19	04/24/25 17:48	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517694
LIMS Reference ID: AD17694
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Eastside High School

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

04/30/2025 20:04

Analytical Results**(Continued)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WFB-3/By Room 03X - Bottle Filler Lims Reference ID: AD17694-10 Matrix: Drinking Water Sampled: 04/15/25 07:12:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:19	04/24/25 17:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-4/By Room 10 - Water Fountain Lims Reference ID: AD17694-11 Matrix: Drinking Water Sampled: 04/15/25 07:13:00									
Metals									
Lead	14.1		1	1.00	µg/L	04/23/25 16:19	04/24/25 17:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-5/By Room 05 - Water Fountain Lims Reference ID: AD17694-12 Matrix: Drinking Water Sampled: 04/15/25 07:15:00									
Metals									
Lead	5.06		1	1.00	µg/L	04/23/25 16:19	04/24/25 17:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-6/Boys Locker Room - Water Fountain Lims Reference ID: AD17694-13 Matrix: Drinking Water Sampled: 04/15/25 07:20:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:19	04/24/25 17:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-7/Cafeteria North - Water Fountain Lims Reference ID: AD17694-14 Matrix: Drinking Water Sampled: 04/15/25 07:25:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:19	04/24/25 18:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-8/Cafeteria South - Water Fountain Lims Reference ID: AD17694-15 Matrix: Drinking Water Sampled: 04/15/25 07:25:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:19	04/24/25 18:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-9/By Room 127 - Water Fountain Lims Reference ID: AD17694-16 Matrix: Drinking Water Sampled: 04/15/25 07:26:00									
Metals									
Lead	1.74		1	1.00	µg/L	04/23/25 16:19	04/24/25 18:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-10/By Room 122-123 - Bottle Filler Lims Reference ID: AD17694-17 Matrix: Drinking Water Sampled: 04/15/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:19	04/24/25 18:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-11/By Room 150 - Bottle Filler Lims Reference ID: AD17694-18 Matrix: Drinking Water Sampled: 04/15/25 07:32:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:19	04/24/25 18:13	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517694
LIMS Reference ID: AD17694
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Eastside High School

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

04/30/2025 20:04

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-12/1st Floor Stairway #1 - Water Fountain Lims Reference ID: AD17694-19 Matrix: Drinking Water Sampled: 04/15/25 07:33:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:19	04/24/25 18:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-13/By Office 102 - Bottle Filler Lims Reference ID: AD17694-20 Matrix: Drinking Water Sampled: 04/15/25 07:34:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:19	04/24/25 18:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-14/Gym Entrance - Water Fountain Lims Reference ID: AD17694-21 Matrix: Drinking Water Sampled: 04/15/25 07:35:00									
Metals									
Lead	1.19		1	1.00	µg/L	04/23/25 16:22	04/24/25 18:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-15/Gym Entrance - Water Fountain Lims Reference ID: AD17694-22 Matrix: Drinking Water Sampled: 04/15/25 07:35:00									
Metals									
Lead	2.88		1	1.00	µg/L	04/23/25 16:22	04/24/25 18:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: ICE M1/Room 112 - Ice Machine Lims Reference ID: AD17694-23 Matrix: Drinking Water Sampled: 04/15/25 07:40:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:22	04/24/25 18:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-19/Room 106 - Sink Faucet Lims Reference ID: AD17694-24 Matrix: Drinking Water Sampled: 04/15/25 07:42:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:22	04/24/25 18:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-16/By Room 107 - Water Fountain Lims Reference ID: AD17694-25 Matrix: Drinking Water Sampled: 04/15/25 07:43:00									
Metals									
Lead	14.2		1	1.00	µg/L	04/23/25 16:22	04/24/25 18:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-17/Room 107 - Sink Faucet Lims Reference ID: AD17694-26 Matrix: Drinking Water Sampled: 04/15/25 07:50:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:22	04/24/25 18:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-10/Room 109 - Sink Faucet Lims Reference ID: AD17694-27 Matrix: Drinking Water Sampled: 04/15/25 07:51:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:22	04/24/25 18:53	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517694
LIMS Reference ID: AD17694
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Eastside High School

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

04/30/2025 20:04

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SF-11/Room 109 - Sink Faucet Lims Reference ID: AD17694-28 Matrix: Drinking Water Sampled: 04/15/25 07:52:00									
Metals									
Lead	ND	1	1.00		µg/L	04/23/25 16:22	04/24/25 18:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-12/Room 109 - Sink Faucet Lims Reference ID: AD17694-29 Matrix: Drinking Water Sampled: 04/15/25 07:52:00									
Metals									
Lead	ND	1	1.00		µg/L	04/23/25 16:22	04/24/25 18:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-13/Room 109 - Sink Faucet Lims Reference ID: AD17694-30 Matrix: Drinking Water Sampled: 04/15/25 07:53:00									
Metals									
Lead	ND	1	1.00		µg/L	04/23/25 16:22	04/24/25 18:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-14/Room 109 - Sink Faucet Lims Reference ID: AD17694-31 Matrix: Drinking Water Sampled: 04/15/25 07:54:00									
Metals									
Lead	ND	1	1.00		µg/L	04/23/25 16:22	04/24/25 19:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-15/Room 109 - Sink Faucet Lims Reference ID: AD17694-32 Matrix: Drinking Water Sampled: 04/15/25 07:55:00									
Metals									
Lead	ND	1	1.00		µg/L	04/23/25 16:22	04/24/25 19:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-16/Room 109 - Sink Faucet Lims Reference ID: AD17694-33 Matrix: Drinking Water Sampled: 04/15/25 07:55:00									
Metals									
Lead	ND	1	1.00		µg/L	04/23/25 16:22	04/24/25 19:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: ICE M2/Room 109 - Ice Machine Lims Reference ID: AD17694-34 Matrix: Drinking Water Sampled: 04/15/25 07:56:00									
Metals									
Lead	ND	1	1.00		µg/L	04/23/25 16:22	04/24/25 19:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-9/Nurse Office 115 - Sink Faucet Lims Reference ID: AD17694-35 Matrix: Drinking Water Sampled: 04/15/25 08:00:00									
Metals									
Lead	ND	1	1.00		µg/L	04/23/25 16:22	04/24/25 19:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-17/By Room 224 - Bottle Filler Lims Reference ID: AD17694-36 Matrix: Drinking Water Sampled: 04/15/25 08:15:00									
Metals									
Lead	3.70	1	1.00		µg/L	04/23/25 16:22	04/24/25 19:18	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517694
LIMS Reference ID: AD17694
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Eastside High School

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

04/30/2025 20:04

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WFB-18/By Room 202 - Bottle Filler Lims Reference ID: AD17694-37 Matrix: Drinking Water Sampled: 04/15/25 08:17:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:22	04/24/25 19:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-18/By Room 206-207 - Water Fountain Lims Reference ID: AD17694-38 Matrix: Drinking Water Sampled: 04/15/25 08:20:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:22	04/24/25 19:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-19/By Room 241 - Bottle Filler Lims Reference ID: AD17694-39 Matrix: Drinking Water Sampled: 04/15/25 08:25:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:22	04/24/25 19:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-20/By Room 220 - Bottle Filler Lims Reference ID: AD17694-40 Matrix: Drinking Water Sampled: 04/15/25 08:26:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:22	04/24/25 19:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-21/By Room 300 - Bottle Filler Lims Reference ID: AD17694-41 Matrix: Drinking Water Sampled: 04/15/25 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 09:40	04/24/25 23:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-22/By Room 321 - Bottle Filler Lims Reference ID: AD17694-42 Matrix: Drinking Water Sampled: 04/15/25 08:31:00									
Metals									
Lead	1.36		1	1.00	µg/L	04/24/25 09:40	04/24/25 23:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-23/By Room 316 - Water Fountain Lims Reference ID: AD17694-43 Matrix: Drinking Water Sampled: 04/15/25 08:35:00									
Metals									
Lead	1.33		1	1.00	µg/L	04/24/25 09:40	04/24/25 23:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-24/TCU-CY1 - Water Fountain Lims Reference ID: AD17694-44 Matrix: Drinking Water Sampled: 04/15/25 08:55:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 09:40	04/24/25 23:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-25/TCU-CY2 - Water Fountain Lims Reference ID: AD17694-45 Matrix: Drinking Water Sampled: 04/15/25 08:56:00									
Metals									
Lead	1.37		1	1.00	µg/L	04/24/25 09:40	04/24/25 23:40	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517694
LIMS Reference ID: AD17694
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Eastside High School

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

04/30/2025 20:04

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-26/TCU-CY3 - Water Fountain Lims Reference ID: AD17694-46 Matrix: Drinking Water Sampled: 04/15/25 08:57:00									
Metals									
Lead	2.35		1	1.00	µg/L	04/24/25 09:40	04/24/25 23:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-27/TCU-CY4 - Water Fountain Lims Reference ID: AD17694-47 Matrix: Drinking Water Sampled: 04/15/25 08:58:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 09:40	04/24/25 23:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-28/TCU-CY5- Water Fountain Lims Reference ID: AD17694-48 Matrix: Drinking Water Sampled: 04/15/25 08:59:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 09:40	04/24/25 23:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-29/TCU-CY6- Water Fountain Lims Reference ID: AD17694-49 Matrix: Drinking Water Sampled: 04/15/25 09:00:00									
Metals									
Lead	1.57		1	1.00	µg/L	04/24/25 09:40	04/24/25 23:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-30/Room 5 Cosmetology - Bottle Filler Lims Reference ID: AD17694-50 Matrix: Drinking Water Sampled: 04/15/25 09:05:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 09:40	04/24/25 23:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-1S/Basement by Staircase #2 - Water Fountain Lims Reference ID: AD17694-51 Matrix: Drinking Water Sampled: 04/15/25 07:10:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 09:40	04/24/25 23:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-2S/By Room #19 - Water Fountain Lims Reference ID: AD17694-52 Matrix: Drinking Water Sampled: 04/15/25 07:11:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 09:40	04/25/25 00:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-3S/By Room 03X - Water Fountain Lims Reference ID: AD17694-53 Matrix: Drinking Water Sampled: 04/15/25 07:12:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 09:40	04/25/25 00:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-10S/By Room 122-123 - Water Fountain Lims Reference ID: AD17694-54 Matrix: Drinking Water Sampled: 04/15/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 09:40	04/25/25 00:08	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517694**LIMS Reference ID:** AD17694**EMSL Customer ID:** TTIE54**Attention:** Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Eastside High School

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

04/30/2025 20:04

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-11S/By Room 150 - Water Fountain Lims Reference ID: AD17694-55 Matrix: Drinking Water Sampled: 04/15/25 07:32:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 09:40	04/25/25 00:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-17/By Room 224 - Water Fountain Lims Reference ID: AD17694-57 Matrix: Drinking Water Sampled: 04/15/25 08:15:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 09:40	04/25/25 00:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-19/By Room 241 - Water Fountain Lims Reference ID: AD17694-58 Matrix: Drinking Water Sampled: 04/15/25 08:25:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 09:40	04/25/25 00:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-30/Room 5 Cosmetology - Water Fountain Lims Reference ID: AD17694-62 Matrix: Drinking Water Sampled: 04/15/25 09:05:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 09:40	04/25/25 00:16	PL	EPA 200.8 (DA)/EPA 200.8