

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517689
LIMS Reference ID: AD17689
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477 / Panther Academy

Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/18/2025 09:00
Reported: 05/02/2025 12:46

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WFB-1/1st Floor Hallway Lims Reference ID: AD17689-01 Matrix: Drinking Water Sampled: 04/16/25 08:35:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:27	04/29/25 16:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-1/Nurse Office Lims Reference ID: AD17689-02 Matrix: Drinking Water Sampled: 04/16/25 08:40:00									
Metals									
Lead	3.30		1	1.00	µg/L	04/28/25 15:27	04/29/25 16:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-2/1st Floor Faculty Room Lims Reference ID: AD17689-03 Matrix: Drinking Water Sampled: 04/16/25 08:40:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:27	04/29/25 16:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-2/2nd Floor Hallway Lims Reference ID: AD17689-04 Matrix: Drinking Water Sampled: 04/16/25 08:45:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:27	04/29/25 16:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-1/5/1st Floor Hallway Lims Reference ID: AD17689-05 Matrix: Drinking Water Sampled: 04/16/25 08:35:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:27	04/29/25 16:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-2/5/2nd Floor Hallway Lims Reference ID: AD17689-06 Matrix: Drinking Water Sampled: 04/16/25 08:45:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:27	04/29/25 16:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Blank/Blank Lims Reference ID: AD17689-07 Matrix: Drinking Water Sampled: 04/16/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:27	04/29/25 16:41	PL	EPA 200.8 (DA)/EPA 200.8