

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517986
LIMS Reference ID: AD17986
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Public School #4

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

05/01/2025 12:52

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 1-WF1B/Main Lobby Lims Reference ID: AD17986-01 Matrix: Drinking Water Sampled: 04/15/25 08:47:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 09:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 2-WFB2/By Boys Bathroom Lims Reference ID: AD17986-02 Matrix: Drinking Water Sampled: 04/15/25 08:51:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 09:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 3-SF1/Kitchen Lims Reference ID: AD17986-03 Matrix: Drinking Water Sampled: 04/15/25 08:54:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 09:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 4-WF10/Girls Bathroom Lims Reference ID: AD17986-04 Matrix: Drinking Water Sampled: 04/15/25 08:56:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 09:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 5-WF-11/Girls Bathroom Lims Reference ID: AD17986-05 Matrix: Drinking Water Sampled: 04/15/25 08:57:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 09:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 6-WFB3/Across Teachers Room 2nd Floor Lims Reference ID: AD17986-06 Matrix: Drinking Water Sampled: 04/15/25 09:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 09:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 7-SF2/Teachers Lounge 2nd Floor Lims Reference ID: AD17986-07 Matrix: Drinking Water Sampled: 04/15/25 09:08:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 09:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 8-SF3/Nurse Lims Reference ID: AD17986-08 Matrix: Drinking Water Sampled: 04/15/25 09:09:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 10:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 9-WFB4/Across Room 209 Lims Reference ID: AD17986-09 Matrix: Drinking Water Sampled: 04/15/25 09:13:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 10:02	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517986
LIMS Reference ID: AD17986
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Public School #4

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

05/01/2025 12:52

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 10-WFBS/Across Room 303 Lims Reference ID: AD17986-10 Matrix: Drinking Water Sampled: 04/15/25 09:19:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 10:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 11-WFB6/Across Room 313 Lims Reference ID: AD17986-11 Matrix: Drinking Water Sampled: 04/15/25 09:21:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 10:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-WF7B/Across Room 413 Lims Reference ID: AD17986-12 Matrix: Drinking Water Sampled: 04/15/25 09:28:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 10:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 13-WFB8/Across Room 403 Lims Reference ID: AD17986-13 Matrix: Drinking Water Sampled: 04/15/25 09:30:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 10:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 14-Field Blank/Field Blank Lims Reference ID: AD17986-14 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 10:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 15-WF-1/Main Lobby Lims Reference ID: AD17986-15 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 10:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 16-WF-2/1st Floor Boys Bathroom Lims Reference ID: AD17986-16 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 10:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 17-WF-6/Teacher Lounge 2nd Floor Lims Reference ID: AD17986-17 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 10:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 19-WF-9/3rd Floor Next to 303 Lims Reference ID: AD17986-18 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 10:27	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517986
LIMS Reference ID: AD17986
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Public School #4

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

05/01/2025 12:52

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 20-WF-10/Across From 313 3rd Floor Lims Reference ID: AD17986-19 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 10:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 21-WF-11/Across From 413 4th Floor Lims Reference ID: AD17986-20 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:55	04/25/25 10:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 22-WF-12/Across From 403 4th Floor Lims Reference ID: AD17986-21 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:56	04/25/25 11:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 23-WF-8/Across From 209 2nd Floor Lims Reference ID: AD17986-22 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:56	04/25/25 11:16	PL	EPA 200.8 (DA)/EPA 200.8