

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517443
LIMS Reference ID: AD17443
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477 / Paterson Public Schools / Public
School #5 / 430 Totowa Ave, Paterson, NJ
07502
Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/16/2025 09:00
Reported: 04/30/2025 17:43

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WFB-1/Hallway by Cafeteria Lims Reference ID: AD17443-01 Matrix: Drinking Water Sampled: 04/14/25 11:36:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:59	04/25/25 07:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-1/Hallway by Cafeteria Lims Reference ID: AD17443-02 Matrix: Drinking Water Sampled: 04/14/25 11:36:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:59	04/25/25 07:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-1/Kitchen Lims Reference ID: AD17443-03 Matrix: Drinking Water Sampled: 04/14/25 11:38:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:59	04/25/25 07:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-5/Sink by Cafe B Lims Reference ID: AD17443-04 Matrix: Drinking Water Sampled: 04/14/25 11:43:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:59	04/25/25 08:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-2/Teacher's Room Lims Reference ID: AD17443-05 Matrix: Drinking Water Sampled: 04/14/25 11:50:00									
Metals									
Lead	3.22		1	1.00	µg/L	04/24/25 14:59	04/25/25 08:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-3/Nurse Office Lims Reference ID: AD17443-06 Matrix: Drinking Water Sampled: 04/14/25 11:52:00									
Metals									
Lead	13.8		1	1.00	µg/L	04/24/25 14:59	04/25/25 08:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-2/Hallway Across Room 101 Lims Reference ID: AD17443-07 Matrix: Drinking Water Sampled: 04/14/25 11:53:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:59	04/25/25 08:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-2/Hallway Across Room 102 Lims Reference ID: AD17443-08 Matrix: Drinking Water Sampled: 04/14/25 11:56:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:59	04/25/25 08:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-3/Hallway Across Room 201 Lims Reference ID: AD17443-09 Matrix: Drinking Water Sampled: 04/14/25 11:59:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:59	04/25/25 08:13	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517443
LIMS Reference ID: AD17443
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Paterson Public Schools / Public
School #5 / 430 Totowa Ave, Paterson, NJ
07502

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

04/30/2025 17:43

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-3/Hallway Across Room 202									
Lims Reference ID:				AD17443-10		Matrix: Drinking Water		Sampled: 04/14/25 11:59:00	
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:59	04/25/25 08:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-4/Hallway Across Room 303									
Lims Reference ID:				AD17443-11		Matrix: Drinking Water		Sampled: 04/14/25 12:02:00	
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:59	04/25/25 08:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-4/Hallway Across Room 304									
Lims Reference ID:				AD17443-12		Matrix: Drinking Water		Sampled: 04/14/25 12:02:00	
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:59	04/25/25 08:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-4/Teacher's Lounge									
Lims Reference ID:				AD17443-13		Matrix: Drinking Water		Sampled: 04/14/25 12:04:00	
Metals									
Lead	7.04		1	1.00	µg/L	04/24/25 14:59	04/25/25 08:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Field Blank/Field Blank									
Lims Reference ID:				AD17443-14		Matrix: Drinking Water		Sampled: 04/14/25 00:00:00	
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:59	04/25/25 08:30	PL	EPA 200.8 (DA)/EPA 200.8