

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517686**LIMS Reference ID:** AD17686**EMSL Customer ID:** TTIE54**Attention:** Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Joseph A. Taub School

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/05/2025 17:20

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 1 - SF-1/CR1-1 Custodian Workroom Lims Reference ID: AD17686-01 Matrix: Drinking Water Sampled: 04/17/25 08:22:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 07:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 2 - SF-2/104 FSCS Community Room Lims Reference ID: AD17686-02 Matrix: Drinking Water Sampled: 04/17/25 08:23:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 07:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 3 - SF-3/D112 FSCS Health Center WFB-1 Lims Reference ID: AD17686-03 Matrix: Drinking Water Sampled: 04/17/25 08:24:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 07:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 4 - WFB-1/Cafetorium Lims Reference ID: AD17686-04 Matrix: Drinking Water Sampled: 04/17/25 08:25:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 07:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 5 - SF-4/Kitchen Lims Reference ID: AD17686-05 Matrix: Drinking Water Sampled: 04/17/25 08:27:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 07:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 6 - Ice Mach/Kitchen Lims Reference ID: AD17686-06 Matrix: Drinking Water Sampled: 04/17/25 08:28:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 08:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 7 - SF-5/Kitchen Lims Reference ID: AD17686-07 Matrix: Drinking Water Sampled: 04/17/25 08:29:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 08:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 8 - SF-6/Kitchen Lims Reference ID: AD17686-08 Matrix: Drinking Water Sampled: 04/17/25 08:29:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 08:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 10 - WF-1/Exterior Playground Lims Reference ID: AD17686-10 Matrix: Drinking Water Sampled: 04/17/25 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 08:10	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517686
LIMS Reference ID: AD17686
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Joseph A. Taub School

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/05/2025 17:20

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 11 - WF-2/Exterior Playground Lims Reference ID: AD17686-11 Matrix: Drinking Water Sampled: 04/17/25 08:32:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 08:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 13 - WFB-5/First Floor Near 103 Lims Reference ID: AD17686-13 Matrix: Drinking Water Sampled: 04/17/25 08:33:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 08:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 14 - WF-3/First Floor Near 103 Lims Reference ID: AD17686-14 Matrix: Drinking Water Sampled: 04/17/25 08:33:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 08:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 15 - SF-7/Main Office 101A Lims Reference ID: AD17686-15 Matrix: Drinking Water Sampled: 04/17/25 08:34:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 08:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 16 - SF-8/Nurse Office 114 Lims Reference ID: AD17686-16 Matrix: Drinking Water Sampled: 04/17/25 08:35:00									
Metals									
Lead	1.81		1	1.00	µg/L	04/29/25 17:04	04/30/25 08:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 17 - SF-9/Nurse Office 114C Lims Reference ID: AD17686-17 Matrix: Drinking Water Sampled: 04/17/25 08:35:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 08:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 18 - WFB-6/First Floor Near Stair 3 Lims Reference ID: AD17686-18 Matrix: Drinking Water Sampled: 04/17/25 08:37:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 08:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 19 - WF-4/First Floor Near Stair 3 Lims Reference ID: AD17686-19 Matrix: Drinking Water Sampled: 04/17/25 08:37:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 08:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 20 - WFB-7/Second Floor Near 219 Lims Reference ID: AD17686-20 Matrix: Drinking Water Sampled: 04/17/25 08:40:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 08:34	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517686
LIMS Reference ID: AD17686
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477 / Joseph A. Taub School

Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/18/2025 09:00
Reported: 05/05/2025 17:20

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 21 - WF-5/Second Floor Near 203 Lims Reference ID: AD17686-21 Matrix: Drinking Water Sampled: 04/17/25 08:42:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 08:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 22 - WFB-8/Second Floor Near 203 Lims Reference ID: AD17686-22 Matrix: Drinking Water Sampled: 04/17/25 08:42:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:04	04/30/25 08:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 23 - SF-10/Second Floor 230 Teachers Workroom SF-11 Lims Reference ID: AD17686-23 Matrix: Drinking Water Sampled: 04/17/25 08:44:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:05	04/30/25 08:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 24 - SF-11/Third Floor 331 Teachers Workroom Lims Reference ID: AD17686-24 Matrix: Drinking Water Sampled: 04/17/25 08:45:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:05	04/30/25 08:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 25 - WFB-9/Third Floor Next to 303 Lims Reference ID: AD17686-25 Matrix: Drinking Water Sampled: 04/17/25 08:46:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:05	04/30/25 08:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 26 - WF-6/Third Floor Next to 303 Lims Reference ID: AD17686-26 Matrix: Drinking Water Sampled: 04/17/25 08:46:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:05	04/30/25 08:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 27 - WF-7/Third Floor Next to 320 Lims Reference ID: AD17686-27 Matrix: Drinking Water Sampled: 04/17/25 08:47:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:05	04/30/25 09:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 28 - WFB-10/Third Floor Next to 320 Lims Reference ID: AD17686-28 Matrix: Drinking Water Sampled: 04/17/25 08:47:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:05	04/30/25 09:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 29 - WFB-11/Third Floor Gym Next to 319E Lims Reference ID: AD17686-29 Matrix: Drinking Water Sampled: 04/17/25 08:48:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:05	04/30/25 09:08	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517686
LIMS Reference ID: AD17686
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477 / Joseph A. Taub School

Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/18/2025 09:00
Reported: 05/05/2025 17:20

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: 29 - WFB-11/Third Floor Gym Next to 319E (Continued) Lims Reference ID: AD17686-29 Matrix: Drinking Water Sampled: 04/17/25 08:48:00

Metals (Continued)

Sample: 30 - WFB-12/Third Floor Gym Next to 319F Lims Reference ID: AD17686-30 Matrix: Drinking Water Sampled: 04/17/25 08:50:00

Metals

Lead	ND	1	1.00	µg/L	04/29/25 17:05	04/30/25 09:10	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 31 - WFB-13/Third Floor Near Stair 3 Lims Reference ID: AD17686-31 Matrix: Drinking Water Sampled: 04/17/25 08:52:00

Metals

Lead	ND	1	1.00	µg/L	04/29/25 17:05	04/30/25 09:12	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 32 - WF-8/Third Floor Near Stair 3 Lims Reference ID: AD17686-32 Matrix: Drinking Water Sampled: 04/17/25 08:53:00

Metals

Lead	ND	1	1.00	µg/L	04/29/25 17:05	04/30/25 09:14	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 33 - WFB-14/Fourth Floor Next to 418 Lims Reference ID: AD17686-33 Matrix: Drinking Water Sampled: 04/17/25 08:55:00

Metals

Lead	ND	1	1.00	µg/L	04/29/25 17:05	04/30/25 09:16	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 34 - WF-9/Fourth Floor Next to 418 Lims Reference ID: AD17686-34 Matrix: Drinking Water Sampled: 04/17/25 08:55:00

Metals

Lead	ND	1	1.00	µg/L	04/29/25 17:05	04/30/25 09:22	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 35 - WF-10/Fourth Floor Next to 403 Lims Reference ID: AD17686-35 Matrix: Drinking Water Sampled: 04/17/25 08:57:00

Metals

Lead	ND	1	1.00	µg/L	04/29/25 17:05	04/30/25 09:24	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 36 - WFB-15/Fourth Floor Next to 403 Lims Reference ID: AD17686-36 Matrix: Drinking Water Sampled: 04/17/25 08:57:00

Metals

Lead	ND	1	1.00	µg/L	04/29/25 17:05	04/30/25 09:29	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 37 - SF-12/Fourth Floor 429 Teachers Workroom Lims Reference ID: AD17686-37 Matrix: Drinking Water Sampled: 04/17/25 08:59:00

Metals

Lead	ND	1	1.00	µg/L	04/29/25 17:05	04/30/25 09:31	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517686
LIMS Reference ID: AD17686
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477 / Joseph A. Taub School

Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/18/2025 09:00
Reported: 05/05/2025 17:20

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 38 - WF/Cafetorium Lims Reference ID: AD17686-38 Matrix: Drinking Water Sampled: 04/17/25 08:25:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:05	04/30/25 09:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 39 - WF/Cafetorium Lims Reference ID: AD17686-39 Matrix: Drinking Water Sampled: 04/17/25 08:26:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:05	04/30/25 09:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 40 - WFB/Cafetorium Lims Reference ID: AD17686-40 Matrix: Drinking Water Sampled: 04/17/25 08:26:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:05	04/30/25 09:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 41 - WF/Exterior Playground Lims Reference ID: AD17686-41 Matrix: Drinking Water Sampled: 04/17/25 08:32:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:05	04/30/25 09:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 42 - WF/Exterior Playground Lims Reference ID: AD17686-42 Matrix: Drinking Water Sampled: 04/17/25 08:32:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:05	04/30/25 09:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 43 - WF/First Fl. Near 103 Lims Reference ID: AD17686-43 Matrix: Drinking Water Sampled: 04/17/25 08:33:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:07	04/30/25 21:42	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 44 - WF/First Fl. Near Stair 3 Lims Reference ID: AD17686-44 Matrix: Drinking Water Sampled: 04/17/25 08:38:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:07	04/30/25 21:47	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 45 - WF/Second Fl. Near 219 Lims Reference ID: AD17686-45 Matrix: Drinking Water Sampled: 04/17/25 08:40:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:07	04/30/25 21:49	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 46 - WF/Second Fl. Near 203 Lims Reference ID: AD17686-46 Matrix: Drinking Water Sampled: 04/17/25 08:43:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:07	04/30/25 21:51	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517686
LIMS Reference ID: AD17686
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Joseph A. Taub School

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/05/2025 17:20

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 47 - WF/Third Fl. Near 303 Lims Reference ID: AD17686-47 Matrix: Drinking Water Sampled: 04/17/25 08:47:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:07	04/30/25 21:53	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 48 - WF/Third Fl. Near 320 Lims Reference ID: AD17686-48 Matrix: Drinking Water Sampled: 04/17/25 08:48:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:07	04/30/25 21:59	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 49 - WF/Third Fl. Gym Next to 319E Lims Reference ID: AD17686-49 Matrix: Drinking Water Sampled: 04/17/25 08:49:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:07	04/30/25 22:01	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 50 - WF/Third Fl. Gym Next to 319F Lims Reference ID: AD17686-50 Matrix: Drinking Water Sampled: 04/17/25 08:50:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:07	04/30/25 22:03	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 51 - WF/Third Fl. Near Stair 3 Lims Reference ID: AD17686-51 Matrix: Drinking Water Sampled: 04/17/25 08:53:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:07	04/30/25 22:05	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 52 - WF/Fourth Fl. Next to 418 Lims Reference ID: AD17686-52 Matrix: Drinking Water Sampled: 04/17/25 08:56:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:07	04/30/25 22:06	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: Field Blank Lims Reference ID: AD17686-53 Matrix: Drinking Water Sampled: 04/17/25 08:56:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 17:07	04/30/25 22:08	JW1	EPA 200.8 (DA)/EPA 200.8