

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517687**LIMS Reference ID:** AD17687**EMSL Customer ID:** TTIE54**Attention:** Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 /Paterson Public Schools / John F.
Kennedy High School

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/02/2025 12:28

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-1/Auditorium Boys' Bathroom - Water Fountain									
Lims Reference ID:				AD17687-01		Matrix: Drinking Water		Sampled: 04/16/25 09:20:00	
Metals									
Lead	1.49		1	1.00	µg/L	04/29/25 12:09	04/29/25 19:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-2/Auditorium Girls' Bathroom - Water Fountain									
Lims Reference ID:				AD17687-02		Matrix: Drinking Water		Sampled: 04/16/25 09:20:00	
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:09	04/29/25 19:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-3/Auditorium Hallway BTMF - Water Fountain									
Lims Reference ID:				AD17687-03		Matrix: Drinking Water		Sampled: 04/16/25 09:21:00	
Metals									
Lead	1.40		1	1.00	µg/L	04/29/25 12:09	04/29/25 19:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-1/BTMF Hallway by Boys' Bathroom - Bottle Filler									
Lims Reference ID:				AD17687-04		Matrix: Drinking Water		Sampled: 04/16/25 09:22:00	
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:09	04/29/25 19:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF4/Inside Classroom 113 - Water Fountain									
Lims Reference ID:				AD17687-05		Matrix: Drinking Water		Sampled: 04/16/25 09:23:00	
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:09	04/29/25 19:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-5/Auditorium Hallway Set - Water Fountain									
Lims Reference ID:				AD17687-06		Matrix: Drinking Water		Sampled: 04/16/25 09:24:00	
Metals									
Lead	25.7		1	1.00	µg/L	04/29/25 12:09	04/29/25 19:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-2/Nurses Office - Bottle Filler									
Lims Reference ID:				AD17687-07		Matrix: Drinking Water		Sampled: 04/16/25 09:25:00	
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:09	04/29/25 20:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-1/Nurses Office - Sink Faucet									
Lims Reference ID:				AD17687-08		Matrix: Drinking Water		Sampled: 04/16/25 09:25:00	
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:09	04/29/25 20:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-3/Next to Main Office - Bottle Filler									
Lims Reference ID:				AD17687-09		Matrix: Drinking Water		Sampled: 04/16/25 09:30:00	

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517687
LIMS Reference ID: AD17687
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477 /Paterson Public Schools / John F.
Kennedy High School

Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/18/2025 09:00
Reported: 05/02/2025 12:28

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WFB-3/Next to Main Office - Bottle Filler (Continued) Lims Reference ID: AD17687-09 Matrix: Drinking Water Sampled: 04/16/25 09:30:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:09	04/29/25 20:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-4/Center Hallway - Bottle Filler Lims Reference ID: AD17687-10 Matrix: Drinking Water Sampled: 04/16/25 09:35:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:09	04/29/25 20:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-5/Hallway Next to 117 - Bottle Filler Lims Reference ID: AD17687-11 Matrix: Drinking Water Sampled: 04/16/25 09:40:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:09	04/29/25 20:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-6/Inside 117 - Water Fountain Lims Reference ID: AD17687-12 Matrix: Drinking Water Sampled: 04/16/25 09:42:00									
Metals									
Lead	1.68		1	1.00	µg/L	04/29/25 12:09	04/29/25 20:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-7/Act Entrance by the Gym - Bottle Filler Lims Reference ID: AD17687-13 Matrix: Drinking Water Sampled: 04/16/25 09:45:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:09	04/29/25 20:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-7/Inside Boy Locker Room - Water Fountain Lims Reference ID: AD17687-14 Matrix: Drinking Water Sampled: 04/16/25 09:46:00									
Metals									
Lead	2.21		1	1.00	µg/L	04/29/25 12:09	04/29/25 20:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-8/Inside Coaches Office - Bottle Filler Lims Reference ID: AD17687-15 Matrix: Drinking Water Sampled: 04/16/25 09:50:00									
Metals									
Lead	1.01		1	1.00	µg/L	04/29/25 12:09	04/29/25 20:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-8/Inside Girls Locker Room - Water Fountain Lims Reference ID: AD17687-16 Matrix: Drinking Water Sampled: 04/16/25 09:52:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:09	04/29/25 20:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-9/STEM Entrance to the Gym - Bottle Filler Lims Reference ID: AD17687-17 Matrix: Drinking Water Sampled: 04/16/25 09:55:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517687
LIMS Reference ID: AD17687
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477 /Paterson Public Schools / John F.
Kennedy High School

Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/18/2025 09:00
Reported: 05/02/2025 12:28

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WFB-9/STEM Entrance to the Gym - Bottle Filler (Continued) Lims Reference ID: AD17687-17 Matrix: Drinking Water Sampled: 04/16/25 09:55:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:09	04/29/25 20:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-2/Kitchen / 1 - Sink Faucet Lims Reference ID: AD17687-18 Matrix: Drinking Water Sampled: 04/16/25 09:56:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:09	04/29/25 20:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-3/Kitchen / 2 - Sink Faucet Lims Reference ID: AD17687-19 Matrix: Drinking Water Sampled: 04/16/25 09:57:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:09	04/29/25 20:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: ICE-1/Gym Food Stand - Ice Maker Lims Reference ID: AD17687-20 Matrix: Drinking Water Sampled: 04/16/25 10:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:09	04/29/25 20:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-9/Gym Entrance Boys' Bathroom - Water Fountain Lims Reference ID: AD17687-21 Matrix: Drinking Water Sampled: 04/16/25 10:05:00									
Metals									
Lead	1.55		1	1.00	µg/L	04/29/25 12:13	04/29/25 20:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-10/Gym Entrance Girls' Bathroom - Water Fountain Lims Reference ID: AD17687-22 Matrix: Drinking Water Sampled: 04/16/25 10:10:00									
Metals									
Lead	1.22		1	1.00	µg/L	04/29/25 12:13	04/29/25 20:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-11/Basement - Water Fountain Lims Reference ID: AD17687-23 Matrix: Drinking Water Sampled: 04/16/25 10:15:00									
Metals									
Lead	13.4		1	1.00	µg/L	04/29/25 12:13	04/29/25 20:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-12/2nd Floor BTMF Hallway Boys' Bathroom - Water Fountain Lims Reference ID: AD17687-24 Matrix: Drinking Water Sampled: 04/16/25 10:20:00									
Metals									
Lead	2.15		1	1.00	µg/L	04/29/25 12:13	04/29/25 20:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB10/2nd Floor BTMF Hallway Girls' Bathroom - Bottle Filler Lims Reference ID: AD17687-25 Matrix: Drinking Water Sampled: 04/16/25 10:20:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517687
LIMS Reference ID: AD17687
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477 /Paterson Public Schools / John F.
Kennedy High School
Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/18/2025 09:00
Reported: 05/02/2025 12:28

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WFB10/2nd Floor BTMF Hallway Girls' Bathroom - Bottle Filler (Continued) Lims Reference ID: AD17687-25 Matrix: Drinking Water Sampled: 04/16/25 10:20:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:13	04/29/25 20:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-11/2nd Floor Set Hallway Girls' Bathroom - Bottle Filler Lims Reference ID: AD17687-26 Matrix: Drinking Water Sampled: 04/16/25 10:22:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:13	04/29/25 21:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-12/2nd Floor ACT Hallway Girls' Bathroom - Bottle Filler Lims Reference ID: AD17687-27 Matrix: Drinking Water Sampled: 04/16/25 10:23:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:13	04/29/25 21:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-13/2nd Floor STEM Hallway Girls' Bathroom - Bottle Filler Lims Reference ID: AD17687-28 Matrix: Drinking Water Sampled: 04/16/25 10:24:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:13	04/29/25 21:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-13/3rd Floor BTMF Hallway Boys' Bathroom - Water Fountain Lims Reference ID: AD17687-29 Matrix: Drinking Water Sampled: 04/16/25 10:25:00									
Metals									
Lead	7.93		1	1.00	µg/L	04/29/25 12:13	04/29/25 21:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WBF-14/3rd Floor BTMF Hallway Girls' Bathroom - Bottle Filler Lims Reference ID: AD17687-30 Matrix: Drinking Water Sampled: 04/16/25 10:26:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:13	04/29/25 21:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: ICE-2/Westside Cafe - Water Fountain Lims Reference ID: AD17687-31 Matrix: Drinking Water Sampled: 04/16/25 10:30:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:13	04/29/25 21:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-14/3rd Floor SET Hallway Boys' Bathroom - Water Fountain Lims Reference ID: AD17687-32 Matrix: Drinking Water Sampled: 04/16/25 10:33:00									
Metals									
Lead	1.16		1	1.00	µg/L	04/29/25 12:13	04/29/25 21:17	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517687
LIMS Reference ID: AD17687
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477 /Paterson Public Schools / John F.
Kennedy High School

Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/18/2025 09:00
Reported: 05/02/2025 12:28

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-14/3rd Floor SET Hallway Boys' Bathroom - Water Fountain (Continued) Lims Reference ID: AD17687-32 Matrix: Drinking Water Sampled: 04/16/25 10:33:00									
Metals (Continued)									
Sample: WBF-15/3rd Floor SET Hallway Girl' Bathroom - Bottler Filler Lims Reference ID: AD17687-33 Matrix: Drinking Water Sampled: 04/16/25 10:34:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:13	04/29/25 21:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-15/3rd Floor Center Hallway - Water Fountain Lims Reference ID: AD17687-34 Matrix: Drinking Water Sampled: 04/16/25 10:35:00									
Metals									
Lead	4.22		1	1.00	µg/L	04/29/25 12:13	04/29/25 21:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-16/3rd Floor ACT Hallway Girls' Bathroom - Bottle Filler Lims Reference ID: AD17687-35 Matrix: Drinking Water Sampled: 04/16/25 10:36:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:13	04/29/25 21:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-16/3rd Floor ACT Hallway Boys' Bathroom - Water Fountain Lims Reference ID: AD17687-36 Matrix: Drinking Water Sampled: 04/16/25 10:50:00									
Metals									
Lead	3.91		1	1.00	µg/L	04/29/25 12:13	04/29/25 21:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-17/3rd Floor STEM Hallway Girls' Bathroom - Bottle Filler Lims Reference ID: AD17687-37 Matrix: Drinking Water Sampled: 04/16/25 10:51:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:13	04/29/25 21:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-18/Trailer /CV5 - Water Fountain Lims Reference ID: AD17687-38 Matrix: Drinking Water Sampled: 04/16/25 11:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:13	04/29/25 21:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-19/Trailer /CY8 - Water Fountain Lims Reference ID: AD17687-39 Matrix: Drinking Water Sampled: 04/16/25 11:01:00									
Metals									
Lead	1.46		1	1.00	µg/L	04/29/25 12:13	04/29/25 21:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-20/Trailer /CY6 - Water Fountain Lims Reference ID: AD17687-40 Matrix: Drinking Water Sampled: 04/16/25 11:02:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517687**LIMS Reference ID:** AD17687**EMSL Customer ID:** TTIE54**Attention:** Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 /Paterson Public Schools / John F.
Kennedy High School

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/02/2025 12:28

Analytical Results**(Continued)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-20/Trailer /CY6 - Water Fountain (Continued) Lims Reference ID: AD17687-40 Matrix: Drinking Water Sampled: 04/16/25 11:02:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:13	04/29/25 21:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-21/Trailer /CY7 - Water Fountain Lims Reference ID: AD17687-41 Matrix: Drinking Water Sampled: 04/16/25 11:03:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:14	04/30/25 13:40	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-1/S/BTMF Hallway by Boys' Bathroom Lims Reference ID: AD17687-42 Matrix: Drinking Water Sampled: 04/16/25 09:22:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:14	04/30/25 13:46	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-2/S/Nurses Office Lims Reference ID: AD17687-43 Matrix: Drinking Water Sampled: 04/16/25 09:25:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:14	04/30/25 13:48	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-3/S/Next to Main Office Lims Reference ID: AD17687-44 Matrix: Drinking Water Sampled: 04/16/25 09:30:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:14	04/30/25 13:50	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-4/S/Center Hallway Lims Reference ID: AD17687-45 Matrix: Drinking Water Sampled: 04/16/25 09:35:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:14	04/30/25 13:51	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-5/S/Hallway Next to 117 Lims Reference ID: AD17687-46 Matrix: Drinking Water Sampled: 04/16/25 09:40:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:14	04/30/25 13:57	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-7/S/ACT Entrance by the Gym Lims Reference ID: AD17687-47 Matrix: Drinking Water Sampled: 04/16/25 09:45:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:14	04/30/25 13:59	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-8/S/Inside Coaches Office Lims Reference ID: AD17687-48 Matrix: Drinking Water Sampled: 04/16/25 09:50:00									
Metals									
Lead	1.25		1	1.00	µg/L	04/29/25 12:14	04/30/25 14:01	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517687**LIMS Reference ID:** AD17687**EMSL Customer ID:** TTIE54**Attention:** Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 /Paterson Public Schools / John F.
Kennedy High School

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/02/2025 12:28

Analytical Results**(Continued)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WFB-9/S/STEM Entrance to the Gym Lims Reference ID: AD17687-49 Matrix: Drinking Water Sampled: 04/16/25 09:55:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:14	04/30/25 14:03	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-10/S/2nd Floor BTMF Hallway Girls' Bathroom Lims Reference ID: AD17687-50 Matrix: Drinking Water Sampled: 04/16/25 10:20:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:14	04/30/25 14:05	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-11/S/2nd Floor SET Hallway Girls' Bathroom Lims Reference ID: AD17687-51 Matrix: Drinking Water Sampled: 04/16/25 10:22:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:14	04/30/25 14:07	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-12/S/2nd Floor ACT Hallway Girls' Bathroom Lims Reference ID: AD17687-52 Matrix: Drinking Water Sampled: 04/16/25 10:25:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:14	04/30/25 14:13	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-13/S/2nd Floor STEM Hallway Girls' Bathroom Lims Reference ID: AD17687-53 Matrix: Drinking Water Sampled: 04/16/25 10:25:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:14	04/30/25 14:15	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-14/S/3rd Floor BTMF Hallway Girls' Bathroom Lims Reference ID: AD17687-54 Matrix: Drinking Water Sampled: 04/16/25 10:30:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:14	04/30/25 14:20	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-15/S/3rd Floor SET Hallway Girls' Bathroom Lims Reference ID: AD17687-55 Matrix: Drinking Water Sampled: 04/16/25 10:45:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:14	04/30/25 14:22	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-16/S/3rd Floor ACT Hallway Girls' Bathroom Lims Reference ID: AD17687-56 Matrix: Drinking Water Sampled: 04/16/25 10:50:00									
Metals									
Lead	ND		1	1.00	µg/L	04/29/25 12:14	04/30/25 14:24	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517687**LIMS Reference ID:** AD17687**EMSL Customer ID:** TTIE54**Attention:** Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 /Paterson Public Schools / John F.
Kennedy High School

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/02/2025 12:28

Analytical Results**(Continued)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	-----------------------	-----------------------	---------------------	----------------------------

Sample: WFB-16/S/3rd Floor ACT Hallway Girls'
Bathroom (Continued)

Lims Reference ID: AD17687-56 Matrix: Drinking Water

Sampled: 04/16/25 10:50:00

Metals (Continued)

Sample: WFB-17/S/3rd Floor STEM Hallway Girls'
Bathroom

Lims Reference ID: AD17687-57 Matrix: Drinking Water

Sampled: 04/16/25 10:51:00

Metals

Lead	ND	1	1.00	µg/L	04/29/25 12:14	04/30/25 14:26	JW1	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	-----	--------------------------