

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517441
LIMS Reference ID: AD17441
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Public School #8

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

04/30/2025 17:40

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF1/Outside Chief's Office Lims Reference ID: AD17441-01 Matrix: Drinking Water Sampled: 04/14/25 07:15:00									
Metals									
Lead	1.39		1	1.00	µg/L	04/24/25 14:58	04/25/25 08:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB1/Outside Chief's Office Lims Reference ID: AD17441-02 Matrix: Drinking Water Sampled: 04/14/25 07:15:00									
Metals									
Lead	2.27		1	1.00	µg/L	04/24/25 14:58	04/25/25 08:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF2/Outside Cafe Lims Reference ID: AD17441-03 Matrix: Drinking Water Sampled: 04/14/25 07:17:00									
Metals									
Lead	1.04		1	1.00	µg/L	04/24/25 14:58	04/25/25 08:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB2/Outside Cafe Lims Reference ID: AD17441-04 Matrix: Drinking Water Sampled: 04/14/25 07:17:00									
Metals									
Lead	2.80		1	1.00	µg/L	04/24/25 14:58	04/25/25 08:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF1/Kitchen Lims Reference ID: AD17441-05 Matrix: Drinking Water Sampled: 04/14/25 07:20:00									
Metals									
Lead	7.49		1	1.00	µg/L	04/24/25 14:58	04/25/25 08:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF2/Nurse Office Lims Reference ID: AD17441-06 Matrix: Drinking Water Sampled: 04/14/25 07:24:00									
Metals									
Lead	6.63		1	1.00	µg/L	04/24/25 14:58	04/25/25 09:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF3/Outside 107 Lims Reference ID: AD17441-07 Matrix: Drinking Water Sampled: 04/14/25 07:26:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:58	04/25/25 09:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB3/Outside 107 Lims Reference ID: AD17441-08 Matrix: Drinking Water Sampled: 04/14/25 07:26:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:58	04/25/25 09:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF4/Outside 105 Lims Reference ID: AD17441-09 Matrix: Drinking Water Sampled: 04/14/25 07:27:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:58	04/25/25 09:05	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517441
LIMS Reference ID: AD17441
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Public School #8

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

04/30/2025 17:40

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WFB4/Outside 105 Lims Reference ID: AD17441-10 Matrix: Drinking Water Sampled: 04/14/25 07:27:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:58	04/25/25 09:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF5/Outside 205 Lims Reference ID: AD17441-11 Matrix: Drinking Water Sampled: 04/14/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:58	04/25/25 09:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB5/Outside 205 Lims Reference ID: AD17441-12 Matrix: Drinking Water Sampled: 04/14/25 07:30:00									
Metals									
Lead	1.20		1	1.00	µg/L	04/24/25 14:58	04/25/25 09:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF6/Outside 209 Lims Reference ID: AD17441-13 Matrix: Drinking Water Sampled: 04/14/25 07:33:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:58	04/25/25 09:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB6/Outside 209 Lims Reference ID: AD17441-14 Matrix: Drinking Water Sampled: 04/14/25 07:33:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 14:58	04/25/25 09:22	PL	EPA 200.8 (DA)/EPA 200.8