

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517706**LIMS Reference ID:** AD17706**EMSL Customer ID:** TTIE54**Attention:** Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Public School #15

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

05/01/2025 12:49

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 1 - WFB-1/Hallway by Boiler Room Lims Reference ID: AD17706-01 Matrix: Drinking Water Sampled: 04/14/25 07:22:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 17:25	04/28/25 18:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 2 - WF-1 - Right/Hallway by Boiler Room Lims Reference ID: AD17706-02 Matrix: Drinking Water Sampled: 04/14/25 07:22:00									
Metals									
Lead	1.36		1	1.00	µg/L	04/24/25 17:25	04/28/25 18:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 3 - SF-1/Room by Gym Entrance Lims Reference ID: AD17706-03 Matrix: Drinking Water Sampled: 04/14/25 07:25:00									
Metals									
Lead	1.12		1	1.00	µg/L	04/24/25 17:25	04/28/25 19:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 4 - WF-3/Hallway Across Opposite of WFB-1 Lims Reference ID: AD17706-04 Matrix: Drinking Water Sampled: 04/14/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 17:25	04/28/25 19:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 5 - WF-4/Hallway Across Opposite of WFB-1 Lims Reference ID: AD17706-05 Matrix: Drinking Water Sampled: 04/14/25 07:27:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 17:25	04/28/25 19:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 6 - WFB-2/Across Room 114 Lims Reference ID: AD17706-06 Matrix: Drinking Water Sampled: 04/14/25 07:42:00									
Metals									
Lead	8.85		1	1.00	µg/L	04/28/25 13:23	04/29/25 17:20	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: 7 - WF-2 - Right/Across Room 114 Lims Reference ID: AD17706-07 Matrix: Drinking Water Sampled: 04/14/25 07:40:00									
Metals									
Lead	13.5		1	1.00	µg/L	04/24/25 17:25	04/28/25 19:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 8 - WFB-5/Across Room 203 Lims Reference ID: AD17706-08 Matrix: Drinking Water Sampled: 04/14/25 07:50:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 17:25	04/28/25 19:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 9 - WF-5/Across Room 203 Lims Reference ID: AD17706-09 Matrix: Drinking Water Sampled: 04/14/25 07:52:00									
Metals									
Lead	1.27		1	1.00	µg/L	04/24/25 17:25	04/28/25 19:14	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517706
LIMS Reference ID: AD17706
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Public School #15

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

05/01/2025 12:49

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 10 - WFB-6/Across Room 214 Lims Reference ID: AD17706-10 Matrix: Drinking Water Sampled: 04/14/25 07:53:00									
Metals									
Lead	13.0		1	1.00	µg/L	04/28/25 13:23	04/29/25 17:22	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: 11 - WF-6/Across Room 214 Lims Reference ID: AD17706-11 Matrix: Drinking Water Sampled: 04/14/25 07:54:00									
Metals									
Lead	5.69		1	1.00	µg/L	04/28/25 13:23	04/29/25 17:28	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: 12 - WFB-7/Across Room 303 Lims Reference ID: AD17706-12 Matrix: Drinking Water Sampled: 04/14/25 07:55:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 17:25	04/28/25 19:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 13 - WF-7/Across Room 303 Lims Reference ID: AD17706-13 Matrix: Drinking Water Sampled: 04/14/25 07:56:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 17:25	04/28/25 19:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 14 - WF-8/Across Room 314 Lims Reference ID: AD17706-14 Matrix: Drinking Water Sampled: 04/14/25 08:00:00									
Metals									
Lead	2.13		1	1.00	µg/L	04/24/25 17:25	04/28/25 19:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 15 - WF-9/Across Room 314 Lims Reference ID: AD17706-15 Matrix: Drinking Water Sampled: 04/14/25 08:01:00									
Metals									
Lead	1.66		1	1.00	µg/L	04/24/25 17:25	04/28/25 19:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 16 - WFB-1A/Hallway by Boiler Room Lims Reference ID: AD17706-16 Matrix: Drinking Water Sampled: 04/14/25 07:22:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 17:25	04/28/25 19:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 17 - WFB/Across Room 106 Lims Reference ID: AD17706-17 Matrix: Drinking Water Sampled: 04/14/25 07:35:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 17:25	04/28/25 19:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 20 - WF - Left/Across Room 114 Lims Reference ID: AD17706-20 Matrix: Drinking Water Sampled: 04/14/25 07:44:00									
Metals									
Lead	8.10		1	1.00	µg/L	04/25/25 12:52	04/28/25 22:56	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517706
LIMS Reference ID: AD17706
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477 / Public School #15

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/16/2025 09:00
Reported: 05/01/2025 12:49

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 21 - SF-2/Nurses Office Lims Reference ID: AD17706-21 Matrix: Drinking Water Sampled: 04/14/25 07:45:00									
Metals									
Lead	1.26		1	1.00	µg/L	04/24/25 17:25	04/28/25 19:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 22 - WF - Right/Across Room 203 Lims Reference ID: AD17706-22 Matrix: Drinking Water Sampled: 04/14/25 07:50:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 17:25	04/28/25 19:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 23 - WF - Right/Across Room 214 Lims Reference ID: AD17706-23 Matrix: Drinking Water Sampled: 04/14/25 07:53:00									
Metals									
Lead	9.83		1	1.00	µg/L	04/28/25 13:23	04/29/25 17:30	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: 24 - WF - Right/Across Room Lims Reference ID: AD17706-24 Matrix: Drinking Water Sampled: 04/14/25 07:57:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 17:25	04/28/25 19:39	PL	EPA 200.8 (DA)/EPA 200.8