

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517701
LIMS Reference ID: AD17701
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Paterson Public Schools / Public
School #13 - 690 E. 23rd St., Paterson, NJ
07504

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

04/30/2025 20:07

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 1 - WFB-01/Next to Basement Girls Bathroom									
Lims Reference ID:				AD17701-01		Matrix: Drinking Water		Sampled: 04/14/25 08:20:00	
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:24	04/24/25 19:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 2 - WFB-02/Next to Basement Boys Bathroom									
Lims Reference ID:				AD17701-02		Matrix: Drinking Water		Sampled: 04/14/25 08:25:00	
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:24	04/24/25 19:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 3 - WFB-03/Next to 1st Floor Girls Bathroom									
Lims Reference ID:				AD17701-03		Matrix: Drinking Water		Sampled: 04/14/25 08:32:00	
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:24	04/24/25 19:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 4 - WF-01/Next to 1st Floor Main Office									
Lims Reference ID:				AD17701-04		Matrix: Drinking Water		Sampled: 04/14/25 08:31:00	
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:24	04/24/25 19:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 5 - WFB-04/Next to 2nd Floor Boys Bathroom									
Lims Reference ID:				AD17701-05		Matrix: Drinking Water		Sampled: 04/14/25 08:43:00	
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:24	04/24/25 19:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 6 - WFB-05/Next to 2nd Floor Girls Bathroom									
Lims Reference ID:				AD17701-06		Matrix: Drinking Water		Sampled: 04/14/25 08:41:00	
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:24	04/24/25 19:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 7 - WFB-06/Next to 3rd Floor Girls Bathroom									
Lims Reference ID:				AD17701-07		Matrix: Drinking Water		Sampled: 04/14/25 08:52:00	
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:24	04/24/25 19:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 8 - WFB-07/Next to 3rd Floor Boys Bathroom									
Lims Reference ID:				AD17701-08		Matrix: Drinking Water		Sampled: 04/14/25 08:47:00	
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:24	04/24/25 19:58	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517701**LIMS Reference ID:** AD17701**EMSL Customer ID:** TTIE54**Attention:** Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Paterson Public Schools / Public
School #13 - 690 E. 23rd St., Paterson, NJ
07504

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

04/30/2025 20:07

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 9 - WF-02/Inside 1st Floor Rm. 7 Lims Reference ID: AD17701-09 Matrix: Drinking Water Sampled: 04/14/25 08:37:00									
Metals									
Lead	2.10		1	1.00	µg/L	04/23/25 16:24	04/24/25 19:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 10 - WF-03/Inside 1st Floor Rm. 8 Lims Reference ID: AD17701-10 Matrix: Drinking Water Sampled: 04/14/25 08:36:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:24	04/24/25 20:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 11 - WF-04/Inside 1st Floor Rm. 9 Lims Reference ID: AD17701-11 Matrix: Drinking Water Sampled: 04/14/25 08:39:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:24	04/24/25 20:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12 - WF-05/Inside 1st Floor Rm. 10 Lims Reference ID: AD17701-12 Matrix: Drinking Water Sampled: 04/14/25 08:38:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:24	04/24/25 20:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 13 - SINK1/Inside Basement Kitchen Lims Reference ID: AD17701-13 Matrix: Drinking Water Sampled: 04/14/25 08:27:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:24	04/24/25 20:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 14 - SINK2/Inside Nurse's Office Lims Reference ID: AD17701-14 Matrix: Drinking Water Sampled: 04/14/25 08:30:00									
Metals									
Lead	1.61		1	1.00	µg/L	04/23/25 16:24	04/24/25 20:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 15 - WF/Next to Basement Girls Bathroom Lims Reference ID: AD17701-15 Matrix: Drinking Water Sampled: 04/14/25 08:22:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:24	04/24/25 20:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 16 - WF/Next to Basement Boys Bathroom Lims Reference ID: AD17701-16 Matrix: Drinking Water Sampled: 04/14/25 08:25:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:24	04/24/25 20:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 17 - WF/Next to 1st Fl. Girls Bathroom Lims Reference ID: AD17701-17 Matrix: Drinking Water Sampled: 04/14/25 08:33:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:24	04/24/25 20:22	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517701
LIMS Reference ID: AD17701
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Paterson Public Schools / Public
School #13 - 690 E. 23rd St., Paterson, NJ
07504

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

04/30/2025 20:07

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 18 - WF/Next to 2nd Fl. Girls Bathroom Lims Reference ID: AD17701-18 Matrix: Drinking Water Sampled: 04/14/25 08:40:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:24	04/24/25 20:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 19 - WF/Next to 2nd Fl. Boys Bathroom Lims Reference ID: AD17701-19 Matrix: Drinking Water Sampled: 04/14/25 08:45:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:24	04/24/25 20:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 20 - WF/Next to 3rd Fl. Boys Bathroom Lims Reference ID: AD17701-20 Matrix: Drinking Water Sampled: 04/14/25 08:48:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:24	04/24/25 20:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 21 - WF/Next to 3rd Fl. Girls Bathroom Lims Reference ID: AD17701-21 Matrix: Drinking Water Sampled: 04/14/25 08:50:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:25	04/24/25 20:45	PL	EPA 200.8 (DA)/EPA 200.8