

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517544
LIMS Reference ID: AD17544
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477/ Public School #19 / 31 James St.,
Paterson, NJ 07502
Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/16/2025 09:00
Reported: 04/30/2025 17:36

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF1/Ground Floor, Kindergarten (Double) Lims Reference ID: AD17544-01 Matrix: Drinking Water Sampled: 04/14/25 11:00:00									
Metals									
Lead	7.56		1	1.00	µg/L	04/25/25 12:55	04/28/25 21:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF1/Ground Floor, Classroom B2 Lims Reference ID: AD17544-02 Matrix: Drinking Water Sampled: 04/14/25 11:02:00									
Metals									
Lead	12.0		1	1.00	µg/L	04/25/25 12:55	04/28/25 21:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF2/Ground Floor, Kitchen Lims Reference ID: AD17544-03 Matrix: Drinking Water Sampled: 04/14/25 11:03:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:55	04/28/25 21:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF3/Ground Floor, Kitchen Lims Reference ID: AD17544-04 Matrix: Drinking Water Sampled: 04/14/25 11:04:00									
Metals									
Lead	2.42		1	1.00	µg/L	04/25/25 12:55	04/28/25 21:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB1/1st Floor Hallway by Classroom 106 Lims Reference ID: AD17544-05 Matrix: Drinking Water Sampled: 04/14/25 11:05:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:55	04/28/25 21:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF2/1st Floor Hallway by Classroom 104 Lims Reference ID: AD17544-06 Matrix: Drinking Water Sampled: 04/14/25 11:06:00									
Metals									
Lead	3.30		1	1.00	µg/L	04/25/25 12:55	04/28/25 21:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF3/1st Floor Classroom 103 Lims Reference ID: AD17544-07 Matrix: Drinking Water Sampled: 04/14/25 11:07:00									
Metals									
Lead	3.42		1	1.00	µg/L	04/25/25 12:55	04/28/25 21:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF4/2nd Floor Hallway by Classroom 204 Lims Reference ID: AD17544-08 Matrix: Drinking Water Sampled: 04/14/25 11:08:00									
Metals									
Lead	8.21		1	1.00	µg/L	04/25/25 12:55	04/28/25 21:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF4/Nurses Office Lims Reference ID: AD17544-09 Matrix: Drinking Water Sampled: 04/14/25 11:09:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:55	04/28/25 21:48	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517544
LIMS Reference ID: AD17544
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477/ Public School #19 / 31 James St.,
Paterson, NJ 07502
Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/16/2025 09:00
Reported: 04/30/2025 17:36

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SF5/Teachers' Lounge Lims Reference ID: AD17544-10 Matrix: Drinking Water Sampled: 04/14/25 11:10:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:55	04/28/25 21:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB2/2nd Floor Hallway by Classroom 205 Lims Reference ID: AD17544-11 Matrix: Drinking Water Sampled: 04/14/25 11:12:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:55	04/28/25 21:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB1.5/1st Fl. Hall by 106 Filler Lims Reference ID: AD17544-12 Matrix: Drinking Water Sampled: 04/14/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 12:55	04/28/25 21:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF1/Ground Fl. Kindergarden (Double) Lims Reference ID: AD17544-13 Matrix: Drinking Water Sampled: 04/14/25 00:00:00									
Metals									
Lead	2.40		1	1.00	µg/L	04/25/25 12:55	04/28/25 21:56	PL	EPA 200.8 (DA)/EPA 200.8