

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517435
LIMS Reference ID: AD17435
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Public School #25

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

04/30/2025 17:38

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-1/Ground Floor Girls Bathroom Lims Reference ID: AD17435-01 Matrix: Drinking Water Sampled: 04/14/25 10:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 13:00	04/28/25 19:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-2/Ground Floor Girls Bathroom Lims Reference ID: AD17435-02 Matrix: Drinking Water Sampled: 04/14/25 10:01:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 13:00	04/28/25 20:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-3/Ground Floor Boys Bathroom Lims Reference ID: AD17435-03 Matrix: Drinking Water Sampled: 04/14/25 10:03:00									
Metals									
Lead	1.69		1	1.00	µg/L	04/25/25 13:00	04/28/25 20:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-4/Ground Floor Boys Bathroom Lims Reference ID: AD17435-04 Matrix: Drinking Water Sampled: 04/14/25 10:05:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 13:00	04/28/25 20:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-5/1st Floor Girls Bathroom Lims Reference ID: AD17435-05 Matrix: Drinking Water Sampled: 04/14/25 10:08:00									
Metals									
Lead	5.37		1	1.00	µg/L	04/25/25 13:00	04/28/25 20:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-6/1st Floor Girls Bathroom Lims Reference ID: AD17435-06 Matrix: Drinking Water Sampled: 04/14/25 10:10:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 13:00	04/28/25 20:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-7/1st Floor Boys Bathroom Lims Reference ID: AD17435-07 Matrix: Drinking Water Sampled: 04/14/25 10:12:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 13:00	04/28/25 20:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-8/1st Floor Boys Bathroom Lims Reference ID: AD17435-08 Matrix: Drinking Water Sampled: 04/14/25 10:14:00									
Metals									
Lead	1.73		1	1.00	µg/L	04/25/25 13:00	04/28/25 20:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-9/1st Floor teacher Bathroom CR# 103 Lims Reference ID: AD17435-09 Matrix: Drinking Water Sampled: 04/14/25 10:15:00									
Metals									
Lead	82.8		1	1.00	µg/L	04/25/25 13:00	04/28/25 20:19	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517435
LIMS Reference ID: AD17435
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Public School #25

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

04/30/2025 17:38

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-10/2nd Floor Girls Bathroom Lims Reference ID: AD17435-10 Matrix: Drinking Water Sampled: 04/14/25 10:18:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 13:00	04/28/25 20:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-12/2nd Floor Boys Bathroom Lims Reference ID: AD17435-11 Matrix: Drinking Water Sampled: 04/14/25 10:20:00									
Metals									
Lead	1.90		1	1.00	µg/L	04/25/25 13:00	04/28/25 20:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-1/Nurse Lims Reference ID: AD17435-12 Matrix: Drinking Water Sampled: 04/14/25 10:24:00									
Metals									
Lead	1.05		1	1.00	µg/L	04/25/25 13:00	04/28/25 20:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-2/Cafe Lims Reference ID: AD17435-13 Matrix: Drinking Water Sampled: 04/14/25 10:25:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 13:00	04/28/25 20:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-3/Teacher's Room Sink Lims Reference ID: AD17435-14 Matrix: Drinking Water Sampled: 04/14/25 10:26:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 13:00	04/28/25 20:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-10B/2nd FI Girls Bathroom Lims Reference ID: AD17435-15 Matrix: Drinking Water Sampled: 04/14/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 13:00	04/28/25 20:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-7B/1st FI Boys Bathroom Lims Reference ID: AD17435-16 Matrix: Drinking Water Sampled: 04/14/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 13:00	04/28/25 20:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Blank Lims Reference ID: AD17435-17 Matrix: Drinking Water Sampled: 04/14/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/25/25 13:00	04/28/25 20:42	PL	EPA 200.8 (DA)/EPA 200.8