

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517688
LIMS Reference ID: AD17688
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Rutland Center

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/02/2025 12:30

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-27/Rutland Classroom 507 Lims Reference ID: AD17688-01 Matrix: Drinking Water Sampled: 04/17/25 06:53:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:27	04/29/25 16:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-28/Rutland Classroom 506 Lims Reference ID: AD17688-02 Matrix: Drinking Water Sampled: 04/17/25 06:54:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:27	04/29/25 16:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-29/Rutland Classroom 505 Lims Reference ID: AD17688-03 Matrix: Drinking Water Sampled: 04/17/25 06:55:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:27	04/29/25 16:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-30/Rutland Classroom 504 Lims Reference ID: AD17688-04 Matrix: Drinking Water Sampled: 04/17/25 06:56:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:27	04/29/25 16:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-31/Rutland Classroom 503 Lims Reference ID: AD17688-05 Matrix: Drinking Water Sampled: 04/17/25 06:57:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:27	04/29/25 16:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-32/Rutland Classroom 502 Lims Reference ID: AD17688-06 Matrix: Drinking Water Sampled: 04/17/25 06:58:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:27	04/29/25 16:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-33/Rutland Classroom 501 Lims Reference ID: AD17688-07 Matrix: Drinking Water Sampled: 04/17/25 06:59:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:27	04/29/25 17:02	PL	EPA 200.8 (DA)/EPA 200.8