

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517700**LIMS Reference ID:** AD17700**EMSL Customer ID:** TTIE54**Attention:** Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Public School #21

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

04/30/2025 20:06

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-1/Across B8									
Lims Reference ID:				AD17700-01		Matrix: Drinking Water		Sampled: 04/15/25 00:00:00	
Metals									
Lead	2.80		1	1.00	µg/L	04/23/25 16:25	04/24/25 20:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-2/Across 106									
Lims Reference ID:				AD17700-02		Matrix: Drinking Water		Sampled: 04/15/25 00:00:00	
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:25	04/24/25 20:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-3/Across 109									
Lims Reference ID:				AD17700-03		Matrix: Drinking Water		Sampled: 04/15/25 00:00:00	
Metals									
Lead	3.23		1	1.00	µg/L	04/23/25 16:25	04/24/25 20:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-4/Across 102									
Lims Reference ID:				AD17700-04		Matrix: Drinking Water		Sampled: 04/15/25 00:00:00	
Metals									
Lead	1.07		1	1.00	µg/L	04/23/25 16:25	04/24/25 20:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-5/Inside 114									
Lims Reference ID:				AD17700-05		Matrix: Drinking Water		Sampled: 04/15/25 00:00:00	
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:25	04/24/25 21:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-6/Inside 116									
Lims Reference ID:				AD17700-06		Matrix: Drinking Water		Sampled: 04/15/25 00:00:00	
Metals									
Lead	1.65		1	1.00	µg/L	04/23/25 16:25	04/24/25 21:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-7/Inside 115									
Lims Reference ID:				AD17700-07		Matrix: Drinking Water		Sampled: 04/15/25 00:00:00	
Metals									
Lead	1.55		1	1.00	µg/L	04/23/25 16:25	04/24/25 21:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-8/Inside 117									
Lims Reference ID:				AD17700-08		Matrix: Drinking Water		Sampled: 04/15/25 00:00:00	
Metals									
Lead	5.58		1	1.00	µg/L	04/23/25 16:25	04/24/25 21:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-9/Across 209									
Lims Reference ID:				AD17700-09		Matrix: Drinking Water		Sampled: 04/15/25 00:00:00	
Metals									
Lead	4.39		1	1.00	µg/L	04/23/25 16:25	04/24/25 21:10	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517700
LIMS Reference ID: AD17700
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Public School #21

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

04/30/2025 20:06

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-10/Across 206 Lims Reference ID: AD17700-10 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	1.55		1	1.00	µg/L	04/23/25 16:25	04/24/25 21:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-11/Across 202 Lims Reference ID: AD17700-11 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	2.47		1	1.00	µg/L	04/23/25 16:25	04/24/25 21:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-12/Across 306 Lims Reference ID: AD17700-12 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:25	04/24/25 21:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-13/Across 305 Lims Reference ID: AD17700-13 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:25	04/24/25 21:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-1/Inside Kitchen Lims Reference ID: AD17700-14 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:25	04/24/25 21:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-2/Inside Kitchen Lims Reference ID: AD17700-15 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	1.34		1	1.00	µg/L	04/23/25 16:25	04/24/25 21:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-3/Inside 2nd Floor Teacher's Lounge Lims Reference ID: AD17700-16 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	4.76		1	1.00	µg/L	04/23/25 16:25	04/24/25 21:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF-4/Inside 2nd Floor Nurse Office Lims Reference ID: AD17700-17 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:25	04/24/25 21:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-1/Across B4 Lims Reference ID: AD17700-18 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:25	04/24/25 21:35	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517700**LIMS Reference ID:** AD17700**EMSL Customer ID:** TTIE54**Attention:** Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Public School #21

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/16/2025 09:00

Reported:

04/30/2025 20:06

Analytical Results**(Continued)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WFB-2/Across 105 Lims Reference ID: AD17700-19 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/23/25 16:25	04/24/25 21:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-3/Across 205 Lims Reference ID: AD17700-20 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 16:26	04/24/25 22:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-4/Across 309 Lims Reference ID: AD17700-21 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	3.57		1	1.00	µg/L	04/24/25 16:26	04/24/25 23:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB-5/Across 302 Lims Reference ID: AD17700-22 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 16:26	04/24/25 23:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF/Across B4 Lims Reference ID: AD17700-23 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 16:26	04/24/25 23:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF/Across 105 Lims Reference ID: AD17700-24 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 16:26	04/24/25 23:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF/Across 205 Lims Reference ID: AD17700-25 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 16:26	04/24/25 23:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF/Across 309 Lims Reference ID: AD17700-26 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	4.73		1	1.00	µg/L	04/24/25 09:40	04/25/25 00:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF/Across 302 Lims Reference ID: AD17700-27 Matrix: Drinking Water Sampled: 04/15/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/24/25 09:40	04/25/25 00:19	PL	EPA 200.8 (DA)/EPA 200.8