

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517645
LIMS Reference ID: AD17645
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Roberto Clemente

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/05/2025 17:18

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: WFB-1/NEXT TO BOYS RESTROOM-Water Fountain Lims Reference ID: AD17645-01 Matrix: Drinking Water Sampled: 04/17/25 06:30:00

Metals

Lead	ND	1	1.00	µg/L	04/28/25 17:18	04/29/25 22:52	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: WF-1/NEXT TO BOYS RESTROOM-Water Fountain Lims Reference ID: AD17645-02 Matrix: Drinking Water Sampled: 04/17/25 06:30:00

Metals

Lead	ND	1	1.00	µg/L	04/28/25 17:18	04/29/25 22:58	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: SF-1/KITCHEN-SINK FAUCET Lims Reference ID: AD17645-03 Matrix: Drinking Water Sampled: 04/17/25 06:31:00

Metals

Lead	1.47	1	1.00	µg/L	04/28/25 17:18	04/29/25 23:00	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: WF-2/NEXT TO CAFETERIA-Water Fountain Lims Reference ID: AD17645-04 Matrix: Drinking Water Sampled: 04/17/25 06:32:00

Metals

Lead	2.46	1	1.00	µg/L	04/28/25 17:18	04/29/25 23:01	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: WF-3/1ST FL ROOM 2-Water Fountain Lims Reference ID: AD17645-05 Matrix: Drinking Water Sampled: 04/17/25 06:35:00

Metals

Lead	1.83	1	1.00	µg/L	04/28/25 17:18	04/29/25 23:03	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: WF-4/1ST FL ROOM 3-Water Fountain Lims Reference ID: AD17645-06 Matrix: Drinking Water Sampled: 04/17/25 06:36:00

Metals

Lead	27.4	1	1.00	µg/L	04/30/25 09:45	05/01/25 18:10	JW1	EPA 200.8 (Dig)/EPA 200.8
------	------	---	------	------	----------------	----------------	-----	---------------------------

Sample: BF/1ST FL BY NURSE-Sink Lims Reference ID: AD17645-07 Matrix: Drinking Water Sampled: 04/17/25 06:37:00

Metals

Lead	ND	1	1.00	µg/L	04/28/25 17:18	04/29/25 23:09	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: SF-2/1ST FL TEACHERS ROOM-Sink Faucet Lims Reference ID: AD17645-08 Matrix: Drinking Water Sampled: 04/17/25 06:38:00

Metals

Lead	ND	1	1.00	µg/L	04/28/25 17:18	04/29/25 23:11	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: WFB-6/1st FL HALLWAY BY GYM-Bottle Filler Lims Reference ID: AD17645-09 Matrix: Drinking Water Sampled: 04/17/25 06:39:00

Metals

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517645
LIMS Reference ID: AD17645
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477 / Roberto Clemente

Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/18/2025 09:00
Reported: 05/05/2025 17:18

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: WFB-6/1st FL HALLWAY BY GYM-Bottle Filler (Continued) Lims Reference ID: AD17645-09 Matrix: Drinking Water Sampled: 04/17/25 06:39:00

Metals (Continued)

Lead	ND	1	1.00	µg/L	04/28/25 17:18	04/29/25 23:13	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: WF-6/1st FL HALLWAY BY GYM-Water Fountain Lims Reference ID: AD17645-10 Matrix: Drinking Water Sampled: 04/17/25 06:40:00

Metals

Lead	ND	1	1.00	µg/L	04/28/25 17:18	04/29/25 23:15	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: WF-7/1ST FL ROOM 5-Water Fountain Lims Reference ID: AD17645-11 Matrix: Drinking Water Sampled: 04/17/25 06:41:00

Metals

Lead	2.19	1	1.00	µg/L	04/28/25 17:18	04/29/25 23:17	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: WF-8/2ND FL ROOM 6-Water Fountain Lims Reference ID: AD17645-12 Matrix: Drinking Water Sampled: 04/17/25 06:45:00

Metals

Lead	3.44	1	1.00	µg/L	04/28/25 17:18	04/29/25 23:19	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: WF-10/2ND FL ROOM 8-Water Fountain Lims Reference ID: AD17645-14 Matrix: Drinking Water Sampled: 04/17/25 06:47:00

Metals

Lead	ND	1	1.00	µg/L	04/28/25 17:18	04/29/25 23:24	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: WF-12/2ND FL HALLWAY BY RESTROOM-Water Fountain Lims Reference ID: AD17645-16 Matrix: Drinking Water Sampled: 04/17/25 06:50:00

Metals

Lead	1.07	1	1.00	µg/L	04/28/25 17:18	04/29/25 23:26	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: WF-13/2ND FL ROOM 10-Water Fountain Lims Reference ID: AD17645-17 Matrix: Drinking Water Sampled: 04/17/25 06:54:00

Metals

Lead	1.48	1	1.00	µg/L	04/28/25 17:18	04/29/25 23:32	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: WF-14/2ND FL ROOM 9-Water Fountain Lims Reference ID: AD17645-18 Matrix: Drinking Water Sampled: 04/17/25 06:55:00

Metals

Lead	1.52	1	1.00	µg/L	04/28/25 17:18	04/29/25 23:34	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: WF-15/2ND FL ROOM 12-Water Fountain Lims Reference ID: AD17645-19 Matrix: Drinking Water Sampled: 04/17/25 06:56:00

Metals

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517645**LIMS Reference ID:** AD17645**EMSL Customer ID:** TTIE54**Attention:** Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Roberto Clemente

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/05/2025 17:18

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-15/2ND FL ROOM 12-Water Fountain (Continued)									
		Lims Reference ID:		AD17645-19		Matrix: Drinking Water		Sampled: 04/17/25 06:56:00	
Metals (Continued)									
Lead	1.66		1	1.00	µg/L	04/28/25 17:18	04/29/25 23:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-16/2ND FL ROOM 11-Water Fountain									
		Lims Reference ID:		AD17645-20		Matrix: Drinking Water		Sampled: 04/17/25 06:57:00	
Metals									
Lead	1.64		1	1.00	µg/L	04/28/25 17:18	04/29/25 23:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-17/3RD FL ROOM 12-Water Fountain									
		Lims Reference ID:		AD17645-21		Matrix: Drinking Water		Sampled: 04/17/25 06:59:00	
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 17:18	04/29/25 23:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-18/3RD FL ROOM 12A-Water Fountain									
		Lims Reference ID:		AD17645-22		Matrix: Drinking Water		Sampled: 04/17/25 07:00:00	
Metals									
Lead	1.76		1	1.00	µg/L	04/28/25 17:18	04/29/25 23:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-20/3RD FL ROOM 13A-Water Fountain									
		Lims Reference ID:		AD17645-24		Matrix: Drinking Water		Sampled: 04/17/25 07:02:00	
Metals									
Lead	2.13		1	1.00	µg/L	04/28/25 17:18	04/29/25 23:43	PL	EPA 200.8 (DA)/EPA 200.8