

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517697
LIMS Reference ID: AD17697
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Rosa Parks High School

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/02/2025 12:52

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 1 - WF-1/HW 102 Lims Reference ID: AD17697-01 Matrix: Drinking Water Sampled: 04/16/25 08:05:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 17:03	04/29/25 19:59	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 2 - WF-2/HW Guidance Lims Reference ID: AD17697-02 Matrix: Drinking Water Sampled: 04/16/25 08:07:00									
Metals									
Lead	4.28		1	1.00	µg/L	04/28/25 17:03	04/29/25 20:01	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 3 - WF-3/HW Student Bathrooms Lims Reference ID: AD17697-03 Matrix: Drinking Water Sampled: 04/16/25 08:10:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 17:28	04/29/25 22:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 4 - Sink/Nurse Lims Reference ID: AD17697-04 Matrix: Drinking Water Sampled: 04/16/25 08:20:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 17:28	04/29/25 22:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 5 - Sink/Kitchen 1 Lims Reference ID: AD17697-05 Matrix: Drinking Water Sampled: 04/16/25 08:15:00									
Metals									
Lead	1.46		1	1.00	µg/L	04/28/25 17:28	04/29/25 22:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 6 - Sink/Kitchen 2 Lims Reference ID: AD17697-06 Matrix: Drinking Water Sampled: 04/16/25 08:15:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 17:28	04/29/25 22:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 7 - Sink/Kitchen 3 Lims Reference ID: AD17697-07 Matrix: Drinking Water Sampled: 04/16/25 08:15:00									
Metals									
Lead	1.28		1	1.00	µg/L	04/28/25 17:28	04/29/25 22:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 8 - WFB - 1/HW 102 Lims Reference ID: AD17697-08 Matrix: Drinking Water Sampled: 04/16/25 08:05:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 17:28	04/29/25 22:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 9 - WFB - 2/HW Student Bathrooms Lims Reference ID: AD17697-09 Matrix: Drinking Water Sampled: 04/16/25 08:10:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 17:28	04/29/25 22:41	PL	EPA 200.8 (DA)/EPA 200.8