

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517707
LIMS Reference ID: AD17707
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Public School #28

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/05/2025 17:26

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 1 - WF.F1/Gym Lims Reference ID: AD17707-01 Matrix: Drinking Water Sampled: 04/16/25 06:51:00									
Metals									
Lead	1.01		1	1.00	µg/L	04/28/25 15:29	04/29/25 15:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 2 - W.F2/Gym Lims Reference ID: AD17707-02 Matrix: Drinking Water Sampled: 04/16/25 06:52:00									
Metals									
Lead	1.26		1	1.00	µg/L	04/28/25 15:29	04/29/25 15:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 3 - W.F3/Gym Lims Reference ID: AD17707-03 Matrix: Drinking Water Sampled: 04/16/25 06:53:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:29	04/29/25 15:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 4 - W.F4/Gym Lims Reference ID: AD17707-04 Matrix: Drinking Water Sampled: 04/16/25 06:54:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:29	04/29/25 15:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 5 - W.FS/Main Lobby Lims Reference ID: AD17707-05 Matrix: Drinking Water Sampled: 04/16/25 06:59:00									
Metals									
Lead	2.25		1	1.00	µg/L	04/28/25 15:29	04/29/25 15:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 6 - W.F6/Main Lobby Lims Reference ID: AD17707-06 Matrix: Drinking Water Sampled: 04/16/25 06:59:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:29	04/29/25 15:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 7 - W.F 6B/Main Lobby Lims Reference ID: AD17707-07 Matrix: Drinking Water Sampled: 04/16/25 07:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 15:29	04/29/25 15:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 8 - W.F7/RM #106 Lims Reference ID: AD17707-08 Matrix: Drinking Water Sampled: 04/16/25 07:02:00									
Metals									
Lead	4.92		1	1.00	µg/L	04/28/25 15:29	04/29/25 15:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 9 - W.F8/RM #105 Lims Reference ID: AD17707-09 Matrix: Drinking Water Sampled: 04/16/25 07:03:00									
Metals									
Lead	14.9		1	1.00	µg/L	04/28/25 15:29	04/29/25 15:53	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517707
LIMS Reference ID: AD17707
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Public School #28

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/05/2025 17:26

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 10 - W.F9/RM #104 Lims Reference ID: AD17707-10 Matrix: Drinking Water Sampled: 04/16/25 07:04:00									
Metals									
Lead	22.1	1	1.00		µg/L	04/28/25 15:29	04/29/25 15:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 11 - W.F10/RM #103 Lims Reference ID: AD17707-11 Matrix: Drinking Water Sampled: 04/16/25 07:06:00									
Metals									
Lead	13.3	1	1.00		µg/L	04/28/25 15:29	04/29/25 16:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12 - W.F11/RM #102 Lims Reference ID: AD17707-12 Matrix: Drinking Water Sampled: 04/16/25 07:07:00									
Metals									
Lead	15.3	1	1.00		µg/L	04/28/25 15:29	04/29/25 16:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 13 - W.F12/RM #101 Lims Reference ID: AD17707-13 Matrix: Drinking Water Sampled: 04/16/25 07:08:00									
Metals									
Lead	8.58	1	1.00		µg/L	04/28/25 15:29	04/29/25 16:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 14 - S.F1/Kitchen Lims Reference ID: AD17707-14 Matrix: Drinking Water Sampled: 04/16/25 07:11:00									
Metals									
Lead	1.33	1	1.00		µg/L	04/28/25 15:29	04/29/25 16:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 15 - W.F13/Cafeteria Lims Reference ID: AD17707-15 Matrix: Drinking Water Sampled: 04/16/25 07:13:00									
Metals									
Lead	9.15	1	1.00		µg/L	04/28/25 15:29	04/29/25 16:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 16 - W.F14/Cafeteria Lims Reference ID: AD17707-16 Matrix: Drinking Water Sampled: 04/16/25 07:14:00									
Metals									
Lead	3.44	1	1.00		µg/L	04/28/25 15:29	04/29/25 16:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 17 - W.F15/RM #109 Lims Reference ID: AD17707-17 Matrix: Drinking Water Sampled: 04/16/25 07:15:00									
Metals									
Lead	8.32	1	1.00		µg/L	04/28/25 14:29	04/30/25 21:18	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 18 - W.F16/RM #110 Lims Reference ID: AD17707-18 Matrix: Drinking Water Sampled: 04/16/25 07:16:00									
Metals									
Lead	7.43	1	1.00		µg/L	04/25/25 14:40	04/29/25 09:48	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517707
LIMS Reference ID: AD17707
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Public School #28

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/05/2025 17:26

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 19 - S.F2/Nurse Lims Reference ID: AD17707-19 Matrix: Drinking Water Sampled: 04/16/25 07:18:00									
Metals									
Lead	42.5	1	1.00		µg/L	04/30/25 09:45	05/01/25 18:33	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: 20 - S.F3/Nurse Lims Reference ID: AD17707-20 Matrix: Drinking Water Sampled: 04/16/25 07:19:00									
Metals									
Lead	3.53	1	1.00		µg/L	04/25/25 14:40	04/29/25 09:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 21 - W.F17/2nd FI By Wellness Rm Lims Reference ID: AD17707-21 Matrix: Drinking Water Sampled: 04/16/25 07:25:00									
Metals									
Lead	ND	1	1.00		µg/L	04/25/25 14:40	04/29/25 09:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 22 - W.F18/2nd FI By Wellness Rm Lims Reference ID: AD17707-22 Matrix: Drinking Water Sampled: 04/16/25 07:27:00									
Metals									
Lead	3.54	1	1.00		µg/L	04/25/25 14:40	04/29/25 09:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 23 - W.F20/3rd FI. By Rm #316 Lims Reference ID: AD17707-23 Matrix: Drinking Water Sampled: 04/16/25 07:31:00									
Metals									
Lead	ND	1	1.00		µg/L	04/25/25 14:40	04/29/25 10:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 24 - W.F20/3rd FI. By Rm #316 Lims Reference ID: AD17707-24 Matrix: Drinking Water Sampled: 04/16/25 07:32:00									
Metals									
Lead	10.3	1	1.00		µg/L	04/25/25 14:40	04/29/25 10:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 25 - S.F4/Teachers Room Lims Reference ID: AD17707-25 Matrix: Drinking Water Sampled: 04/16/25 07:33:00									
Metals									
Lead	22.9	1	1.00		µg/L	04/28/25 14:29	04/30/25 21:24	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 26 - SF/Lactation Room in Nurse Room Lims Reference ID: AD17707-26 Matrix: Drinking Water Sampled: 04/16/25 07:20:00									
Metals									
Lead	45.7	1	1.00		µg/L	04/25/25 14:40	04/29/25 10:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 27 - WFB-2/By Wellness Lounge - 2nd Floor Lims Reference ID: AD17707-27 Matrix: Drinking Water Sampled: 04/16/25 07:27:00									
Metals									
Lead	ND	1	1.00		µg/L	04/25/25 14:40	04/29/25 10:09	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517707**LIMS Reference ID:** AD17707**EMSL Customer ID:** TTIE54**Attention:** Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / Public School #28

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/05/2025 17:26

Analytical Results**(Continued)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	-----------------------	-----------------------	---------------------	----------------------------

Sample: 28 - WFB-3/By Rm# 316**Lims Reference ID:** AD17707-28 **Matrix:** Drinking Water**Sampled:** 04/16/25 07:29:00**Metals**

Lead	ND	1	1.00	µg/L	04/25/25 14:40	04/29/25 10:11	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------