

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517681
LIMS Reference ID: AD17681
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477 / Young Mens Leadership Academy

Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/18/2025 09:00
Reported: 05/02/2025 12:21

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WFB1/By Guidance Office Lims Reference ID: AD17681-01 Matrix: Drinking Water Sampled: 04/16/25 07:31:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 17:28	04/29/25 21:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF1/By Kitchen Lims Reference ID: AD17681-02 Matrix: Drinking Water Sampled: 04/16/25 07:34:00									
Metals									
Lead	3.64		1	1.00	µg/L	04/28/25 17:28	04/29/25 21:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF2/Teachers' Lounge Room Lims Reference ID: AD17681-03 Matrix: Drinking Water Sampled: 04/16/25 07:35:00									
Metals									
Lead	3.76		1	1.00	µg/L	04/28/25 17:28	04/29/25 22:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WFB2/By Nurse Office Lims Reference ID: AD17681-04 Matrix: Drinking Water Sampled: 04/16/25 07:36:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 17:28	04/29/25 22:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SF3/Nurse Office Lims Reference ID: AD17681-05 Matrix: Drinking Water Sampled: 04/16/25 07:36:00									
Metals									
Lead	1.09		1	1.00	µg/L	04/28/25 17:28	04/29/25 22:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF/By Guidance Office Lims Reference ID: AD17681-06 Matrix: Drinking Water Sampled: 04/16/25 07:32:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 17:28	04/29/25 22:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF/By Nurse Office Lims Reference ID: AD17681-07 Matrix: Drinking Water Sampled: 04/16/25 07:37:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 17:28	04/29/25 22:12	PL	EPA 200.8 (DA)/EPA 200.8