

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517698
LIMS Reference ID: AD17698
EMSL Customer ID: TTIE54

Attention: Tim Popp

TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name:

24-1477 / SAGE Building

Customer PO:

041096

EMSL Sales Rep:

Sheryl Steinmetz

Received:

04/18/2025 09:00

Reported:

05/02/2025 12:53

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 1 - SF-1/Basement Kitchen Lims Reference ID: AD17698-01 Matrix: Drinking Water Sampled: 04/17/25 08:20:00									
Metals									
Lead	1.28		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 2 - WF-1/Basement Hallway Boys & Girls Bathroom Lims Reference ID: AD17698-02 Matrix: Drinking Water Sampled: 04/17/25 08:26:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 3 - WF2B/Basement Hallway Boys & Girls Bathroom Lims Reference ID: AD17698-03 Matrix: Drinking Water Sampled: 04/17/25 08:26:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 4 - WF2/Basement Hallway Boys & Girls Bathroom Lims Reference ID: AD17698-04 Matrix: Drinking Water Sampled: 04/17/25 08:27:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 5 - SF-2/Room - B1 Lims Reference ID: AD17698-05 Matrix: Drinking Water Sampled: 04/17/25 08:29:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 6 - SF-3/Basement Nurse Office Bathroom Lims Reference ID: AD17698-06 Matrix: Drinking Water Sampled: 04/17/25 08:31:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 7 - SF-4/Basement Nurse Office Lims Reference ID: AD17698-07 Matrix: Drinking Water Sampled: 04/17/25 08:31:00									
Metals									
Lead	2.60		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 8 - WF3B/1st Floor Hallway Boys & Girls Bathroom Lims Reference ID: AD17698-08 Matrix: Drinking Water Sampled: 04/17/25 08:35:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 9 - WF3/1st Floor Hallway Boys & Girls Bathroom Lims Reference ID: AD17698-09 Matrix: Drinking Water Sampled: 04/17/25 08:36:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517698
LIMS Reference ID: AD17698
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477 / SAGE Building

Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/18/2025 09:00
Reported: 05/02/2025 12:53

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 9 - WF3/1st Floor Hallway Boys & Girls Bathroom (Continued) Lims Reference ID: AD17698-09 Matrix: Drinking Water Sampled: 04/17/25 08:36:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 10 - WF-4/1st Floor Hallway Boys & Girls Bathroom Lims Reference ID: AD17698-10 Matrix: Drinking Water Sampled: 04/17/25 08:37:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 11 - WF5B/2nd Floor Hallway Boys & Girls Bathroom Lims Reference ID: AD17698-11 Matrix: Drinking Water Sampled: 04/17/25 08:42:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12 - WF5/2nd Floor Hallway Boys & Girls Bathroom Lims Reference ID: AD17698-12 Matrix: Drinking Water Sampled: 04/17/25 08:43:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 13 - SF-5/2nd Floor Teacher Lunch Lims Reference ID: AD17698-13 Matrix: Drinking Water Sampled: 04/17/25 08:44:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 14 - WF-6/3rd Floor Hallway Boys Bathroom Lims Reference ID: AD17698-14 Matrix: Drinking Water Sampled: 04/17/25 08:51:00									
Metals									
Lead	19.6		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 15 - WF-7/4th Floor Hallway Boys Bathroom Lims Reference ID: AD17698-15 Matrix: Drinking Water Sampled: 04/17/25 08:53:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 16 - SF-2 Left/Kitchen Basement Lims Reference ID: AD17698-16 Matrix: Drinking Water Sampled: 04/17/25 08:23:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 17 - SF-3 Right/Kitchen Basement Lims Reference ID: AD17698-17 Matrix: Drinking Water Sampled: 04/17/25 08:24:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517698
LIMS Reference ID: AD17698
EMSL Customer ID: TTIE54

Attention: Tim Popp
TTI Environmental Inc. [TTIE54]
1253 North Church Street
Moorestown, NJ 08057
(856) 840-8800
timp@ttienv.com

Project Name: 24-1477 / SAGE Building

Customer PO: 041096
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/18/2025 09:00
Reported: 05/02/2025 12:53

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 17 - SF-3 Right/Kitchen Basement (Continued) Lims Reference ID: AD17698-17 Matrix: Drinking Water Sampled: 04/17/25 08:24:00									
Metals									
Lead	1.03		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 18 - W.F.B. - 6/4th Floor Hallway Boys Bathroom Lims Reference ID: AD17698-18 Matrix: Drinking Water Sampled: 04/17/25 08:55:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 19 - Field Blank Lims Reference ID: AD17698-19 Matrix: Drinking Water Sampled: 04/17/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 14:31	04/30/25 00:49	PL	EPA 200.8 (DA)/EPA 200.8