Morris School District							
Lafayette Learning Center							
Drinking water testing - 2025							
	Control Sample	Taken from bottled water NOT from teachers room sinks as on chain of command sheets					
	Description	Date of Sample	Type of sample	Results Concentration ug/L (ppb)	Maximum Acceptable Contaminant Level	Analysis Date	
W.F # 1	Water Fountain	4/8/2025	First Draw	< 1.00	15.0 ppb	4/18/2025	
W.F. # 2	Water Fountain	4/8/2025	First Draw	< 1.00	15.0 ppb	4/18/2025	
Kitchen	Kitchen Prep Sink	4/8/2025	First Draw	3.98	15.0 ppb	4/18/2025	
Control sample		4/11/2025		< 1.00	15.0 ppb	4/18/2025	

Morris School District

Alfred Vail Elementary School

Drinking Water Testing - 2025 School Year

Control Sample | Taken from bottled water NOT from teachers room sinks as on chain of command sheets

Location	Description	Date of Sample	Type of sample	Results Concentration ug/L (ppb)	Maximum Acceptable Contaminant Level	Analysis Date
WF # 1	Water Fountain	4/8/2025	First Draw	< 1.00	15.0 ppb	4/18/2025
WF # 2	Water Fountain	4/8/2025	First Draw	< 1.00	15.0 ppb	4/18/2025
WF # 3	Water Fountain	4/8/2025	First Draw	< 1.00	15.0 ppb	4/18/2025
WF # 4	Water Fountain	4/8/2025	First Draw	< 1.00	15.0 ppb	4/18/2025
WF # 5	Water Fountain	4/8/2025	First Draw	< 1.00	15.0 ppb	4/18/2025
WF # 6	Water Fountain	4/8/2025	First Draw	< 1.00	15.0 ppb	4/18/2025
WF # 7	Water Fountain	4/8/2025	First Draw	< 1.00	15.0 ppb	4/18/2025
WF # 8	Water Fountain	4/8/2025	First Draw	< 1.00	15.0 ppb	4/18/2025
Kitchen	Kitchen Prep Sink	4/9/2025	First Draw	6.2	15.0 ppb	4/18/2025
Control sample		4/11/2025		<1.00	15.0 ppb	4/18/2025

Morris school district

Alexander Hamilton Elementary School

Drinking Water Testing - 2025 School year

Control Sample | Taken from bottled water NOT from teachers room sinks as on chain of command sheets

Location	Description	Date of Sample	Type of sample	Results Concentration ug/L (ppb)	Maximum Acceptable Contaminant Level	Analysis Date
WF # 1	Water Fountain	4/11/2025	First Draw	< 1.00	15.0 ppb	4/18/2025
WF # 2	Water Fountain	4/11/2025	First Draw	< 1.00	15.0 ppb	4/18/2025
WF # 3	Water Fountain	4/11/2025	First Draw	< 1.00	15.0 ppb	4/18/2025
WF # 4	Water Fountain	4/11/2025	First Draw	< 1.00	15.0 ppb	4/18/2025
WF # 5	Water Fountain	4/11/2025	First Draw	< 1.00	15.0 ppb	4/18/2025
WF # 6	Water Fountain	4/11/2025	First Draw	< 1.00	15.0 ppb	4/18/2025
Kitchen	Kitchen Prep Sink	4/11/2025	First Draw	1.43	15.0 ppb	4/18/2025
Control Sample		4/14/2025		< 1.00	15.0 ppb	4/18/2025

Morris School District							
Sussex Avenue Elementary School							
drinking Water Testing - 2025 School Year							
Control Sample	Taken from bottled water NOT from teachers room sinks as on chain of command sheets						
Location	Description	Date of Sample	Type of Sample	Results Concentration ug/L (ppb)	Maximum Acceptable Contaminant Level	Analysis Date	Corrective Actions Taken
WF # 1	Water Fountain	4/11/2025	First Draw	< 1.00	15.0 ppb	4/18/2025	
WF # 2	Water Fountain	4/11/2025	First Draw	< 1.00	15.0 ppb	4/18/2025	
WF # 3	Water Fountain	4/11/2025	First Draw	< 1.00	15.0 ppb	4/18/2025	
WF # 4	Water Fountain	4/11/2025	First Draw	< 1.00	15.0 ppb	4/18/2025	
WF # 5	Water Fountain	4/11/2025	First Draw	< 1.00	15.0 ppb	4/18/2025	
WF # 6/ GYM	Water Fountain	4/11/2025	First Draw	14.1	15.0 ppb	4/18/2025	turned off 6-30-25
Kitchen	Kitchen Prep Sink	4/11/2025	First Draw	< 1.00	15.0 ppb	4/18/2025	
Control Sample		4/14/2025		< 1.00	15.0 ppb	4/18/2025	

Morris School District						
Normandy Park Elementary School						
Drinking Water Testing - 2025 School Year						
Control Sample	Taken from bottled water NOT from teachers room sinks as on chain of command sheets					
Location	Description	Date of Sample	Type of Sample	Results Concentration ug/L (ppb)	Maximum Acceptable Contaminant Level	Analysis Date
WF # 1	Water Fountain	4/23/2025	First Draw	< 1.00	15.0 ppb	5/2/2025
WF # 2	Water Fountain	4/23/2025	First Draw	< 1.00	15.0 ppb	5/2/2025
WF # 3	Water Fountain	4/23/2025	First Draw	< 1.00	15.0 ppb	5/2/2025
WF # 4	Water Fountain	4/23/2025	First Draw	< 1.00	15.0 ppb	5/2/2025
WF # 5	Water Fountain	4/23/2025	First Draw	< 1.00	15.0 ppb	5/2/2025
WF # 6	Water Fountain	4/23/2025	First Draw	< 1.00	15.0 ppb	5/2/2025
WF # 7	Water Fountain	4/23/2025	First Draw	< 1.00	15.0 ppb	5/5/2025
Kitchen	Kitchen Prep Sink	4/23/2025	First Draw	< 1.00	15.0 ppb	5/5/2025
Control Sample		4/25/2025		< 1.00	15.0 ppb	5/7/2025

Morris School District

Thomas Jefferson Elementary School

Drinking Water Testing 2025 - School Year

Control Sample Taken from bottled water NOT from teachers room sinks as on chain of command sheets

Location	Description	Date of Sample	Type of Sample	Results Concentration ug/L (ppb)	Maximum Acceptable Contaminant Level	Analysis Date
WF # 1	Water Fountain	4/23/2025	First Draw	< 1.00	15.0 ppb	5-6-2025
WF # 2	Water Fountain	4/23/2025	First Draw	< 1.00	15.0 ppb	5-6-2025
WF # 3	Water Fountain	4/23/2025	First Draw	< 1.00	15.0 ppb	5-6-2025
WF # 4	Water Fountain	4/23/2025	First Draw	< 1.00	15.0 ppb	5-6-2025
WF # 5	Water Fountain	4/23/2025	First Draw	< 1.00	15.0 ppb	5-6-2025
WF # 6	Water Fountain	4/23/2025	First Draw	< 1.00	15.0 ppb	5-6-2025
WF # 7	Water Fountain	4/23/2025	First Draw	< 1.00	15.0 ppb	5-6-2025
Kitchen	Kitchen Prep Sink	4/23/2025	First Draw	1	15.0 ppb	5-6-2025
Control Sample		4/25/2025		< 1.00	15.0 ppb	5-6-2025

Morris School District

Hillcrest Elementary School

Drinking Water Testing - 2025 School Year

Control Sample | Taken from bottled water NOT from teachers room sinks as on chain of command sheets

Location	Description	Date of Sample	Type of sample	Results Concentration ug/L (ppb)	Maximum Acceptable Contaminant Level	Analysis Date	Corrective Actions Taken	New sampole results
W.F. #1	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/1/2025		
W.F. #2	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/1/2025		
W.F. #3	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/2/2025		
W.F. #4	Water Fountain	4/25/2025	First Draw	16.09	15.0 ppb	5/2/2025	Replace water fountain with new bottle filler added additional filter 6-11-25	new sample taken 6-11-25 Results < 1.00
Control Sample		6/26/2025		<1.00		6/26/2025		
Kitchen	Kitchen Prep Sink	4/25/2025	First Draw	1.09	15.0 ppb	5/2/2025		
Control sample		4/25/2025		< 1.00	15.0 ppb	5/2/2025		

Morris School District

Frelinghuysen Middle School

Drinking Water Testing - 2025 School Year

Control Sample | Taken from bottled water NOT from teachers room sinks as on chain of command sheets

Location	Description	Date of Sample	Type of sample	Results Concentration ug/L (ppb)	Maximum Acceptable Contaminant Level	Analysis Date
WF # 1	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 2	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 3	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 4	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 5	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 6a	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 6b	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 7	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 8	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 9	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 10	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 11	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 12	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 13	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 14	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 1 T.R.- A	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 2 T.R.- A	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 1 T.R.- B	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 2 T.R.- B	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 1 T. R - C	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
WF # 2 T. R - C	Water Fountain	4/22/2025	First Draw	< 1.00	15.0 ppb	5/6/2025
Kitchen	Kitchen Prep Sink	4/22/2025	First Draw	1.64	15.0 ppb	5/6/2025
Control Sample		4/25/2025		< 1.00	15.0 ppb	5/6/2025

Morris School District						
Morristown High School						
Drinking Water Testing - 2025 School Year						
Control Sample	Taken from bottled water NOT from teachers room sinks as on chain of command sheets					
Location	Description	Date of Sample	Type of sample	Results Concentration ug/L (ppb)	Maximum Acceptable Contaminant Level	Analysis Date
WF # 1	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 2	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 3	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 4A	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 4B	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 5	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 6	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 7	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 8	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 9	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 10	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 11	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 12	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 13	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 14	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 15	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 2A	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 1A	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
Kitchen 1A	Kitchen Prep Sink	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
Kitchen 1B	Kitchen Prep Sink	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 16	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 17	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 18	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 19	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25

WF # 20	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 21	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
Wf # 22	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 23	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 24	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 25	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 3A	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25
WF # 4A	Water Fountain	4/25/2025	First Draw	< 1.00	15.0 ppb	5/10/25

Morris School District						
Woodland Avenue Elementary School						
Drinking Water Testing - 2025 School Year						
Control Sample	Taken from bottled water NOT from teachers room sinks as on chain of command sheets					
Location	Description	Date of Sample	Type of sample	Results	Maximum Acceptable Contaminant Level	Analysis Date
W.F # 1	Water Fountain	4/23/2025	First Draw	< 1.00	15.0 ppb	5/6/0205
W.F # 2	Water Fountain	4/23/2025	First Draw	< 1.00	15.0 ppb	5/6/0205
W.F # 3	Water Fountain	4/23/2025	First Draw	< 1.00	15.0 ppb	5/6/0205
Kitchen	Kitchen Prep Sink	4/23/2025	First Draw	2.67	15.0 ppb	5/6/0205
Control Sample		4/25/2025		< 1.00	15.0 ppb	5/6/0205

Morris School District

Athletic Fields

Drinking water testing 2025 school year

Field	Location	Description	Date of Sample	Type of sample	Results	Maximum Acceptable Contaminant Level	Analysis Date
Harter Road	Wf # 1	Water Fountain	6/11/2025	First Draw	< 1.00	15.0 ppb	6-26-25
Harter Road	WF # 2	Water Fountain	6/11/2025	First Draw	<1.00	15.0 ppb	6-26-25
Harter Road	WF # 3	Water Fountain	6/11/2025	First Draw	< 1.00	15.0 ppb	6-26-25
Control sample			6/26/2025		< 1.00	15.0 ppb	6-26-25
High School	WF by visitors Bleachers	Water Fountain	6/19/2025	First Draw	< 1.00	15.0 ppb	6-26-25
High School	Bubbler by concession	Bubbler	6/19/2025	First Draw	< 1.00	15.0 ppb	6-26-25
Control sample			6/26/2025		<1.00	15.0 ppb	2-26-25
Frelinghuysen	WF between F1 & F2	Water Fountain	6/11/2025	First Draw	< 1.00	15.0 ppb	2-26-25
Control sample			6-26-25		< 1.00	15.0 ppb	2-26-25