



EnviroVision
Consultants, Inc.

20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145/Email:info@envirovisionconsultants.com
NJ DOH IEHA Lic.# 1097

CLIENT: Somerset Hills School District
PROJECT: Lead (Pb)in Drinking Water
ADDRESS: 25 Olcott Avenue, Bernardsville, NJ 07924
Field Technician: Dakota Arabia-Meyer

Project Number: 25-196
Bernards High School
Report Date: June 24, 2025

As per your request, EnviroVision Consultants, Inc. was contracted by Somerset Hills School District to conduct Lead (Pb) in drinking water sampling at Bernards High School on June 7, 2025. The sample locations, in addition to unique sample location codes, were determined / assigned by school district personnel. The school district performed the proper flushing of the outlets prior to sampling and EnviroVision was instructed to collect only first draw samples for this sampling event. The school district's corresponding flushing logs should be attached to this report.

The facility was closed at the time of sampling in order to prevent occupants from utilizing any water outlets. After flushing, the water in the facility must remain motionless in the plumbing fixtures for a minimum of 8 hours, but no more than 48 hours. Cold water samples were collected in pre-cleaned high-density polyethylene (HDPE) 250mL wide mouth bottles.

The sample was analyzed at EMSL Analytical, Inc. in Cinnaminson, New Jersey (NJDEP#03036), accredited in accordance with NELAC (National Environmental Laboratory Accreditation Conference). The analytical method utilized was inductively coupled plasma mass spectrometry ICP-MS (EPA 200.8).

Results: Forty-Three drinking water samples were collected and analyzed from Bernards High School. All of the samples analyzed were either "None Detected" or less than the US EPA established threshold for lead in drinking water of 15 parts per billion (ppb or ug/L). In addition, a blank sample was collected and analyzed, as required, for Quality Assurance purposes.

Should you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision looks forward to providing you with the service and attention to detail you have come to expect from us.

Sincerely,
EnviroVision Consultants, Inc.

Cathy DiNardo

Cathy DiNardo, Project Manager
Attached: Lab results, associated data sheets



EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012523802
LIMS Reference ID: AD23802
EMSL Customer ID: RAMA51

Attention: Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

Somerset Hills School District - Bernards High
School - 25 Olcott Ave, Bernardsville, NJ
07924 / 25-196

Customer PO:

Sheryl Steinmetz

EMSL Sales Rep:

Received:

06/10/2025 09:00

Reported:

06/23/2025 16:37

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: A204-IWFL/Left Side Hallway Next to Weight Room									
			Lims Reference ID:		AD23802-01		Matrix: Drinking Water		Sampled: 06/07/25 08:30:00
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:19	06/18/25 12:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: A204-IWFO/Fountain Next to Lockers									
			Lims Reference ID:		AD23802-02		Matrix: Drinking Water		Sampled: 06/07/25 08:31:00
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:19	06/18/25 12:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: A204-2BF/Bottle Filler Next to Lockers									
			Lims Reference ID:		AD23802-03		Matrix: Drinking Water		Sampled: 06/07/25 08:32:00
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:19	06/18/25 12:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: A304-1WF/3rd Floor Left of Room B304									
			Lims Reference ID:		AD23802-04		Matrix: Drinking Water		Sampled: 06/07/25 08:37:00
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:19	06/18/25 12:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: A304-2BF/3rd Floor Left of Room B304									
			Lims Reference ID:		AD23802-05		Matrix: Drinking Water		Sampled: 06/07/25 08:38:00
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:19	06/18/25 12:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Principal Sink/Principal Office Keurig									
			Lims Reference ID:		AD23802-06		Matrix: Drinking Water		Sampled: 06/07/25 08:42:00
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:19	06/18/25 12:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Attendance Sink/Attendance Office Keurig									
			Lims Reference ID:		AD23802-07		Matrix: Drinking Water		Sampled: 06/07/25 08:44:00
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:19	06/18/25 12:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: A306-WF/Left of Room 306									
			Lims Reference ID:		AD23802-08		Matrix: Drinking Water		Sampled: 06/07/25 08:49:00
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:19	06/18/25 12:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: A410-1WF/Left of Room A410									
			Lims Reference ID:		AD23802-09		Matrix: Drinking Water		Sampled: 06/07/25 08:50:00
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:19	06/18/25 12:53	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:cs@emsl.com
 EMSL-CIN-01

EMSL Order ID: 012523802
LIMS Reference ID: AD23802
EMSL Customer ID: RAMA51

Attention: Info

EnviroVision Consultants, Inc [RAMA51]
 20-21 Wagaraw Rd, Bldg 35E
 Fair Lawn, NJ 07410
 (973) 636-9145
 info@envirovisionconsultants.com

Project Name:

Somerset Hills School District - Bernards High
 School - 25 Olcott Ave, Bernardsville, NJ
 07924 / 25-196

Customer PO:

Sheryl Steinmetz

EMSL Sales Rep:**Received:**

06/10/2025 09:00

Reported:

06/23/2025 16:37

Analytical Results**(Continued)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: A410-2BF/Left of Room A410 Lims Reference ID: AD23802-10 Matrix: Drinking Water Sampled: 06/07/25 08:50:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:19	06/18/25 12:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: A404-1WF/Left of Room A404 Lims Reference ID: AD23802-11 Matrix: Drinking Water Sampled: 06/07/25 08:54:00									
Metals									
Lead	1.35		1	1.00	µg/L	06/11/25 14:19	06/18/25 12:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Nurse B300WF/Sink in Nurses Office Lims Reference ID: AD23802-12 Matrix: Drinking Water Sampled: 06/07/25 08:58:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:19	06/18/25 13:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: B300-1WFL/Fountain Next to Custodial Closet Lims Reference ID: AD23802-13 Matrix: Drinking Water Sampled: 06/07/25 09:01:00									
Metals									
Lead	ND		1	1.00	µg/L	06/12/25 17:04	06/12/25 23:03	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: B300-2BF/Fountain Next to Custodial Closet Lims Reference ID: AD23802-14 Matrix: Drinking Water Sampled: 06/07/25 09:02:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 10:51	06/12/25 17:46	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: B300-3WF/Fountain Across from Lockers Lims Reference ID: AD23802-15 Matrix: Drinking Water Sampled: 06/07/25 09:06:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:19	06/18/25 13:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: C203-1WFL/Fountain Across from Elevators Lims Reference ID: AD23802-16 Matrix: Drinking Water Sampled: 06/07/25 09:20:00									
Metals									
Lead	1.70		1	1.00	µg/L	06/11/25 14:19	06/18/25 13:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: C203-1WFU/Fountain Across from Elevators Lims Reference ID: AD23802-17 Matrix: Drinking Water Sampled: 06/07/25 09:21:00									
Metals									
Lead	2.05		1	1.00	µg/L	06/11/25 14:19	06/18/25 13:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: C205-Sink/Home Living Room C205 Lims Reference ID: AD23802-18 Matrix: Drinking Water Sampled: 06/07/25 09:26:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:19	06/18/25 13:13	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:cs@emsl.com
 EMSL-CIN-01

EMSL Order ID: 012523802
LIMS Reference ID: AD23802
EMSL Customer ID: RAMA51

Attention: Info

EnviroVision Consultants, Inc [RAMA51]
 20-21 Wagaraw Rd, Bldg 35E
 Fair Lawn, NJ 07410
 (973) 636-9145
 info@envirovisionconsultants.com

Project Name:

Somerset Hills School District - Bernards High
 School - 25 Olcott Ave, Bernardsville, NJ
 07924 / 25-196

Customer PO:

Sheryl Steinmetz

EMSL Sales Rep:**Received:**

06/10/2025 09:00

Reported:

06/23/2025 16:37

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: B200-1WF/Fountain Right of Boys Bathroom Lims Reference ID: AD23802-19 Matrix: Drinking Water Sampled: 06/07/25 09:30:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:19	06/18/25 13:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: B200-BF/Bottle Filler Right of Boys Bathroom Lims Reference ID: AD23802-20 Matrix: Drinking Water Sampled: 06/07/25 09:31:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:19	06/18/25 13:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: D29-1L/Lower Fountain Right of Boys Bathroom Lims Reference ID: AD23802-21 Matrix: Drinking Water Sampled: 06/07/25 09:38:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:19	06/18/25 13:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: D29-26/Upper Fountain Right of Boys Bathroom Lims Reference ID: AD23802-22 Matrix: Drinking Water Sampled: 06/07/25 09:39:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:19	06/18/25 13:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: D29-3 Bottle Filler/Bottle Filler Next to Both Bathrooms Lims Reference ID: AD23802-23 Matrix: Drinking Water Sampled: 06/07/25 09:40:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:17	06/18/25 13:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Cafe Ice Machine/Ice Machine in Cafe Corner Lims Reference ID: AD23802-24 Matrix: Drinking Water Sampled: 06/07/25 09:46:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 10:51	06/12/25 17:49	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: Kit1/Sink on Left Side Next to Ice Machine Lims Reference ID: AD23802-25 Matrix: Drinking Water Sampled: 06/07/25 09:51:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:17	06/18/25 13:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Kit2/Sink Across from Double Doors Lims Reference ID: AD23802-26 Matrix: Drinking Water Sampled: 06/07/25 09:53:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:17	06/18/25 13:57	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:cs@emsl.com
 EMSL-CIN-01

EMSL Order ID: 012523802
LIMS Reference ID: AD23802
EMSL Customer ID: RAMA51

Attention: Info

EnviroVision Consultants, Inc [RAMA51]
 20-21 Wagaraw Rd, Bldg 35E
 Fair Lawn, NJ 07410
 (973) 636-9145
 info@envirovisionconsultants.com

Project Name:

Somerset Hills School District - Bernards High
 School - 25 Olcott Ave, Bernardsville, NJ
 07924 / 25-196

Customer PO:

Sheryl Steinmetz

EMSL Sales Rep:**Received:**

06/10/2025 09:00

Reported:

06/23/2025 16:37

Analytical Results
 (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: Kit3/Sink on Back of Sink 2									
				Lims Reference ID: AD23802-27		Matrix: Drinking Water		Sampled: 06/07/25 09:54:00	
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:17	06/18/25 13:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Kit4/Sink on Far Back Wall Near Windows									
				Lims Reference ID: AD23802-28		Matrix: Drinking Water		Sampled: 06/07/25 09:55:00	
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:17	06/18/25 14:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Kit5/Sink Adjacent to Sink 4									
				Lims Reference ID: AD23802-29		Matrix: Drinking Water		Sampled: 06/07/25 09:56:00	
Metals									
Lead	3.83		1	1.00	µg/L	06/11/25 10:51	06/12/25 17:51	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: Kit6/Sink Next to Grill									
				Lims Reference ID: AD23802-30		Matrix: Drinking Water		Sampled: 06/07/25 09:58:00	
Metals									
Lead	2.78		1	1.00	µg/L	06/11/25 14:17	06/18/25 14:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Kit PF/Sink Next to Coffee Station									
				Lims Reference ID: AD23802-31		Matrix: Drinking Water		Sampled: 06/07/25 10:00:00	
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:17	06/18/25 14:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Fac Dining/Fountain Next to Brunos Room									
				Lims Reference ID: AD23802-32		Matrix: Drinking Water		Sampled: 06/07/25 10:14:00	
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:17	06/18/25 14:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LA Bruno WF/Fountains on Right Side of Ramp									
				Lims Reference ID: AD23802-33		Matrix: Drinking Water		Sampled: 06/07/25 10:18:00	
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:17	06/18/25 14:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: L Gym-1/Fountain on Right Side Entry									
				Lims Reference ID: AD23802-34		Matrix: Drinking Water		Sampled: 06/07/25 10:25:00	
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:17	06/18/25 14:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: L Gym-2/Fountain in Middle Left Side Wall									
				Lims Reference ID: AD23802-35		Matrix: Drinking Water		Sampled: 06/07/25 10:26:00	
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:17	06/18/25 14:16	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:cs@emsl.com
 EMSL-CIN-01

EMSL Order ID: 012523802
LIMS Reference ID: AD23802
EMSL Customer ID: RAMA51

Attention: Info

EnviroVision Consultants, Inc [RAMA51]
 20-21 Wagaraw Rd, Bldg 35E
 Fair Lawn, NJ 07410
 (973) 636-9145
 info@envirovisionconsultants.com

Project Name:

Somerset Hills School District - Bernards High
 School - 25 Olcott Ave, Bernardsville, NJ
 07924 / 25-196

Customer PO:

Sheryl Steinmetz

EMSL Sales Rep:**Received:**

06/10/2025 09:00

Reported:

06/23/2025 16:37

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: G-206 BF/Bottle Filler Across from Gym Lims Reference ID: AD23802-36 Matrix: Drinking Water Sampled: 06/07/25 10:32:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 10:51	06/12/25 17:53	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: G207-WF/Water Fountain Across on Right Side Gym Lims Reference ID: AD23802-37 Matrix: Drinking Water Sampled: 06/07/25 10:33:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:17	06/18/25 14:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: G201-WF/Fountain Across from Elevator Lims Reference ID: AD23802-38 Matrix: Drinking Water Sampled: 06/07/25 10:37:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:17	06/18/25 14:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: G111-WF/Fountain Across from Gym Lims Reference ID: AD23802-39 Matrix: Drinking Water Sampled: 06/07/25 10:40:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:17	06/18/25 14:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: G114-WF/Fountain Facing Boys Locker Room Lims Reference ID: AD23802-40 Matrix: Drinking Water Sampled: 06/07/25 10:41:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:17	06/18/25 14:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: G115-WF/Fountain in Boys Locker Room Lims Reference ID: AD23802-41 Matrix: Drinking Water Sampled: 06/07/25 10:51:00									
Metals									
Lead	2.81		1	1.00	µg/L	06/11/25 14:17	06/18/25 14:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: G115-Ice Machine/Ice Machine in Storage Lims Reference ID: AD23802-42 Matrix: Drinking Water Sampled: 06/07/25 10:55:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:17	06/18/25 14:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: D20-WF/Water Fountain in Storage Lims Reference ID: AD23802-43 Matrix: Drinking Water Sampled: 06/07/25 11:00:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:17	06/18/25 14:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Blank/Blank Lims Reference ID: AD23802-44 Matrix: Drinking Water Sampled: 06/07/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	06/11/25 14:17	06/18/25 14:38	PL	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012523802
LIMS Reference ID: AD23802
EMSL Customer ID: RAMA51

Attention: Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

Somerset Hills School District - Bernards High
School - 25 Olcott Ave, Bernardsville, NJ
07924 / 25-196

Customer PO:

Sheryl Steinmetz

EMSL Sales Rep:

Received:

06/10/2025 09:00

Reported:

06/23/2025 16:37

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: Blank/Blank (Continued)

Lims Reference ID: AD23802-44 Matrix: Drinking Water

Sampled: 06/07/25 00:00:00

Metals (Continued)



EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012523802
LIMS Reference ID: AD23802
EMSL Customer ID: RAMA51

Attention: Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

Somerset Hills School District - Bernards High School - 25 Olcott Ave, Bernardsville, NJ 07924 / 25-196

Customer PO:

Sheryl Steinmetz

EMSL Sales Rep:

Received:

06/10/2025 09:00

Reported:

06/23/2025 16:37

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2026
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	04/01/2027
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012523802
LIMS Reference ID: AD23802
EMSL Customer ID: RAMA51

Attention: Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

Somerset Hills School District - Bernards High
School - 25 Olcott Ave, Bernardsville, NJ
07924 / 25-196

Customer PO:

EMSL Sales Rep:

Received:

Reported:

Sheryl Steinmetz
06/10/2025 09:00
06/23/2025 16:37

Notes and Definitions

Item	Definition
D	Analyte was reported from a dilution run.
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



A023808
 20-21 Wagaraw Road - Bldg. 35E, Fair Lawn, NJ 07410
 (973) 636-9145 / info@envirovisionconsultants.com
 NJDOH IHEA Lic #: 1097

CLIENT	Somerset Hills School District	ADDRESS	25 Olcott Ave, Bernardsville, NJ 07924
PROJECT	Bernard's High School	ADDRESS	25 Olcott Ave, Bernardsville, NJ 07924
TECH	Dakota Arabia-Meyer	SAMPLING DATE	6 / 7 / 2025 PROJ # 25 - 196

LEAD IN DRINKING WATER DATA SHEET

Sample ID #	Date/Time Collected	Sample Location	Observations
A204-1WF	6/7/25 8:30	Left Side Hallway next to Weight room	
A204-1WFL	6/7/25 8:31	Fountain NEXT to lockers	
A204-2BF	6/7/25 8:32	Bottle f. lics next to lockers	
A304-1WF	6/7/25 8:37	3rd Floor left of room B304	
A304-2BF	6/7/25 8:38	3rd Floor left of room B304	
Principal Sink	6/7/25 8:42	Principal office Keying	
Attendance Sink	6/7/25 8:44	Attendance office Keying	
A306-WF	6/7/25 8:49	Left of room 306	
A410-1WF	6/7/25 8:50	Left of room 410	
A410-2BF	6/7/25 8:50	Left of room 410	
A404-1WF	6/7/25 8:54	Left of room 4104	
Nurse B300WF	6/7/25 8:58	Sink in Nurses office	

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date & Time
Dakota Arabia-Meyer	[Signature] (WT)	6.9.25 @ 5 PM
	D. O'Keefe (WT)	6/10/25 0900

Rec'd PMS.

LABORATORY SUBMITTED TO:	
LAB ORDER #	

ANALYSIS:
 ___ Unpreserved, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))
X Preserved with HNO₃, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))

Matrix: Drinking Water, Sample Type: Grab
 Sample(s) Temperature Upon Receipt (Lab Only): _____
 Bottle Size: 250 mL, wide mouth
 TURNAROUND TIME 2 WEEKS
 EMAIL RESULTS TO info@envirovisionconsultants.com



20-21 Wagaraw Road - Bldg. 35E, Fair Lawn, NJ 07410
 (973) 636-9145 / info@envirovisionconsultants.com
 NJDOH IHEA Lic #: 1097

AD23802

CLIENT	Somerset Hills School District	ADDRESS	25 Olcott Ave, Bernardsville, NJ 07924
PROJECT	Bernard's High School	ADDRESS	25 Olcott Ave, Bernardsville, NJ 07924
TECH	Dakota Arabia-Meyer	SAMPLING DATE	6 / 7 / 2025 PROJ # 25 - 196

LEAD IN DRINKING WATER DATA SHEET

Sample ID #	Date/Time Collected	Sample Location	Observations
B300-1WFL	6/7/25 9:01	Fountain next to Custodial Closet	
B300-2BF	6/7/25 9:02	Fountain next to Custodial Closet	
B300-3WF	6/7/25 9:06	Fountain across from Lockers	
C-203-1WFL	6/7/25 9:20	Fountain across from elevators	
C-203-1WFL	6/7/25 9:21	Fountain across from elevators	
C-206 sink	6/7/25 9:26	Home living room C205	
B200-1wof	6/7/25 9:30	Fountain right of Boys Bathroom	
B200 BF	6/7/25 9:31	Bottle filler right of Boys Bathroom	
D29-1L	6/7/25 9:35	lower fountain right of Boys Bathroom	
D29-2L	6/7/25 9:39	upper fountain right of Boys Bathroom	
D29-3 Bottle Filler	6/7/25 9:40	Bottle filler next to both Bathrooms	
Cafe Ice-machine	6/7/25 9:46	Ice-Machine in Cafe corner	
KIT 1	6/7/25 9:51	sink on left side next to Ice-machine	
KIT 2	6/7/25 9:53	Sink across from double doors	
KIT 3	6/7/25 9:54	Sink on back of sink #2	
KIT 4	6/7/25 9:55	Sink on far back wall near window	
KIT 5	6/7/25 9:56	Sink adjacent to sink #4	
KIT 6	6/7/25 9:58	Sink next to grill	
KIT P.F	6/7/25 10:00	sink next to coffee station	
FAC Pining	6/7/25 10:14	Fountain next to Brunos room	
L A Bruno WF	6/7/25 10:18	Fountains on right side of ramp	
L Gym-1	6/7/25 10:25	Fountain on right side entry	
L Gym-2	6/7/25 10:26	Fountain in middle left side wall	
G-206 BF	6/7/25 10:32	Bottle filler across from gym	
G-207 WF	6/7/25 10:33	Water fountain across on right side gym	

