

Results Summary Lead in Drinking Water Samples 2024-2025 SY

School Name: East Brunswick School District - Support Operations Building

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S-SO01	13-SOF-041425-01	Training Room A; sink	ND	No
S-SO02	13-SOF-041425-02	Training Room B; sink	3.15	No
S-SO02	13-SOF-041425-03	Kitchenette; Chilled Water dispenser	ND	No
S-SO04	13-SOF-041425-04	Kitchenette; sink faucet	ND	No
QA BLANK	13-SOF-041425-05	QA Blank	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517035
LIMS Reference ID: AD17035
EMSL Customer ID: EDI50

Attention: Tim Gromen
Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name: East Brunswick BOE - Support Operations
Facility / PR-220424-1198

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/15/2025 09:00
Reported: 04/29/2025 16:26

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 13-SOF-041425-01/Training Room A Sink Lims Reference ID: AD17035-01 Matrix: Drinking Water Sampled: 04/14/25 08:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/15/25 14:51	04/15/25 19:50	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 13-SOF-041425-02/Training Room B Sink Lims Reference ID: AD17035-02 Matrix: Drinking Water Sampled: 04/14/25 08:01:00									
Metals									
Lead	3.15		1	1.00	µg/L	04/15/25 14:51	04/15/25 19:52	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 13-SOF-041425-03/Kitchenette Chilled Water Dispenser Lims Reference ID: AD17035-03 Matrix: Drinking Water Sampled: 04/14/25 08:03:00									
Metals									
Lead	ND		1	1.00	µg/L	04/15/25 14:51	04/15/25 19:54	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 13-SOF-041425-04/Kitchenette Sink Faucet Lims Reference ID: AD17035-04 Matrix: Drinking Water Sampled: 04/14/25 08:03:00									
Metals									
Lead	ND		1	1.00	µg/L	04/15/25 14:51	04/15/25 20:08	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 13-SOF-041425-05/QA Blank Lims Reference ID: AD17035-05 Matrix: Drinking Water Sampled: 04/14/25 08:00:00									
Metals									
Lead	ND		1	1.00	µg/L	04/17/25 12:08	04/17/25 20:43	JW1	EPA 200.8 (DA)/EPA 200.8