

Results Summary Lead in Drinking Water Samples 2024-2025 SY

School Name: East Brunswick School District - Hammarskjold Middle School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S-002	47-HAM-1108-01	Sink in Kitchen	ND	No
S-005	47-HAM-1108-02	Sink in Kitchen	2.43	No
S-007	47-HAM-1108-03	Sink in Kitchen	ND	No
S-009	47-HAM-1108-04	Sink across Rice Cooker	ND	No
S-55	47-HAM-1108-05	Rice Cooker Faucet	ND	No
S-011	47-HAM-1108-06	Sink in Kitchen	1.88	No
S-012	47-HAM-1108-07	Sink in Kitchen	ND	No
S-014	47-HAM-1108-08	Sink in Kitchen	1.53	No
S-016	47-HAM-1108-09	Sink in Kitchen	ND	No
S-018	47-HAM-1108-10	Sink in Faculty Room	ND	No
S-042	47-HAM-1108-11	Sink in Faculty Prep Room 1622	ND	No
BF-54	47-HAM-1108-12	Hall near HM1405	ND	No
WF-53	47-HAM-1108-13	Hall near HM1405	ND	No
WF-52	47-HAM-1108-14	Hall near HM1103	ND	No
S-065	47-HAM-1108-15	Sink in Home EC. Room HM1403	ND	No
S-066	47-HAM-1108-16	Sink in Home EC. Room HM1403	ND	No
S-064	47-HAM-1108-17	Sink in Home EC. Room HM1403	4.89	No
S-063	47-HAM-1108-18	Sink in Home EC. Room HM1403	5.59	No
S-062	47-HAM-1108-19	Sink in Home EC. Room HM1403	2.02	No
S-061	47-HAM-1108-20	Sink in Home EC. Room HM1403	2.58	No

Action Level (AL) ≥15.5 parts per billion (ppb)

Results Summary Lead in Drinking Water Samples 2024-2025 SY

School Name: East Brunswick School District - Hammarskjold Middle School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S-060	47-HAM-1108-21	Sink in Home EC. Room HM1403	2.88	No
S-059	47-HAM-1108-22	Sink in Home EC. Room HM1401	1.05	No
S-058	47-HAM-1108-23	Sink in Home EC. Room HM1401	ND	No
S-057	47-HAM-1108-24	Sink in Home EC. Room HM1401	ND	No
S-056	47-HAM-1108-25	Sink in Home EC. Room HM1401	ND	No
S-055	47-HAM-1108-26	Sink in Home EC. Room HM1401	ND	No
S-054	47-HAM-1108-27	Sink in Home EC. Room HM1401	ND	No
S-053	47-HAM-1108-28	Sink in Home EC. Room HM1401	ND	No
WF-029	47-HAM-1108-29	Water Fountain in Hall across from HM1507	ND	No
WF-28	47-HAM-1108-30	Water Fountain in Hall across from HM1507	ND	No
WF-025	47-HAM-1108-31	Water Fountain in Hall across from HM1524	ND	No
WF-024	47-HAM-1108-32	Water Fountain in Hall across from HM1524	ND	No
S-079	47-HAM-1108-33	Sink in Guidance Office Area HM1013	1.27	No
S-076	47-HAM-1108-34	Sink in Guidance Office Area HM1013	2.37	No
S-067	47-HAM-1108-35	Sink in Room HM1402	ND	No
S-036	47-HAM-1108-36	Sink in Faculty Prep Room HM1031	ND	No
S-091	47-HAM-1108-37	WF Cafe (Right)	ND	No
S-090	47-HAM-1108-38	WF Cafe (Left)	ND	No
BF-99	47-HAM-1108-39	Chiller Bottle filler in Cafeteria (filler)	ND	No
S-098	47-HAM-1108-40	Sink in Kitchen	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)

Results Summary Lead in Drinking Water Samples 2024-2025 SY

School Name: East Brunswick School District - Hammarskjold Middle School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S-092	47-HAM-1108-41	Sink in Kitchen	1.88	No
S-097	47-HAM-1108-42	Hose in kitchen	15.5	Yes
S-094	47-HAM-1108-43	Sink in Kitchen	38.8	Yes
S-073	47-HAM-1108-44	Sink in Exam Room 1003C in Nurse	5.55	No
S-100	47-HAM-1108-45	Sink in Nurses Office (Exam Room)	1.42	No
S-072	47-HAM-1108-46	Sink in Bathroom 1003B IN Nurse	ND	No
S-071	47-HAM-1108-47	Sink in Nurse Room 1003A	ND	No
S-068	47-HAM-1108-48	Sink in Main Office Area	ND	No
WF-085	47-HAM-1108-49	Water Fountain in Hall	ND	No
WF-083	47-HAM-1108-50	Water Fountain in Hall	ND	No
WF-084	47-HAM-1108-51	Water Fountain in Hall	ND	No
BLANK	47-HAM-1108-52	Deionized Blank	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:856-786-5974
EMSL-CIN-01

EMSL Order ID: 012436960
LIMS Reference ID: AC36960
EMSL Customer ID: EDI50

Attention: Tim Gromen
Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name: East Brunswick
BOE-Hammarskjold/PR-220424-1198

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 11/12/2024 09:00
Reported: 11/26/2024 16:22

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 47-HAM-1108-01/Sink in Kitchen Lims Reference ID: AC36960-01 Matrix: Drinking Water Sampled: 11/08/24 08:17:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 10:43	11/18/24 18:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-02/Sink in Kitchen Lims Reference ID: AC36960-02 Matrix: Drinking Water Sampled: 11/08/24 08:18:00									
Metals									
Lead	2.43		1	1.00	µg/L	11/15/24 10:43	11/18/24 19:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-03/Sink in Kitchen Lims Reference ID: AC36960-03 Matrix: Drinking Water Sampled: 11/08/24 08:19:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 10:43	11/18/24 19:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-04/Sink across Rice Cooker Lims Reference ID: AC36960-04 Matrix: Drinking Water Sampled: 11/08/24 08:20:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 10:43	11/18/24 19:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-05/Rice Cooker Faucet Lims Reference ID: AC36960-05 Matrix: Drinking Water Sampled: 11/08/24 08:21:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 10:43	11/18/24 19:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-06/Sink in Kitchen Lims Reference ID: AC36960-06 Matrix: Drinking Water Sampled: 11/08/24 08:22:00									
Metals									
Lead	1.88		1	1.00	µg/L	11/15/24 10:43	11/18/24 19:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-07/Sink in Kitchen Lims Reference ID: AC36960-07 Matrix: Drinking Water Sampled: 11/08/24 08:23:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 10:43	11/18/24 19:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-08/Sink in Kitchen Lims Reference ID: AC36960-08 Matrix: Drinking Water Sampled: 11/08/24 08:26:00									
Metals									
Lead	1.53		1	1.00	µg/L	11/15/24 10:43	11/18/24 19:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-09/Sink in Kitchen Lims Reference ID: AC36960-09 Matrix: Drinking Water Sampled: 11/08/24 08:27:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 10:43	11/18/24 19:25	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012436960**LIMS Reference ID:** AC36960**EMSL Customer ID:** EDI50**Attention:** Tim Gromen

Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name:

East Brunswick
BOE-Hammaraskjold/PR-220424-1198

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

11/12/2024 09:00

Reported:

11/26/2024 16:22

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 47-HAM-1108-10/Sink in Faculty Room Lims Reference ID: AC36960-10 Matrix: Drinking Water Sampled: 11/08/24 08:28:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 10:43	11/18/24 19:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-11/Sink in Faculty Prep Room 1622 Lims Reference ID: AC36960-11 Matrix: Drinking Water Sampled: 11/08/24 08:39:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 10:43	11/18/24 19:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-12/Hall near HM 1405 Lims Reference ID: AC36960-12 Matrix: Drinking Water Sampled: 11/08/24 08:42:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 10:43	11/18/24 19:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-13/Hall near HM 1405 Lims Reference ID: AC36960-13 Matrix: Drinking Water Sampled: 11/08/24 08:43:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 10:43	11/18/24 19:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-14/Hall near HM 1103 Lims Reference ID: AC36960-14 Matrix: Drinking Water Sampled: 11/08/24 08:46:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 10:43	11/18/24 19:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-15/Sink in Home EC. Room HM 1403 Lims Reference ID: AC36960-15 Matrix: Drinking Water Sampled: 11/08/24 08:49:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 10:43	11/18/24 19:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-16/Sink in Home EC. Room HM 1403 Lims Reference ID: AC36960-16 Matrix: Drinking Water Sampled: 11/08/24 08:49:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 10:43	11/18/24 19:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-17/Sink in Home EC. Room HM 1403 Lims Reference ID: AC36960-17 Matrix: Drinking Water Sampled: 11/08/24 08:51:00									
Metals									
Lead	4.89		1	1.00	µg/L	11/15/24 10:43	11/18/24 19:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-18/Sink in Home EC. Room HM 1403 Lims Reference ID: AC36960-18 Matrix: Drinking Water Sampled: 11/08/24 08:51:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012436960
LIMS Reference ID: AC36960
EMSL Customer ID: EDI50

Attention: Tim Gromen
Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name: East Brunswick
BOE-Hammar skjold/PR-220424-1198

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 11/12/2024 09:00
Reported: 11/26/2024 16:22

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: 47-HAM-1108-18/Sink in Home EC. Room Lims Reference ID: AC36960-18 Matrix: Drinking Water Sampled: 11/08/24 08:51:00
HM 1403 (Continued)

Metals

Lead	5.59	1	1.00	µg/L	11/15/24 10:43	11/18/24 19:54	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-19/Sink in Home EC. Room Lims Reference ID: AC36960-19 Matrix: Drinking Water Sampled: 11/08/24 08:52:00
HM 1403

Metals

Lead	2.02	1	1.00	µg/L	11/15/24 10:43	11/18/24 19:56	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-20/Sink in Home EC. Room Lims Reference ID: AC36960-20 Matrix: Drinking Water Sampled: 11/08/24 08:55:00
HM 1403

Metals

Lead	2.58	1	1.00	µg/L	11/15/24 10:43	11/18/24 19:58	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-21/Sink in Home EC. Room Lims Reference ID: AC36960-21 Matrix: Drinking Water Sampled: 11/08/24 08:55:00
HM 1403

Metals

Lead	2.88	1	1.00	µg/L	11/15/24 10:44	11/18/24 17:40	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-22/Sink in Home EC. Room Lims Reference ID: AC36960-22 Matrix: Drinking Water Sampled: 11/08/24 08:58:00
HM 1401

Metals

Lead	1.05	1	1.00	µg/L	11/15/24 10:44	11/18/24 17:47	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-23/Sink in Home EC. Room Lims Reference ID: AC36960-23 Matrix: Drinking Water Sampled: 11/08/24 08:58:00
HM 1401

Metals

Lead	ND	1	1.00	µg/L	11/15/24 10:44	11/18/24 17:49	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-24/Sink in Home EC. Room Lims Reference ID: AC36960-24 Matrix: Drinking Water Sampled: 11/08/24 08:58:00
HM 1401

Metals

Lead	ND	1	1.00	µg/L	11/15/24 10:44	11/18/24 17:51	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-25/Sink in Home EC. Room Lims Reference ID: AC36960-25 Matrix: Drinking Water Sampled: 11/08/24 09:00:00
HM 1401

Metals

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:856-786-5974
EMSL-CIN-01

EMSL Order ID: 012436960
LIMS Reference ID: AC36960
EMSL Customer ID: EDI50

Attention: Tim Gromen
Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name: East Brunswick
BOE-Hammar skjold/PR-220424-1198

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 11/12/2024 09:00
Reported: 11/26/2024 16:22

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	-----------------------	-----------------------	---------------------	----------------------------

Sample: 47-HAM-1108-25/Sink in Home EC. Room Lims Reference ID: AC36960-25 Matrix: Drinking Water Sampled: 11/08/24 09:00:00
HM 1401 (Continued)

Metals (Continued)

Lead	ND	1	1.00	µg/L	11/15/24 10:44	11/18/24 17:53	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-26/Sink in Home EC. Room Lims Reference ID: AC36960-26 Matrix: Drinking Water Sampled: 11/08/24 09:01:00
HM 1401

Metals

Lead	ND	1	1.00	µg/L	11/15/24 10:44	11/18/24 18:00	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-27/Sink in Home EC. Room Lims Reference ID: AC36960-27 Matrix: Drinking Water Sampled: 11/08/24 09:02:00
HM 1401

Metals

Lead	ND	1	1.00	µg/L	11/15/24 10:44	11/18/24 18:02	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-28/Sink in Home EC. Room Lims Reference ID: AC36960-28 Matrix: Drinking Water Sampled: 11/08/24 09:02:00
HM 1401

Metals

Lead	ND	1	1.00	µg/L	11/15/24 10:44	11/18/24 18:04	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-29/Water Fountain in Hall Lims Reference ID: AC36960-29 Matrix: Drinking Water Sampled: 11/08/24 09:07:00
across from HM 1507

Metals

Lead	ND	1	1.00	µg/L	11/15/24 10:44	11/18/24 18:06	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-30/Water Fountain in Hall Lims Reference ID: AC36960-30 Matrix: Drinking Water Sampled: 11/08/24 09:07:00
across from HM 1507

Metals

Lead	ND	1	1.00	µg/L	11/15/24 10:44	11/18/24 18:09	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-31/Water Fountain in Hall Lims Reference ID: AC36960-31 Matrix: Drinking Water Sampled: 11/08/24 09:10:00
across from HM 1524

Metals

Lead	ND	1	1.00	µg/L	11/15/24 10:44	11/18/24 18:11	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-32/Water Fountain in Hall Lims Reference ID: AC36960-32 Matrix: Drinking Water Sampled: 11/08/24 09:10:00
across from HM 1524

Metals

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012436960
LIMS Reference ID: AC36960
EMSL Customer ID: EDI50

Attention: Tim Gromen
Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name: East Brunswick
BOE-Hammaraskjold/PR-220424-1198

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 11/12/2024 09:00
Reported: 11/26/2024 16:22

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: 47-HAM-1108-32/Water Fountain in Hall across from HM 1524 (Continued) Lims Reference ID: AC36960-32 Matrix: Drinking Water Sampled: 11/08/24 09:10:00

Metals (Continued)

Lead	ND	1	1.00	µg/L	11/15/24 10:44	11/18/24 18:17	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-33/Sink in Guidance Office Area HM 1013 Lims Reference ID: AC36960-33 Matrix: Drinking Water Sampled: 11/08/24 09:13:00

Metals

Lead	1.27	1	1.00	µg/L	11/15/24 10:44	11/18/24 18:20	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-34/Sink in Guidance Office Area HM 1013 Lims Reference ID: AC36960-34 Matrix: Drinking Water Sampled: 11/08/24 09:14:00

Metals

Lead	2.37	1	1.00	µg/L	11/15/24 10:44	11/18/24 18:26	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-35/Sink in Room HM 1402 Lims Reference ID: AC36960-35 Matrix: Drinking Water Sampled: 11/08/24 09:18:00

Metals

Lead	ND	1	1.00	µg/L	11/15/24 10:44	11/18/24 18:28	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-36/Sink in Faculty Prep Room HM 1031 Lims Reference ID: AC36960-36 Matrix: Drinking Water Sampled: 11/08/24 09:22:00

Metals

Lead	ND	1	1.00	µg/L	11/15/24 10:44	11/18/24 18:31	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-37/WF Cafe (Right) Lims Reference ID: AC36960-37 Matrix: Drinking Water Sampled: 11/08/24 09:24:00

Metals

Lead	ND	1	1.00	µg/L	11/15/24 10:44	11/18/24 18:33	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-38/WF Cafe (Left) Lims Reference ID: AC36960-38 Matrix: Drinking Water Sampled: 11/08/24 09:24:00

Metals

Lead	ND	1	1.00	µg/L	11/15/24 10:44	11/18/24 18:35	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-39/Chiller Bottle Filler in Cafeteria (Filler) Lims Reference ID: AC36960-39 Matrix: Drinking Water Sampled: 11/08/24 09:24:00

Metals

Lead	ND	1	1.00	µg/L	11/15/24 10:44	11/18/24 18:37	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 47-HAM-1108-40/Sink in Kitchen Lims Reference ID: AC36960-40 Matrix: Drinking Water Sampled: 11/08/24 09:28:00

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:856-786-5974
EMSL-CIN-01

EMSL Order ID: 012436960
LIMS Reference ID: AC36960
EMSL Customer ID: EDI50

Attention: Tim Gromen
Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name: East Brunswick
BOE-Hammarskjold/PR-220424-1198

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 11/12/2024 09:00
Reported: 11/26/2024 16:22

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 47-HAM-1108-40/Sink in Kitchen (Continued) Lims Reference ID: AC36960-40 Matrix: Drinking Water Sampled: 11/08/24 09:28:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 10:44	11/18/24 18:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-41/Sink in Kitchen Lims Reference ID: AC36960-41 Matrix: Drinking Water Sampled: 11/08/24 09:30:00									
Metals									
Lead	1.88		1	1.00	µg/L	11/18/24 09:34	11/19/24 15:21	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: 47-HAM-1108-42/Hose in Kitchen Lims Reference ID: AC36960-42 Matrix: Drinking Water Sampled: 11/08/24 09:34:00									
Metals									
Lead	15.5		1	1.00	µg/L	11/18/24 10:20	11/19/24 22:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-43/Sink in Kitchen Lims Reference ID: AC36960-43 Matrix: Drinking Water Sampled: 11/08/24 09:39:00									
Metals									
Lead	38.8		1	1.00	µg/L	11/18/24 09:34	11/19/24 15:28	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: 47-HAM-1108-44/Sink Exam Room 1003C in Nurse Lims Reference ID: AC36960-44 Matrix: Drinking Water Sampled: 11/08/24 09:42:00									
Metals									
Lead	5.55		1	1.00	µg/L	11/18/24 09:34	11/19/24 15:30	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: 47-HAM-1108-45/Sink in Nurses Office (Exam Room) Lims Reference ID: AC36960-45 Matrix: Drinking Water Sampled: 11/08/24 09:42:00									
Metals									
Lead	1.42		1	1.00	µg/L	11/18/24 10:20	11/19/24 22:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-46/Sink in Bathroom 1003B in Nurse Lims Reference ID: AC36960-46 Matrix: Drinking Water Sampled: 11/08/24 09:44:00									
Metals									
Lead	ND		1	1.00	µg/L	11/18/24 10:20	11/19/24 22:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-47/Sink in Nurse Room 1003A Lims Reference ID: AC36960-47 Matrix: Drinking Water Sampled: 11/08/24 09:45:00									
Metals									
Lead	ND		1	1.00	µg/L	11/18/24 10:20	11/19/24 22:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-48/Sink in Main Office Area Lims Reference ID: AC36960-48 Matrix: Drinking Water Sampled: 11/08/24 09:49:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:856-786-5974
EMSL-CIN-01

EMSL Order ID: 012436960
LIMS Reference ID: AC36960
EMSL Customer ID: EDI50

Attention: Tim Gromen
Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name: East Brunswick
BOE-Hammarskjold/PR-220424-1198

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 11/12/2024 09:00
Reported: 11/26/2024 16:22

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 47-HAM-1108-48/Sink in Main Office Area (Continued) Lims Reference ID: AC36960-48 Matrix: Drinking Water Sampled: 11/08/24 09:49:00									
Metals									
Lead	ND		1	1.00	µg/L	11/18/24 10:16	11/18/24 20:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-49/Water Fountain in Hall Lims Reference ID: AC36960-49 Matrix: Drinking Water Sampled: 11/08/24 09:54:00									
Metals									
Lead	ND		1	1.00	µg/L	11/18/24 10:20	11/19/24 22:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-50/Water Fountain in Hall Lims Reference ID: AC36960-50 Matrix: Drinking Water Sampled: 11/08/24 09:56:00									
Metals									
Lead	ND		1	1.00	µg/L	11/18/24 10:20	11/19/24 22:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-51/Water Fountain in Hall Lims Reference ID: AC36960-51 Matrix: Drinking Water Sampled: 11/08/24 09:57:00									
Metals									
Lead	ND		1	1.00	µg/L	11/18/24 10:20	11/19/24 22:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-HAM-1108-52/Deionized Blank Lims Reference ID: AC36960-52 Matrix: Drinking Water Sampled: 11/08/24 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	11/18/24 10:20	11/19/24 23:00	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:856-786-5974
EMSL-CIN-01

EMSL Order ID: 012436751
LIMS Reference ID: AC36751
EMSL Customer ID: EDI50

Attention: Tim Gromen
Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name: East Brunswick BOE Irwin Elementary School -
PR-220424-1198

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 11/12/2024 09:00
Reported: 11/26/2024 16:18

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 47-IR-1108-01/Bathroom Sink in Nurse Lims Reference ID: AC36751-01 Matrix: Drinking Water Sampled: 11/08/24 10:28:00									
Metals									
Lead	4.52		1	1.00	µg/L	11/15/24 09:28	11/18/24 12:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-IR-1108-02/Sink in Room IR 1105 Lims Reference ID: AC36751-02 Matrix: Drinking Water Sampled: 11/08/24 10:30:00									
Metals									
Lead	1.21		1	1.00	µg/L	11/15/24 09:28	11/18/24 12:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-IR-1108-03/Sink in Faculty Lounge Lims Reference ID: AC36751-03 Matrix: Drinking Water Sampled: 11/08/24 10:38:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 09:28	11/18/24 12:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-IR-1108-04/WF Hall Lims Reference ID: AC36751-04 Matrix: Drinking Water Sampled: 11/08/24 10:39:00									
Metals									
Lead	1.46		1	1.00	µg/L	11/15/24 09:28	11/18/24 12:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-IR-1108-05/WF Hall Lims Reference ID: AC36751-05 Matrix: Drinking Water Sampled: 11/08/24 10:40:00									
Metals									
Lead	5.88		1	1.00	µg/L	11/15/24 09:28	11/18/24 12:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-IR-1108-06/WF Hall Lims Reference ID: AC36751-06 Matrix: Drinking Water Sampled: 11/08/24 10:41:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 09:28	11/18/24 12:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-IR-1108-07/Bottle Filler with WF-IR14 Lims Reference ID: AC36751-07 Matrix: Drinking Water Sampled: 11/08/24 10:41:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 09:28	11/18/24 12:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-IR-1108-08/Dishwasher Sink Right Lims Reference ID: AC36751-08 Matrix: Drinking Water Sampled: 11/08/24 10:45:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 09:28	11/18/24 12:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-IR-1108-09/Hose at Dishwasher Lims Reference ID: AC36751-09 Matrix: Drinking Water Sampled: 11/08/24 10:45:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 09:28	11/18/24 12:56	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012436751**LIMS Reference ID:** AC36751**EMSL Customer ID:** EDI50**Attention:** Tim Gromen

Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name:

East Brunswick BOE Irwin Elementary School -
PR-220424-1198

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

11/12/2024 09:00

Reported:

11/26/2024 16:18

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 47-IR-1108-10/Dishwasher Sink Left Lims Reference ID: AC36751-10 Matrix: Drinking Water Sampled: 11/08/24 10:46:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 09:28	11/18/24 12:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-IR-1108-11/Prep Sink in Kitchen Lims Reference ID: AC36751-11 Matrix: Drinking Water Sampled: 11/08/24 10:47:00									
Metals									
Lead	4.34		1	1.00	µg/L	11/15/24 09:28	11/18/24 13:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-IR-1108-12/WF in Hall Across from IR1309 Lims Reference ID: AC36751-12 Matrix: Drinking Water Sampled: 11/08/24 10:50:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 09:28	11/18/24 13:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-IR-1108-13/WF in Hall Lims Reference ID: AC36751-13 Matrix: Drinking Water Sampled: 11/08/24 10:51:00									
Metals									
Lead	1.99		1	1.00	µg/L	11/15/24 09:28	11/18/24 13:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-IR-1108-14/WF in Hall Lims Reference ID: AC36751-14 Matrix: Drinking Water Sampled: 11/08/24 10:52:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 09:28	11/18/24 13:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-IR-1108-15/WF in Hall Lims Reference ID: AC36751-15 Matrix: Drinking Water Sampled: 11/08/24 10:52:00									
Metals									
Lead	ND		1	1.00	µg/L	11/15/24 09:28	11/18/24 13:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 47-IR-1108-16/Blank Lims Reference ID: AC36751-16 Matrix: Drinking Water Sampled: 11/08/24 10:28:00									
Metals									
Lead	ND		1	1.00	µg/L	11/14/24 14:09	11/14/24 23:58	JW1	EPA 200.8 (DA)/EPA 200.8