

Results Summary Lead in Drinking Water Samples 2024-2025 SY

School Name: East Brunswick School District - Chittick Elementary School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
WF-CH09	44-CH-1108-01	WF in Hall CH09; Bubbler	ND	No
BF-CH45	44-CH-1108-02	WF in Hall by CH09; Bottle Filler	ND	No
BB-CH10	44-CH-1108-03	Room 114; Bubbler	2.73	No
WF-CH14	44-CH-1108-04	WF in Hall by CH15	ND	No
WF-CH15	44-CH-1108-05	WF in Hall by CH15; Bubbler	ND	No
BF-CH46	44-CH-1108-06	WF in Hall by CH15; Bottle Filler	ND	No
S-CH16	44-CH-1108-07	Sink in Main Office area	1.57	No
S-CH17	44-CH-1108-08	Sink in Nurse	ND	No
S-CH18	44-CH-1108-09	Bathroom Sink in Nurse	6.68	No
S-CH19	44-CH-1108-10	Sink in Faculty Room	ND	No
S-CH01	44-CH-1108-11	Dishwasher Sink Right	ND	No
S-CH02	44-CH-1108-12	Hose at Dishwasher Sink	ND	No
S-CH03	44-CH-1108-13	Dishwasher Sink Left	ND	No
S-CH04	44-CH-1108-14	Prep Sink in Kitchen	ND	No
-	44-CH-1108-15	DI Blank	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012436746
LIMS Reference ID: AC36746
EMSL Customer ID: EDI50

Attention: Tim Gromen
Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name: East Brunswick BOE Chittick -
PR-220424-1198

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 11/12/2024 09:00
Reported: 11/26/2024 16:13

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 44-CH-1108-01/Water Fountain in Hall Lims Reference ID: AC36746-01 Matrix: Drinking Water Sampled: 11/08/24 11:28:00									
Metals									
Lead	ND		1	1.00	µg/L	11/14/24 16:08	11/19/24 20:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 44-CH-1108-02/Bottle Filler with WF-CH09 Lims Reference ID: AC36746-02 Matrix: Drinking Water Sampled: 11/08/24 11:29:00									
Metals									
Lead	ND		1	1.00	µg/L	11/14/24 16:08	11/19/24 20:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 44-CH-1108-03/Bubbler in Room 14 Lims Reference ID: AC36746-03 Matrix: Drinking Water Sampled: 11/08/24 11:33:00									
Metals									
Lead	2.73		1	1.00	µg/L	11/14/24 16:08	11/19/24 20:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 44-CH-1108-04/Water Fountain in Hall Lims Reference ID: AC36746-04 Matrix: Drinking Water Sampled: 11/08/24 11:35:00									
Metals									
Lead	ND		1	1.00	µg/L	11/14/24 16:08	11/20/24 08:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 44-CH-1108-05/Water Fountain in Hall Lims Reference ID: AC36746-05 Matrix: Drinking Water Sampled: 11/08/24 11:37:00									
Metals									
Lead	ND		1	1.00	µg/L	11/14/24 16:08	11/20/24 09:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 44-CH-1108-06/Bottle Filler with WF-CH15 Lims Reference ID: AC36746-06 Matrix: Drinking Water Sampled: 11/08/24 11:38:00									
Metals									
Lead	ND		1	1.00	µg/L	11/14/24 16:08	11/20/24 09:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 44-CH-1108-07/Sink in Main Office Area Lims Reference ID: AC36746-07 Matrix: Drinking Water Sampled: 11/08/24 11:39:00									
Metals									
Lead	1.57		1	1.00	µg/L	11/14/24 16:08	11/20/24 09:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 44-CH-1108-08/Sink in Nurse Lims Reference ID: AC36746-08 Matrix: Drinking Water Sampled: 11/08/24 11:41:00									
Metals									
Lead	ND		1	1.00	µg/L	11/14/24 16:08	11/20/24 09:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 44-CH-1108-09/Bathroom Sink in Nurse Lims Reference ID: AC36746-09 Matrix: Drinking Water Sampled: 11/08/24 11:41:00									
Metals									
Lead	6.68		1	1.00	µg/L	11/14/24 16:08	11/20/24 09:09	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:856-786-5974
EMSL-CIN-01

EMSL Order ID: 012436746
LIMS Reference ID: AC36746
EMSL Customer ID: EDI50

Attention: Tim Gromen
Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name: East Brunswick BOE Chittick -
PR-220424-1198

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 11/12/2024 09:00
Reported: 11/26/2024 16:13

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 44-CH-1108-10/Sink in Faculty Room Lims Reference ID: AC36746-10 Matrix: Drinking Water Sampled: 11/08/24 11:44:00									
Metals									
Lead	ND		1	1.00	µg/L	11/14/24 16:08	11/20/24 09:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 44-CH-1108-11/Dishwasher Sink Right Lims Reference ID: AC36746-11 Matrix: Drinking Water Sampled: 11/08/24 11:52:00									
Metals									
Lead	ND		1	1.00	µg/L	11/18/24 10:20	11/19/24 22:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 44-CH-1108-12/Hose at Dish Washer Lims Reference ID: AC36746-12 Matrix: Drinking Water Sampled: 11/08/24 11:53:00									
Metals									
Lead	ND		1	1.00	µg/L	11/18/24 10:20	11/19/24 22:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 44-CH-1108-13/Dishwasher Sink Left Lims Reference ID: AC36746-13 Matrix: Drinking Water Sampled: 11/08/24 11:56:00									
Metals									
Lead	ND		1	1.00	µg/L	11/18/24 10:20	11/19/24 22:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 44-CH-1108-14/Prep Sink in Kitchen Lims Reference ID: AC36746-14 Matrix: Drinking Water Sampled: 11/08/24 11:57:00									
Metals									
Lead	ND		1	1.00	µg/L	11/18/24 10:20	11/19/24 22:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 44-CH-1108-15/Blank Lims Reference ID: AC36746-15 Matrix: Drinking Water Sampled: 11/08/24 11:28:00									
Metals									
Lead	ND		1	1.00	µg/L	11/14/24 14:09	11/15/24 00:01	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:856-786-5974
EMSL-CIN-01

EMSL Order ID: 012436746**LIMS Reference ID:** AC36746**EMSL Customer ID:** EDI50**Attention:** Tim Gromen

Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name:

East Brunswick BOE Chittick -
PR-220424-1198

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

11/12/2024 09:00

Reported:

11/26/2024 16:13

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	68-00367	11/30/2025
NYSDOH	New York State Department of Health	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited	100194	01/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012436746**LIMS Reference ID:** AC36746**EMSL Customer ID:** EDI50**Attention:** Tim Gromen

Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name:

East Brunswick BOE Chittick -
PR-220424-1198

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

11/12/2024 09:00

Reported:

11/26/2024 16:13

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Results Summary Lead in Drinking Water Samples 2024-2025 SY

School Name: East Brunswick School District - Churchill J.H.S.

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S-51	58-CHR-1003-01	CH2011 A-C Faculty Dining Sink	1.74	No
S-56	58-CHR-1003-02	CH2011H Dishwasher Sink	ND	No
S-55	58-CHR-1003-03	CH2011H Dishwasher Sink	1.98	No
S-54	58-CHR-1003-04	CH2011H Dishwasher Sink	ND	No
S-59	58-CHR-1003-05	CH2011 Kitchen Prep Sink	ND	No
F-94	58-CHR-1003-06	CH2011 Kitchen Rice Filler [155]	39.5	Yes
S-60	58-CHR-1003-07	CH2011 Kitchen Sink	ND	No
S-58	58-CHR-1003-08	CH2011D Serving Area 6 Prep Sink	1.07	No
S-86	58-CHR-1003-09	CH2011 Kitchen Sink	1.32	No
S-63	58-CHR-1003-10	CH2011D Serving Area 4 Prep Sink	1.22	No
S-62	58-CHR-1003-11	CH2011D Serving Area 3 Prep Sink	1.42	No
S-80	58-CHR-1003-12	CH2101C Faculty Workroom Sink	ND	No
BF-96	58-CHR-1003-13	Hall across CH2106 Boiler Room/ Electrical Fire Panel WF/ Filler station (filler)	ND	No
S-80	58-CHR-1003-14	CH2208 Faculty Sink	ND	No
BF-95	58-CHR-1003-15	HALL next to CH1710 Boys Restroom WF/ Filler station (filler)	ND	No
IM-98	58-CHR-1003-16	CH1714 Athletic Trainer Ice Machine	ND	No
S-35	58-CHR-1003-17	CH1718 Health Services Sink	ND	No
S-36	58-CHR-1003-18	CH1718 B-C Exam Room/ Storage Sink	ND	No
BF-97	58-CHR-1003-19	Hall next to CH1301 WF/ Filler station (filler)	ND	No
S-98	58-CHR-1003-20	CH1302 SGI Sink	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)

Results Summary Lead in Drinking Water Samples 2024-2025 SY

School Name: East Brunswick School District - Churchill J.H.S.

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S-05	58-CHR-1003-21	CH1502 Faculty Restrooms/ Water Main Sink	ND	No
S-18	58-CHR-1003-22	CH1422 Classroom Sink	ND	No
S-19	58-CHR-1003-23	CH1424 Classroom Sink	ND	No
S-20	58-CHR-1003-24	CH1424 Classroom Sink	ND	No
S-21	58-CHR-1003-25	CH1424 Classroom Sink	ND	No
S-22	58-CHR-1003-26	CH1424 Classroom Sink	ND	No
S-23	58-CHR-1003-27	CH1424 Classroom Sink	ND	No
S-24	58-CHR-1003-28	CH1424 Classroom Sink	ND	No
S-30	58-CHR-1003-29	CH1009 Main Office Sink	ND	No
BLANK	58-CHR-1003-30	Deionized Blank	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012433453
LIMS Reference ID: AC33453
EMSL Customer ID: EDI50

Attention: Jay Murray
Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
jm@editesting.com

Project Name: East Brunswick BOE - Churchill Junior HS

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 10/08/2024 10:00
Reported: 10/23/2024 14:53

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 58-CHR-1003-01/CH2011 A-C Faculty Dining Sink Lims Reference ID: AC33453-01 Matrix: Drinking Water Sampled: 10/03/24 08:33:00									
Metals									
Lead	1.74		1	1.00	µg/L	10/18/24 09:37	10/18/24 18:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 58-CHR-1003-02/CH2011H Dishwasher Sink Lims Reference ID: AC33453-02 Matrix: Drinking Water Sampled: 10/03/24 08:35:00									
Metals									
Lead	ND		1	1.00	µg/L	10/18/24 09:37	10/18/24 18:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 58-CHR-1003-03/CH2011H Dishwasher Sink Lims Reference ID: AC33453-03 Matrix: Drinking Water Sampled: 10/03/24 08:36:00									
Metals									
Lead	1.98		1	1.00	µg/L	10/18/24 09:37	10/18/24 18:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 58-CHR-1003-04/CH2011H Dishwasher Sink Lims Reference ID: AC33453-04 Matrix: Drinking Water Sampled: 10/03/24 08:36:00									
Metals									
Lead	ND		1	1.00	µg/L	10/18/24 09:37	10/18/24 18:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 58-CHR-1003-05/CH2011 Kitchen Prep Sink Lims Reference ID: AC33453-05 Matrix: Drinking Water Sampled: 10/03/24 08:40:00									
Metals									
Lead	ND		1	1.00	µg/L	10/18/24 09:37	10/18/24 18:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 58-CHR-1003-06/CH2011 Kitchen Rice Filler [155] Lims Reference ID: AC33453-06 Matrix: Drinking Water Sampled: 10/03/24 08:41:00									
Metals									
Lead	39.5		1	1.00	µg/L	10/18/24 09:37	10/18/24 18:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 58-CHR-1003-07/CH2011 Kitchen Sink Lims Reference ID: AC33453-07 Matrix: Drinking Water Sampled: 10/03/24 08:47:00									
Metals									
Lead	ND		1	1.00	µg/L	10/18/24 09:37	10/18/24 18:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 58-CHR-1003-08/CH2011D Serving Area 6 Prep Sink Lims Reference ID: AC33453-08 Matrix: Drinking Water Sampled: 10/03/24 08:48:00									
Metals									
Lead	1.07		1	1.00	µg/L	10/18/24 09:37	10/18/24 18:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 58-CHR-1003-09/CH2011 Kitchen Sink Lims Reference ID: AC33453-09 Matrix: Drinking Water Sampled: 10/03/24 08:49:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012433453
LIMS Reference ID: AC33453
EMSL Customer ID: EDI50

Attention: Jay Murray
Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
jm@editesting.com

Project Name: East Brunswick BOE - Churchill Junior HS

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 10/08/2024 10:00
Reported: 10/23/2024 14:53

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: 58-CHR-1003-09/CH2011 Kitchen Sink (Continued) Lims Reference ID: AC33453-09 Matrix: Drinking Water Sampled: 10/03/24 08:49:00

Metals (Continued)

Lead	1.32	1	1.00	µg/L	10/18/24 09:37	10/18/24 19:01	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 58-CHR-1003-10/CH2011D Serving Area 4 Prep Sink Lims Reference ID: AC33453-10 Matrix: Drinking Water Sampled: 10/03/24 08:54:00

Metals

Lead	1.22	1	1.00	µg/L	10/18/24 09:37	10/18/24 19:03	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 58-CHR-1003-11/CH2011D Serving Area 3 Prep Sink Lims Reference ID: AC33453-11 Matrix: Drinking Water Sampled: 10/03/24 08:56:00

Metals

Lead	1.42	1	1.00	µg/L	10/18/24 09:37	10/18/24 19:05	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 58-CHR-1003-12/CH2101C Faculty Workroom Sink Lims Reference ID: AC33453-12 Matrix: Drinking Water Sampled: 10/03/24 09:01:00

Metals

Lead	ND	1	1.00	µg/L	10/18/24 09:37	10/18/24 19:11	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 58-CHR-1003-13/HALL Across CH2106 Boiler Room / Electrical Fire Panel WF / Filler Station (Filler) Lims Reference ID: AC33453-13 Matrix: Drinking Water Sampled: 10/03/24 09:03:00

Metals

Lead	ND	1	1.00	µg/L	10/18/24 09:37	10/18/24 19:13	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 58-CHR-1003-14/CH2208 Faculty Sink Lims Reference ID: AC33453-14 Matrix: Drinking Water Sampled: 10/03/24 09:06:00

Metals

Lead	ND	1	1.00	µg/L	10/18/24 09:37	10/18/24 19:19	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 58-CHR-1003-15/HALL Next to CH1710 Boys Restroom WF / Filler Station (Filler) Lims Reference ID: AC33453-15 Matrix: Drinking Water Sampled: 10/03/24 09:14:00

Metals

Lead	ND	1	1.00	µg/L	10/18/24 09:37	10/18/24 19:21	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 58-CHR-1003-16/CH1714 Athletic Trainer Ice Machine Lims Reference ID: AC33453-16 Matrix: Drinking Water Sampled: 10/03/24 09:20:00

Metals

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012433453
LIMS Reference ID: AC33453
EMSL Customer ID: EDI50

Attention: Jay Murray
Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
jm@editesting.com

Project Name: East Brunswick BOE - Churchill Junior HS

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 10/08/2024 10:00
Reported: 10/23/2024 14:53

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: 58-CHR-1003-16/CH1714 Athletic Trainer Ice Machine (Continued) Lims Reference ID: AC33453-16 Matrix: Drinking Water Sampled: 10/03/24 09:20:00

Metals (Continued)

Lead	ND	1	1.00	µg/L	10/18/24 09:37	10/18/24 19:22	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 58-CHR-1003-17/CH1718 Health Services Sink Lims Reference ID: AC33453-17 Matrix: Drinking Water Sampled: 10/03/24 09:22:00

Metals

Lead	ND	1	1.00	µg/L	10/18/24 09:37	10/18/24 19:24	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 58-CHR-1003-18/CH1718 B-C Exam Room / Storage Sink Lims Reference ID: AC33453-18 Matrix: Drinking Water Sampled: 10/03/24 09:23:00

Metals

Lead	ND	1	1.00	µg/L	10/18/24 09:37	10/18/24 19:26	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 58-CHR-1003-19/HALL Next to CH1301 WF / Filler Station (Filler) Lims Reference ID: AC33453-19 Matrix: Drinking Water Sampled: 10/03/24 09:27:00

Metals

Lead	ND	1	1.00	µg/L	10/18/24 09:37	10/18/24 19:28	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 58-CHR-1003-20/CH1302 SGI Sink Lims Reference ID: AC33453-20 Matrix: Drinking Water Sampled: 10/03/24 09:29:00

Metals

Lead	ND	1	1.00	µg/L	10/18/24 09:37	10/18/24 19:30	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 58-CHR-1003-21/C1502 Faculty Restrooms / Water Main Sink Lims Reference ID: AC33453-21 Matrix: Drinking Water Sampled: 10/03/24 09:31:00

Metals

Lead	ND	1	1.00	µg/L	10/18/24 09:34	10/18/24 15:04	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 58-CHR-1003-22/CH1422 Classroom Sink Lims Reference ID: AC33453-22 Matrix: Drinking Water Sampled: 10/03/24 09:34:00

Metals

Lead	ND	1	1.00	µg/L	10/18/24 09:34	10/18/24 15:10	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 58-CHR-1003-23/CH1424 Classroom Sink Lims Reference ID: AC33453-23 Matrix: Drinking Water Sampled: 10/03/24 09:38:00

Metals

Lead	ND	1	1.00	µg/L	10/18/24 09:34	10/18/24 15:12	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 58-CHR-1003-24/CH1424 Classroom Sink Lims Reference ID: AC33453-24 Matrix: Drinking Water Sampled: 10/03/24 09:39:00

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012433453
LIMS Reference ID: AC33453
EMSL Customer ID: EDI50

Attention: Jay Murray
Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
jm@editesting.com

Project Name: East Brunswick BOE - Churchill Junior HS

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 10/08/2024 10:00
Reported: 10/23/2024 14:53

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 58-CHR-1003-24/CH1424 Classroom Sink (Continued) Lims Reference ID: AC33453-24 Matrix: Drinking Water Sampled: 10/03/24 09:39:00									
Metals									
Lead	ND		1	1.00	µg/L	10/18/24 09:34	10/18/24 15:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 58-CHR-1003-25/CH1424 Classroom Sink Lims Reference ID: AC33453-25 Matrix: Drinking Water Sampled: 10/03/24 09:40:00									
Metals									
Lead	ND		1	1.00	µg/L	10/18/24 09:34	10/18/24 15:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 58-CHR-1003-26/CH1424 Classroom Sink Lims Reference ID: AC33453-26 Matrix: Drinking Water Sampled: 10/03/24 09:40:00									
Metals									
Lead	ND		1	1.00	µg/L	10/18/24 09:34	10/18/24 15:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 58-CHR-1003-27/CH1424 Classroom Sink Lims Reference ID: AC33453-27 Matrix: Drinking Water Sampled: 10/03/24 09:41:00									
Metals									
Lead	ND		1	1.00	µg/L	10/18/24 09:34	10/18/24 15:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 58-CHR-1003-28/CH1424 Classroom Sink Lims Reference ID: AC33453-28 Matrix: Drinking Water Sampled: 10/03/24 09:41:00									
Metals									
Lead	ND		1	1.00	µg/L	10/18/24 09:34	10/18/24 15:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 58-CHR-1003-29/CH1009 Main Office Sink Lims Reference ID: AC33453-29 Matrix: Drinking Water Sampled: 10/03/24 09:44:00									
Metals									
Lead	ND		1	1.00	µg/L	10/18/24 09:34	10/18/24 15:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 58-CHR-1003-30/Deionized Blank Lims Reference ID: AC33453-30 Matrix: Drinking Water Sampled: 10/03/24 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	10/21/24 10:14	10/22/24 16:04	PL	EPA 200.8 (DA)/EPA 200.8