

Results Summary Lead in Drinking Water Samples 2024-2025 SY

School Name: East Brunswick School District - Administration Building

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
3S	13- AD-041425-01	Board Meeting Room; Kitchenette; sink	2.06	No
1BF	13- AD-041425-02	Bottle Fill Station in hallway; bubbler	ND	No
2BB	13- AD-041425-03	Bottle Fill Station in hallway; filler	ND	No
4S	13- AD-041425-04	Staff Break Room; sink	ND	No
5S	13- AD-041425-05	Registration Suite (Room 104); Kitchenette; sink	8.21	No
QA BLANK	13- AD-041425-06	QA Blank	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517044**LIMS Reference ID:** AD17044**EMSL Customer ID:** EDI50

Attention: Tim Gromen
Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name: East Brunswick BOE - Administration Building /
PR-220424-1198

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/15/2025 09:00
Reported: 04/29/2025 16:34

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 13-AD-041425-01/Board Meeting Room Kitchenette Sink Lims Reference ID: AD17044-01 Matrix: Drinking Water Sampled: 04/14/25 07:32:00									
Metals									
Lead	2.06		1	1.00	µg/L	04/17/25 12:08	04/17/25 19:42	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 13-AD-041425-02/Bottle Fill Station in Hallway Bubbler Lims Reference ID: AD17044-02 Matrix: Drinking Water Sampled: 04/14/25 07:34:00									
Metals									
Lead	ND		1	1.00	µg/L	04/17/25 12:08	04/17/25 19:50	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 13-AD-041425-03/Bottle Fill Station in Hallway Filler Lims Reference ID: AD17044-03 Matrix: Drinking Water Sampled: 04/14/25 07:34:00									
Metals									
Lead	ND		1	1.00	µg/L	04/17/25 12:08	04/17/25 19:53	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 13-AD-041425-04/Staff Break Room Sink Lims Reference ID: AD17044-04 Matrix: Drinking Water Sampled: 04/14/25 07:36:00									
Metals									
Lead	ND		1	1.00	µg/L	04/17/25 12:08	04/17/25 19:56	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 13-AD-041425-05/Registration Suite Room 104 Kitchenette Sink Lims Reference ID: AD17044-05 Matrix: Drinking Water Sampled: 04/14/25 07:40:00									
Metals									
Lead	8.21		1	1.00	µg/L	04/17/25 12:08	04/17/25 19:59	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: 13-AD-041425-06/QA Blank Lims Reference ID: AD17044-06 Matrix: Drinking Water Sampled: 04/14/25 07:32:00									
Metals									
Lead	ND		1	1.00	µg/L	04/17/25 11:53	04/17/25 18:46	JW1	EPA 200.8 (DA)/EPA 200.8