

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0001-1	Custodial Office	SS	N/A		6/18/2025				Sign
0002-1	Loading Dock	SP	N/A		6/18/2025				Sign
0003-1	Ladies Bathroom-Basement @A	SK	N/A		6/18/2025				Sign
0003-2	Ladies Bathroom-Basement @B	SK	N/A		6/18/2025				Sign
0004-1	Men's Bathroom-Basement @ A	SK	N/A		6/18/2025				Sign
0004-2	Men's Bathroom-Basement @ B	SK	N/A		6/18/2025				Sign
1001-1	Kitchen 1 Island	SK	App	5.0	6/18/2025				-
1001-2	Kitchen 1 3-Bay @ A	SK	App	2.0	6/18/2025				-
1001-3	Kitchen 1 3-Bay @ B	SK	App	5.0	6/18/2025				-
1001-4	Kitchen Handwash @ A	SK	N/A		6/18/2025				Sign
1001-5	Kitchen Handwash @ B	SK	N/A		6/18/2025				Sign
1001-6	Kitchen Handwash @ C	SK	N/A		6/18/2025				Sign
1001-7	Kitchen closet	SS	N/A		6/18/2025				Sign
1002-1	Cafeteria (left)	WF	App		6/18/2025				Non-functional, sampling required before returning to service
1002-2	Cafeteria (right)	WF	App		6/18/2025				Non-functional, sampling required before returning to service
1003-1	Hall by 1107	WF	App	8.0	6/18/2025				Removed from service, pending fixture replacement
1004-1	Girl's Bathroom by 1116 @ A	SK	N/A		6/18/2025				Sign
1004-2	Girl's Bathroom by 1116 @ B	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1004-3	Girl's Bathroom by 1116 @ C	SK	N/A		6/18/2025				Sign
1004-4	Girl's Bathroom by 1116 @ D	SK	N/A		6/18/2025				Sign
1004-5	Girl's Bathroom by 1116 @ E	SK	N/A		6/18/2025				Sign
1005-1	Hall by 1116	WF	N/A		6/18/2025				Non-functional, sampling required before returning to service
1006-1	Boy's Bathroom by 1116 @ A	SK	N/A		6/18/2025				Sign
1006-2	Boy's Bathroom by 1116 @ B	SK	N/A		6/18/2025				Sign
1006-3	Boy's Bathroom by 1116 @ C	SK	N/A		6/18/2025				Sign
1006-5	Boy's Bathroom by 1116 @ E	SK	N/A		6/18/2025				Sign
1007-1	Custodial Closet by 1116	SS	N/A		6/18/2025				Sign
1008-1	Staff Bathroom by 1502	SK	N/A		6/18/2025				Sign
1009-1	Room 1400 Teacher's Station	SK	N/A		6/18/2025				Sign
1009-2	Room 1400 Counter @ A	SK	N/A		6/18/2025				Sign
1010-1	Room 1400 Prep @ A	SK	App		6/18/2025				Sign
1010-2	Room 1400 Prep @ B	SK	App		6/18/2025				Sign
1011-1	Room 1404 Teacher's Station	SK	N/A		6/18/2025				Sign
1011-2	Room 1404 Counter @ A	SK	N/A		6/18/2025				Sign
1011-3	Room 1404 Counter @ B	SK	N/A		6/18/2025				Sign
1012-1	Girl's Bathroom 1405 @ A	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1012-2	Girl's Bathroom 1405 @ B	SK	N/A		6/18/2025				Sign
1012-3	Girl's Bathroom 1405 @ C	SK	N/A		6/18/2025				Sign
1012-4	Girl's Bathroom 1405 @ D	SK	N/A		6/18/2025				Sign
1013-1	Hall by 1405	WF	App		6/18/2025				Non-functional, sampling required before returning to service
1014-1	Men's Bathroom by 1407	SK	N/A		6/18/2025				Sign
1015-1	Women's Bathroom by 1407	SK	N/A		6/18/2025				Sign
1016-1	Kitchen 3 3-Bay @ A	SK	App	2.0	6/18/2025				-
1016-2	Kitchen 3 3-Bay @ B	SK	App	2.0	6/18/2025				-
1016-3	Kitchen 3 Island by 3 Bay	SK	App	2.0	6/18/2025				-
1016-4	Kitchen 3 Island by Clock	SK	App	4.0	6/18/2025				-
1017-1	Hall by 1305	WF	App	<1.0	6/18/2025				-
1017-2	Hall by 1305	BF	App	<1.0	6/18/2025				-
1018-1	Boy's Bathroom 1306 @ A	SK	N/A		6/18/2025				Sign
1018-2	Boy's Bathroom 1306 @ B	SK	N/A		6/18/2025				Sign
1018-3	Boy's Bathroom 1306 @ C	SK	N/A		6/18/2025				Sign
1018-4	Boy's Bathroom 1306 @ D	SK	N/A		6/18/2025				Sign
1019-1	Staff Bathroom by 1306	SK	N/A		6/18/2025				Sign
1020-1	Boy's Bathroom by 1148 Birdbath	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1020-2	Girl's Bathroom by 1148 Birdbath	WF	N/A		6/18/2025				Sign
1021-1	Hall by 1148	WF	App		6/18/2025				Non-functional, sampling required before returning to service
1022-1	Hall by Auditorium	WF	App		6/18/2025				Non-functional, sampling required before returning to service
1023-1	Art Room 1701 @ A	SK	N/A		6/18/2025				Sign
1023-2	Art Room 1701 @ B	SK	N/A		6/18/2025				Sign
1023-3	Art Room 1701 @ C	SK	N/A		6/18/2025				Sign
1024-1	Art Room 1705 @ A	SK	N/A		6/18/2025				Sign
1024-2	Art Room 1705 @ B	SK	N/A		6/18/2025				Sign
1024-3	Art Room 1705 @ C	SK	N/A		6/18/2025				Sign
1025-1	Hall by Auditorium Concession	BF	App	<1.0	6/18/2025				-
1025-2	Hall by Auditorium Concession	WF	App	<1.0	6/18/2025				-
1026-1	Art Room 1707 @ A	SK	N/A		6/18/2025				Sign
1026-2	Art Room 1707 @ B	SK	N/A		6/18/2025				Sign
1026-3	Art Room 1707 @ C	SK	N/A		6/18/2025				Sign
1027-1	Family Services	SK	N/A		6/18/2025				Sign
1028-1	Room 1711 Station 1	SK	App	2.0	6/18/2025				-
1028-2	Room 1711 Station 1	SPY	App	<1.0	6/18/2025				-
1028-3	Room 1711 Station 2	SK	App	<1.0	6/18/2025				-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1028-4	Room 1711 Station 2	SPY	App	<1.0	6/18/2025				-
1028-5	Room 1711 Station 3	SK	App	2.0	6/18/2025				-
1028-6	Room 1711 Station 3	SPY	App	<1.0	6/18/2025				-
1028-7	Room 1711 Station 4	SK	App	14.0	6/18/2025				Removed from service, pending remediation
1028-8	Room 1711 Station 4	SPY	App	12.0	6/18/2025				Removed from service, pending remediation
1028-9	Room 1711 Station 5	SK	App	1.0	6/18/2025				-
1028-10	Room 1711 Station 5	SPY	App	<1.0	6/18/2025				-
1029-1	Room 1713 Teacher's Station	SK	App	<1.0	6/18/2025				-
1029-2	Room 1713 Counter @ A	SK	App	3.0	6/18/2025				-
1029-3	Room 1713 Counter @ B	SK	App	2.0	6/18/2025				-
1029-4	Room 1713 Counter @ C	SK	App	1.0	6/18/2025				-
1029-5	Room 1713 Counter @ D	SK	App	3.0	6/18/2025				-
1030-1	Room 1715 Counter @ A	SK	App		6/18/2025				Sign
1030-2	Room 1715 Counter @ B	SK	App		6/18/2025				Sign
1030-3	Room 1715 Counter @ C	SK	App		6/18/2025				Sign
1031-1	Art Room 1719 @ A	SK	N/A		6/18/2025				Sign
1031-2	Art Room 1719 @ B	SK	N/A		6/18/2025				Sign
1031-3	Art Room 1719 @ C	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1032-1	Art Room 1721 @ A	SK	N/A		6/18/2025				Sign
1032-2	Art Room 1721 @ B	SK	N/A		6/18/2025				Sign
1032-3	Art Room 1721 @ C	SK	N/A		6/18/2025				Sign
1033-1	Shop Room 1801	SK	N/A		6/18/2025				Sign
1034-1	Shop Room 1803	WF	App	23.0	6/18/2025				Removed from service, pending fixture replacement
1035-1	Boy's Bathroom by 1813 @ A	SK	N/A		6/18/2025				Sign
1035-2	Boy's Bathroom by 1813 @ B	SK	N/A		6/18/2025				Sign
1036-1	Girl's Bathroom by 1813 @ A	SK	N/A		6/18/2025				Sign
1036-2	Girl's Bathroom by 1813 @ B	SK	N/A		6/18/2025				Sign
1037-1	Hall by 1823	WF	App		6/18/2025				Non-functional, sampling required before returning to service
1038-1	Room 1815	SK	N/A		6/18/2025				Sign
1039-1	Room 1816	SK	N/A		6/18/2025				Sign
1040-1	Room 1814	SK	N/A		6/18/2025				Sign
1041-1	Room 1812	SK	N/A		6/18/2025				Sign
1042-1	Men's Bathroom 1810	SK	N/A		6/18/2025				Sign
1043-1	Women's Bathroom 1808	SK	N/A		6/18/2025				Sign
1044-1	Dark Room 1804 @ A	SK	N/A		6/18/2025				Sign
1044-2	Dark Room 1804 @ B	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1045-1	Custodial closet 1727	SS	N/A		6/18/2025				Sign
1046-1	Unisex Bathroom 1733	SK	N/A		6/18/2025				Sign
1047-1	Unisex Bathroom 1735	SK	N/A		6/18/2025				Sign
1048-1	Main Office kitchenette	SK	App	1.0	6/18/2025				-
1048-2	Main Office Bathroom	SK	N/A		6/18/2025				Sign
1049-1	Nurse's Office	SK	N/A		6/18/2025				Sign
1049-2	Nurse's Office Exam Room Left	SK	N/A		6/18/2025				Sign
1049-3	Nurse's Office Exam Room Right	SK	N/A		6/18/2025				Sign
1049-4	Nurse's Office Bathroom 1	SK	N/A		6/18/2025				Sign
1049-5	Nurse's Office Bathroom 2	SK	N/A		6/18/2025				Sign
1050-1	Physical Education Offices Kitchenette	SK	App	2.0	6/18/2025				-
1050-2	Physical Education Offices Kitchenette	SPY	App	<1.0	6/18/2025				-
1050-3	Men's Physical Education Office	SK	N/A		6/18/2025				Sign
1050-4	Women's Physical Education Office	SK	N/A		6/18/2025				Sign
1051-1	Boy's Bathroom 1604 Birdbath	SK	N/A		6/18/2025				Sign
1052-1	Hall by 1604	WF	App	<1.0	6/18/2025				-
1052-2	Hall by 1604	BF	App	<1.0	6/18/2025				-
1053-1	Hall by 1614	WF	App	22.0	6/18/2025				Removed from service, pending fixture replacement

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1055-1	Department of Physical Education Office Handwash	SK	App	5.0	6/18/2025				-
1056-1	Athletic Trainer	SK	App		6/18/2025				Sign
1056-2	Athletic Trainer	IM	App	<1.0	6/18/2025				-
1057-1	Sports Locker Room by Athletic Trainer	SK	N/A		6/18/2025				Sign
1058-1	Hall by 1628	WF	App	3.0	6/18/2025				-
1059-1	Room 1628 Left	SK	N/A		6/18/2025				Sign
1059-2	Room 1628 Right	SK	N/A		6/18/2025				Sign
1059-3	Room 1628 @ C	SK	N/A		6/18/2025				Sign
1060-1	Cardio Room Handwash	SK	N/A		6/18/2025				Sign
1061-1	Girl's Seasonal Locker Room @ A	SK	N/A		6/18/2025				Sign
1061-2	Girl's Seasonal Locker Room @ B	SK	N/A		6/18/2025				Sign
1062-1	Boy's Seasonal Locker Room @ A	SK	N/A		6/18/2025				Sign
1062-2	Boy's Seasonal Locker Room @ B	SK	N/A		6/18/2025				Sign
1063-1	Boy's Bathroom 1638 @ A	SK	N/A		6/18/2025				Sign
1063-2	Boy's Bathroom 1638 @ B	SK	N/A		6/18/2025				Sign
1064-1	Girl's Bathroom 1640 @ A	SK	N/A		6/18/2025				Sign
1064-2	Girl's Bathroom 1640 @ B	SK	N/A		6/18/2025				Sign
1065-1	Coach Sipp's Office	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1066-1	Hall by 1646 (left)	WF	App	1.0	6/18/2025				-
1066-2	Hall by 1646 (right)	WF	App	1.0	6/18/2025				-
1067-1	Girl's Locker Room @ A	SK	N/A		6/18/2025				Sign
1067-2	Girl's Locker Room @ B	SK	N/A		6/18/2025				Sign
1067-3	Girl's Locker Room @ C	SK	N/A		6/18/2025				Sign
1068-1	Boy's Locker Room @ A	SK	N/A		6/18/2025				Sign
1068-2	Boy's Locker Room @ B	SK	N/A		6/18/2025				Sign
1068-3	Boy's Locker Room @ C	SK	N/A		6/18/2025				Sign
1069-1	Storage Closet by Locker Rooms	SK	N/A		6/18/2025				Sign
1070-1	Custodial Closet 1642	SS	N/A		6/18/2025				Sign
1071-1	Boy's Senior Locker Room Office Bathroom	SK	N/A		6/18/2025				Sign
1071-2	Boy's Senior Locker Room Birdbath	SK	N/A		6/18/2025				Sign
1072-1	Boy's Junior Locker Room Birdbath	SK	N/A		6/18/2025				Sign
1073-1	Girl's Junior Locker Room Birdbath	SK	N/A		6/18/2025				Sign
1074-1	Custodial Closet 1615	SS	N/A		6/18/2025				Sign
1075-1	Girl's Senior Locker Room Office	SK	N/A		6/18/2025				Sign
1075-2	Girl's Senior Locker Room Birdbath	SK	N/A		6/18/2025				Sign
2001-1	Kitchen 2 3-Bay @ A	SK	App	3.0	6/18/2025				-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2001-2	Kitchen 2 3-Bay @ B	SK	App	4.0	6/18/2025				-
2001-3	Kitchen 2 Island	SK	App	4.0	6/18/2025				-
2001-4	Kitchen 2 Handwash @ A	SK	N/A		6/18/2025				Sign
2001-5	Kitchen 2 Handwash @ B	SK	N/A		6/18/2025				Sign
2002-1	2nd Floor Cafeteria (left)	WF	App		6/18/2025				Non-functional, sampling required before returning to service
2002-2	2nd Floor Cafeteria (right)	WF	App		6/18/2025				Non-functional, sampling required before returning to service
2003-1	Unisex Bathroom 2501	SK	N/A		6/18/2025				Sign
2004-1	Room 2402 Teacher's Station	SK	N/A		6/18/2025				Sign
2004-2	Room 2402 Counter @ A	SK	N/A		6/18/2025				Sign
2004-3	Room 2402 Counter @ B	SK	N/A		6/18/2025				Sign
2005-1	Room 2402 Prep @ A	SK	N/A		6/18/2025				Sign
2005-2	Room 2402 Prep @ B	SK	N/A		6/18/2025				Sign
2006-1	Room 2404 Teacher's Station	SK	N/A		6/18/2025				Sign
2006-2	Room 2404 Counter @ A	SK	N/A		6/18/2025				Sign
2006-3	Room 2404 Counter @ B	SK	N/A		6/18/2025				Sign
2007-1	Men's Bathroom 2318	SK	N/A		6/18/2025				Sign
2008-1	Women's Bathroom 2316	SK	N/A		6/18/2025				Sign
2009-1	Custodial Closet 2314	SS	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2010-1	Girl's Bathroom 2312 @ A	SK	N/A		6/18/2025				Sign
2010-2	Girl's Bathroom 2312 @ B	SK	N/A		6/18/2025				Sign
2010-3	Girl's Bathroom 2312 @ C	SK	N/A		6/18/2025				Sign
2011-1	Men's Bathroom 2310 @ A	SK	N/A		6/18/2025				Sign
2011-2	Men's Bathroom 2310 @ B	SK	N/A		6/18/2025				Sign
2011-3	Men's Bathroom 2310 @ C	SK	N/A		6/18/2025				Sign
2012-1	Hall by 2305	WF	App		6/18/2025				Non-functional, sampling required before returning to service
2013-1	Unisex Bathroom by 2144	SK	N/A		6/18/2025				Sign
2014-1	Hall by 2144	WF	App		6/18/2025				Non-functional, sampling required before returning to service
2015-1	Boy's Bathroom by 2701 Birdbath	SK	N/A		6/18/2025				Sign
2016-1	Girl's Bathroom by 2701 Birdbath	SK	N/A		6/18/2025				Sign
2017-1	Room 2701 Teacher's Station	SK	N/A		6/18/2025				Sign
2017-2	Room 2701 Counter 1	SK	N/A		6/18/2025				Sign
2017-3	Room 2701 Counter 2	SK	N/A		6/18/2025				Sign
2017-4	Room 2701 Pod 1 @ A	SK	N/A		6/18/2025				Sign
2017-5	Room 2701 Pod 1 @ B	SK	N/A		6/18/2025				Sign
2017-6	Room 2701 Pod 2 @ A	SK	N/A		6/18/2025				Sign
2017-7	Room 2701 Pod 2 @ B	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2017-8	Room 2701 Pod 3 @ A	SK	N/A		6/18/2025				Sign
2017-9	Room 2701 Pod 3 @ B	SK	N/A		6/18/2025				Sign
2017-10	Room 2701 Pod 4 @ A	SK	N/A		6/18/2025				Sign
2017-11	Room 2701 Pod 4 @ B	SK	N/A		6/18/2025				Sign
2017-12	Room 2701 Pod 5 @ A	SK	N/A		6/18/2025				Sign
2017-13	Room 2701 Pod 5 @ B	SK	N/A		6/18/2025				Sign
2017-14	Room 2701 Pod 6 @ A	SK	N/A		6/18/2025				Sign
2017-15	Room 2701 Pod 6 @ B	SK	N/A		6/18/2025				Sign
2018-1	Office Room 2701/2705	SK	N/A		6/18/2025				Sign
2019-1	Room 2705 Teacher's Station	SK	N/A		6/18/2025				Sign
2019-2	Room 2705 Counter 1	SK	N/A		6/18/2025				Sign
2019-3	Room 2705 Counter 2	SK	N/A		6/18/2025				Sign
2019-4	Room 2705 Pod 1 @ A	SK	N/A		6/18/2025				Sign
2019-5	Room 2705 Pod 1 @ B	SK	N/A		6/18/2025				Sign
2019-6	Room 2705 Pod 2 @ A	SK	N/A		6/18/2025				Sign
2019-7	Room 2705 Pod 2 @ B	SK	N/A		6/18/2025				Sign
2019-8	Room 2705 Pod 3 @ A	SK	N/A		6/18/2025				Sign
2019-9	Room 2705 Pod 3 @ B	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2019-10	Room 2705 Pod 4 @ A	SK	N/A		6/18/2025				Sign
2019-11	Room 2705 Pod 4 @ B	SK	N/A		6/18/2025				Sign
2019-12	Room 2705 Pod 5 @ A	SK	N/A		6/18/2025				Sign
2019-13	Room 2705 Pod 5 @ B	SK	N/A		6/18/2025				Sign
2019-14	Room 2705 Pod 6 @ A	SK	N/A		6/18/2025				Sign
2019-15	Room 2705 Pod 6 @ B	SK	N/A		6/18/2025				Sign
2020-1	Hall by 2705	WF	App		6/18/2025				Non-functional, sampling required before returning to service
2021-1	Room 2707 Teacher's Station	SK	N/A		6/18/2025				Sign
2021-2	Room 2707 Counter 1	SK	N/A		6/18/2025				Sign
2021-3	Room 2707 Counter 2	SK	N/A		6/18/2025				Sign
2021-4	Room 2707 Pod 1 @ A	SK	N/A		6/18/2025				Sign
2021-5	Room 2707 Pod 1 @ B	SK	N/A		6/18/2025				Sign
2021-6	Room 2707 Pod 2 @ A	SK	N/A		6/18/2025				Sign
2021-7	Room 2707 Pod 2 @ B	SK	N/A		6/18/2025				Sign
2021-8	Room 2707 Pod 3 @ A	SK	N/A		6/18/2025				Sign
2021-9	Room 2707 Pod 3 @ B	SK	N/A		6/18/2025				Sign
2021-10	Room 2707 Pod 4 @ A	SK	N/A		6/18/2025				Sign
2021-11	Room 2707 Pod 4 @ B	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2021-12	Room 2707 Pod 5 @ A	SK	N/A		6/18/2025				Sign
2021-13	Room 2707 Pod 5 @ B	SK	N/A		6/18/2025				Sign
2021-14	Room 2707 Pod 6 @ A	SK	N/A		6/18/2025				Sign
2021-15	Room 2707 Pod 6 @ B	SK	N/A		6/18/2025				Sign
2022-1	Room 2707/2711 Office	SK	N/A		6/18/2025				Sign
2023-1	Room 2711 Teacher's Station	SK	N/A		6/18/2025				Sign
2023-2	Room 2711 Counter 1	SK	N/A		6/18/2025				Sign
2023-3	Room 2711 Counter 2	SK	N/A		6/18/2025				Sign
2023-4	Room 2711 Pod 1 @ A	SK	N/A		6/18/2025				Sign
2023-5	Room 2711 Pod 1 @ B	SK	N/A		6/18/2025				Sign
2023-6	Room 2711 Pod 2 @ A	SK	N/A		6/18/2025				Sign
2023-7	Room 2711 Pod 2 @ B	SK	N/A		6/18/2025				Sign
2023-8	Room 2711 Pod 3 @ A	SK	N/A		6/18/2025				Sign
2023-9	Room 2711 Pod 3 @ B	SK	N/A		6/18/2025				Sign
2023-10	Room 2711 Pod 4 @ A	SK	N/A		6/18/2025				Sign
2023-11	Room 2711 Pod 4 @ B	SK	N/A		6/18/2025				Sign
2023-12	Room 2711 Pod 5 @ A	SK	N/A		6/18/2025				Sign
2023-13	Room 2711 Pod 5 @ B	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2023-14	Room 2711 Pod 6 @ A	SK	N/A		6/18/2025				Sign
2023-15	Room 2711 Pod 6 @ B	SK	N/A		6/18/2025				Sign
2024-1	Room 2715 Teacher's Station	SK	N/A		6/18/2025				Sign
2024-2	Room 2715 Counter 1	SK	N/A		6/18/2025				Sign
2024-3	Room 2715 Counter 2	SK	N/A		6/18/2025				Sign
2025-1	Room 2715/2717 Office	SK	App		6/18/2025				Sign
2026-1	Room 2717 Teacher's Station	SK	N/A		6/18/2025				Sign
2026-2	Room 2717 Counter 1	SK	N/A		6/18/2025				Sign
2026-3	Room 2717 Counter 2	SK	N/A		6/18/2025				Sign
2027-1	Hall by 2104	WF	App	<1.0	6/18/2025				-
2027-2	Hall by 2104	BF	App	<1.0	6/18/2025				-
2056-1	Room 2101 Kitchenette	SK	App	1.0	6/18/2025				-
2056-2	Room 2107 Kitchenette	SK	App	3.0	6/18/2025				-
2028-1	Teacher's Center Men's Bathroom	SK	N/A		6/18/2025				Sign
2028-2	Teacher's Center Women's Bathroom	SK	N/A		6/18/2025				Sign
2028-3	Teacher's Center Cafeteria	WF	App		6/18/2025				Non-functional, sampling required before returning to service
2028-4	Teacher's Center Cafeteria	BF	App	<1.0	6/18/2025				-
2028-5	Hall by Teacher's Center	WF	App		6/18/2025				Removed from Service

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2028-6	Hall by Teacher's Center	BF	App		6/18/2025				Removed from Service
2028-5	Teacher's Center Kitchen	SK	App	3.0	6/18/2025				-
2028-6	Teacher's Center Kitchen	SPY	App		6/18/2025				Removed from Service
2028-7	Teacher's Center Kitchen Handwash	SK	N/A		6/18/2025				Sign
2029-1	Bathroom 2136	SK	N/A		6/18/2025				Sign
2030-1	Bathroom 2138	SK	N/A		6/18/2025				Sign
2031-1	Men's Room by 2600 @ A	SK	N/A		6/18/2025				Sign
2031-2	Men's Room by 2600 @ B	SK	N/A		6/18/2025				Sign
2032-1	Room 2600 Teacher's Station	SK	N/A		6/18/2025				Sign
2032-2	Room 2600 Counter 1	SK	N/A		6/18/2025				Sign
2032-3	Room 2600 Counter 2	SK	N/A		6/18/2025				Sign
2032-4	Room 2600 Pod 1 @ A	SK	N/A		6/18/2025				Sign
2032-5	Room 2600 Pod 1 @ B	SK	N/A		6/18/2025				Sign
2032-6	Room 2600 Pod 2 @ A	SK	N/A		6/18/2025				Sign
2032-7	Room 2600 Pod 2 @ B	SK	N/A		6/18/2025				Sign
2032-8	Room 2600 Pod 3 @ A	SK	N/A		6/18/2025				Sign
2032-9	Room 2600 Pod 3 @ B	SK	N/A		6/18/2025				Sign
2032-10	Room 2600 Pod 4 @ A	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2032-11	Room 2600 Pod 4 @ B	SK	N/A		6/18/2025				Sign
2032-12	Room 2600 Pod 5 @ A	SK	N/A		6/18/2025				Sign
2032-13	Room 2600 Pod 5 @ B	SK	N/A		6/18/2025				Sign
2032-14	Room 2600 Pod 6 @ A	SK	N/A		6/18/2025				Sign
2032-15	Room 2600 Pod 6 @ B	SK	N/A		6/18/2025				Sign
2033-1	Room 2600/2604 Office @ A	SK	N/A		6/18/2025				Sign
2033-2	Room 2600/2604 Office @ B	SK	N/A		6/18/2025				Sign
2034-1	Room 2604 Teacher's Station	SK	N/A		6/18/2025				Sign
2034-2	Room 2604 Counter 1	SK	N/A		6/18/2025				Sign
2034-3	Room 2604 Counter 2	SK	N/A		6/18/2025				Sign
2034-4	Room 2604 Pod 1 @ A	SK	N/A		6/18/2025				Sign
2034-5	Room 2604 Pod 1 @ B	SK	N/A		6/18/2025				Sign
2034-6	Room 2604 Pod 2 @ A	SK	N/A		6/18/2025				Sign
2034-7	Room 2604 Pod 2 @ B	SK	N/A		6/18/2025				Sign
2034-8	Room 2604 Pod 3 @ A	SK	N/A		6/18/2025				Sign
2034-9	Room 2604 Pod 3 @ B	SK	N/A		6/18/2025				Sign
2034-10	Room 2604 Pod 4 @ A	SK	N/A		6/18/2025				Sign
2034-11	Room 2604 Pod 4 @ B	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2034-12	Room 2604 Pod 5 @ A	SK	N/A		6/18/2025				Sign
2034-13	Room 2604 Pod 5 @ B	SK	N/A		6/18/2025				Sign
2034-14	Room 2604 Pod 6 @ A	SK	N/A		6/18/2025				Sign
2034-15	Room 2604 Pod 6 @ B	SK	N/A		6/18/2025				Sign
2035-1	Room 2606 Teacher's Station	SK	N/A		6/18/2025				Sign
2035-2	Room 2606 Counter 1	SK	N/A		6/18/2025				Sign
2035-3	Room 2606 Counter 2	SK	N/A		6/18/2025				Sign
2035-4	Room 2606 Pod 1 @ A	SK	N/A		6/18/2025				Sign
2035-5	Room 2606 Pod 1 @ B	SK	N/A		6/18/2025				Sign
2035-6	Room 2606 Pod 2 @ A	SK	N/A		6/18/2025				Sign
2035-7	Room 2606 Pod 2 @ B	SK	N/A		6/18/2025				Sign
2035-8	Room 2606 Pod 3 @ A	SK	N/A		6/18/2025				Sign
2035-9	Room 2606 Pod 3 @ B	SK	N/A		6/18/2025				Sign
2035-10	Room 2606 Pod 4 @ A	SK	N/A		6/18/2025				Sign
2035-11	Room 2606 Pod 4 @ B	SK	N/A		6/18/2025				Sign
2035-12	Room 2606 Pod 5 @ A	SK	N/A		6/18/2025				Sign
2035-13	Room 2606 Pod 5 @ B	SK	N/A		6/18/2025				Sign
2035-14	Room 2606 Pod 6 @ A	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2035-15	Room 2606 Pod 6 @ B	SK	N/A		6/18/2025				Sign
2036-1	Room 2606/2610 Office @ A	SK	N/A		6/18/2025				Sign
2036-2	Room 2606/2610 Office @ B	SK	N/A		6/18/2025				Sign
2037-1	Room 2610 Teacher's Station	SK	N/A		6/18/2025				Sign
2037-2	Room 2610 Counter 1	SK	N/A		6/18/2025				Sign
2037-3	Room 2610 Counter 2	SK	N/A		6/18/2025				Sign
2037-4	Room 2610 Pod 1 @ A	SK	N/A		6/18/2025				Sign
2037-5	Room 2610 Pod 1 @ B	SK	N/A		6/18/2025				Sign
2037-6	Room 2610 Pod 2 @ A	SK	N/A		6/18/2025				Sign
2037-7	Room 2610 Pod 2 @ B	SK	N/A		6/18/2025				Sign
2037-8	Room 2610 Pod 3 @ A	SK	N/A		6/18/2025				Sign
2037-9	Room 2610 Pod 3 @ B	SK	N/A		6/18/2025				Sign
2037-10	Room 2610 Pod 4 @ A	SK	N/A		6/18/2025				Sign
2037-11	Room 2610 Pod 4 @ B	SK	N/A		6/18/2025				Sign
2037-12	Room 2610 Pod 5 @ A	SK	N/A		6/18/2025				Sign
2037-13	Room 2610 Pod 5 @ B	SK	N/A		6/18/2025				Sign
2037-14	Room 2610 Pod 6 @ A	SK	N/A		6/18/2025				Sign
2037-15	Room 2610 Pod 6 @ B	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2038-1	Room 2612 Teacher's Station	SK	N/A		6/18/2025				Sign
2038-2	Room 2612 Counter 1	SK	N/A		6/18/2025				Sign
2038-3	Room 2612 Counter 2	SK	N/A		6/18/2025				Sign
2039-1	Room 2612/2616 Office	SK	N/A		6/18/2025				Sign
2040-1	Room 2616 Teacher's Station	SK	N/A		6/18/2025				Sign
2040-2	Room 2616 Counter 1	SK	N/A		6/18/2025				Sign
2040-3	Room 2616 Counter 2	SK	N/A		6/18/2025				Sign
2041-1	Room 2618 Teacher's Station	SK	N/A		6/18/2025				Sign
2041-2	Room 2618 Counter 1	SK	N/A		6/18/2025				Sign
2041-3	Room 2618 Counter 2 @ A	SK	N/A		6/18/2025				Sign
2041-4	Room 2618 Counter 2 @ B	SK	N/A		6/18/2025				Sign
2041-5	Room 2618 Pod 1 @ A	SK	N/A		6/18/2025				Sign
2041-6	Room 2618 Pod 1 @ B	SK	N/A		6/18/2025				Sign
2041-7	Room 2618 Pod 2 @ A	SK	N/A		6/18/2025				Sign
2041-8	Room 2618 Pod 2 @ B	SK	N/A		6/18/2025				Sign
2041-9	Room 2618 Pod 3 @ A	SK	N/A		6/18/2025				Sign
2041-10	Room 2618 Pod 3 @ B	SK	N/A		6/18/2025				Sign
2041-11	Room 2618 Pod 4 @ A	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2041-12	Room 2618 Pod 4 @ B	SK	N/A		6/18/2025				Sign
2041-13	Room 2618 Pod 5 @ A	SK	N/A		6/18/2025				Sign
2041-14	Room 2618 Pod 5 @ B	SK	N/A		6/18/2025				Sign
2041-15	Room 2618 Pod 6 @ A	SK	N/A		6/18/2025				Sign
2041-16	Room 2618 Pod 6 @ B	SK	N/A		6/18/2025				Sign
2042-1	Room 2618/2620 @ A	SK	N/A		6/18/2025				Sign
2042-2	Room 2618/2620 @ B	SK	N/A		6/18/2025				Sign
2043-1	Room 2620 Teacher's Station	SK	N/A		6/18/2025				Sign
2043-2	Room 2620 Pod 1 @ A	SK	N/A		6/18/2025				Sign
2043-3	Room 2620 Pod 1 @ B	SK	N/A		6/18/2025				Sign
2043-4	Room 2620 Pod 2 @ A	SK	N/A		6/18/2025				Sign
2043-5	Room 2620 Pod 2 @ B	SK	N/A		6/18/2025				Sign
2043-6	Room 2620 Pod 3 @ A	SK	N/A		6/18/2025				Sign
2043-7	Room 2620 Pod 3 @ B	SK	N/A		6/18/2025				Sign
2043-8	Room 2620 Counter 1 @ A	SK	N/A		6/18/2025				Sign
2043-9	Room 2620 Counter 1 @ B	SK	N/A		6/18/2025				Sign
2043-10	Room 2620 Counter 2	SK	N/A		6/18/2025				Sign
2043-11	Room 2620 Pod 4 @ A	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2043-12	Room 2620 Pod 4 @ B	SK	N/A		6/18/2025				Sign
2043-13	Room 2620 Pod 5 @ A	SK	N/A		6/18/2025				Sign
2043-14	Room 2620 Pod 5 @ B	SK	N/A		6/18/2025				Sign
2043-15	Room 2620 Pod 6 @ A	SK	N/A		6/18/2025				Sign
2043-16	Room 2620 Pod 6 @ B	SK	N/A		6/18/2025				Sign
2044-1	Hall by 2623 (left)	WF	App	5.0	6/18/2025				-
2044-2	Hall by 2623 (right)	WF	App	4.0	6/18/2025				-
2045-1	Men's Bathroom by 2623	SK	N/A		6/18/2025				Sign
2046-1	Women's Bathroom by 2623	SK	N/A		6/18/2025				Sign
2047-1	Room 2624 Teacher's Station	SK	N/A		6/18/2025				Sign
2047-2	Room 2624 Pod 1 @ A	SK	N/A		6/18/2025				Sign
2047-3	Room 2624 Pod 1 @ B	SK	N/A		6/18/2025				Sign
2047-4	Room 2624 Pod 2 @ A	SK	N/A		6/18/2025				Sign
2047-5	Room 2624 Pod 2 @ B	SK	N/A		6/18/2025				Sign
2047-6	Room 2624 Pod 3 @ A	SK	N/A		6/18/2025				Sign
2047-7	Room 2624 Pod 3 @ B	SK	N/A		6/18/2025				Sign
2047-8	Room 2624 Counter 1	SK	N/A		6/18/2025				Sign
2047-9	Room 2624 Counter 1 @ A	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2047-10	Room 2624 Counter 2 @ B	SK	N/A		6/18/2025				Sign
2047-11	Room 2624 Pod 4 @ A	SK	N/A		6/18/2025				Sign
2047-12	Room 2624 Pod 4 @ B	SK	N/A		6/18/2025				Sign
2047-13	Room 2624 Pod 5 @ A	SK	N/A		6/18/2025				Sign
2047-14	Room 2624 Pod 5 @ B	SK	N/A		6/18/2025				Sign
2047-15	Room 2624 Pod 6 @ A	SK	N/A		6/18/2025				Sign
2047-16	Room 2624 Pod 6 @ B	SK	N/A		6/18/2025				Sign
2048-1	Room 2626 @ A	SK	N/A		6/18/2025				Sign
2048-2	Room 2626 @ B	SK	N/A		6/18/2025				Sign
2049-1	Room 2628 Teacher's Station	SK	N/A		6/18/2025				Sign
2049-2	Room 2628 Pod 1 @ A	SK	N/A		6/18/2025				Sign
2049-3	Room 2628 Pod 1 @ B	SK	N/A		6/18/2025				Sign
2049-4	Room 2628 Pod 2 @ A	SK	N/A		6/18/2025				Sign
2049-5	Room 2628 Pod 2 @ B	SK	N/A		6/18/2025				Sign
2049-6	Room 2628 Pod 3 @ A	SK	N/A		6/18/2025				Sign
2049-7	Room 2628 Pod 3 @ B	SK	N/A		6/18/2025				Sign
2049-8	Room 2628 Counter 1	SK	N/A		6/18/2025				Sign
2049-9	Room 2628 Counter 1 @ A	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2049-10	Room 2628 Counter 2 @ B	SK	N/A		6/18/2025				Sign
2049-11	Room 2628 Pod 4 @ A	SK	N/A		6/18/2025				Sign
2049-12	Room 2628 Pod 4 @ B	SK	N/A		6/18/2025				Sign
2049-13	Room 2628 Pod 5 @ A	SK	N/A		6/18/2025				Sign
2049-14	Room 2628 Pod 5 @ B	SK	N/A		6/18/2025				Sign
2049-15	Room 2628 Pod 6 @ A	SK	N/A		6/18/2025				Sign
2049-16	Room 2628 Pod 6 @ B	SK	N/A		6/18/2025				Sign
2050-1	Room 2635	SK	N/A		6/18/2025				Sign
2051-1	Room 2033 @ A	SK	N/A		6/18/2025				Sign
2051-2	Room 2033 @B	SK	N/A		6/18/2025				Sign
2052-1	Room 2031 @ A	SK	N/A		6/18/2025				Sign
2052-2	Room 2031 @ B	SK	N/A		6/18/2025				Sign
2053-1	Custodial Closet 2613	SS	N/A		6/18/2025				Sign
2053-2	Custodial Closet 2613	IM	N/A		6/18/2025				Removed from Service
2054-1	Hall by Room 2613	BF	App	<1.0	6/18/2025				-
2054-2	Hall by Room 2613	WF	App	<1.0	6/18/2025				-
2055-1	Hall by 2122	WF	App		6/18/2025				Non-functional, sampling required before returning to service
2056-1	Girl's Bathroom by 2122 Birdbath	SK	N/A		6/18/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2057-1	Boy's Bathroom by 2122 Birdbath	SK	N/A		6/18/2025				Sign
	Field Concession Stand Kitchen	SK	App	7.0	6/18/2025				Removed from service, pending remediation
0	Field Men's Bathroom Birdbath	SK	N/A		6/18/2025				Sign
0	Field Women's Bathroom Birdbath	SK	N/A		6/18/2025				Sign
0	Field Varsity Locker Room Bathroom Birdbath	SK	N/A		6/18/2025				Sign
0	Field JV Locker Room Bathroom Birdbath	SK	N/A		6/18/2025				Sign

Laboratory Report (Revised)

NYE Report #: 2502975-33694R

June 30, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Longwood CSD; Longwood High School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 20, 2025. New York Environmental analyzed the samples on June 23, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	18 Jun 2025
Date Received:	20 Jun 2025
Date Analyzed:	23 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250620S165	1	Kitchen 1 3-Bay @A-SK, Initial	0.001	0.002	mg/L	
250620S166	2	Kitchen 1 3-Bay @B-Sk, Initial	0.001	0.005	mg/L	
250620S167	3	Kitchen 1 Island-SK, Initial	0.001	0.005	mg/L	
250620S168	4	Hall by 1107-WF, Initial	0.001	0.008	mg/L	H
250620S169	5	Kitchen 3 Island by Clock-SK, Initial	0.001	0.004	mg/L	
250620S170	6	Kitchen 3 3-Bay @A-SK, Initial	0.001	0.002	mg/L	
250620S171	7	Kitchen 3 3-Bay @B-SK, Initial	0.001	0.002	mg/L	
250620S172	8	Kitchen 3 Island by 3 Bay-SK, Initial	0.001	0.004	mg/L	
250620S173	9	Hall By 1305-BF, Initial	0.001	<0.001	mg/L	
250620S174	10	Hall By 1305-WF, Initial	0.001	<0.001	mg/L	
250620S175	11	Hall By Auditorium Concession-BF, Initial	0.001	<0.001	mg/L	
250620S176	12	Hall by Auditorium Concession-WF, Initial	0.001	<0.001	mg/L	
250620S177	13	Room 1711 Station 1-SK, Initial	0.001	0.002	mg/L	
250620S178	14	Room 1711 Station 1-SPY, Initial	0.001	<0.001	mg/L	
250620S179	15	Room 1711 Station 2-SK, Initial	0.001	<0.001	mg/L	
250620S180	16	Room 1711 Station 2-SPY, Initial	0.001	<0.001	mg/L	
250620S181	17	Room 1711 Station 3-SK, Initial	0.001	0.002	mg/L	
250620S182	18	Room 1711 Station 3-SPY, Initial	0.001	<0.001	mg/L	
250620S183	19	Room 1711 Station 4-SK, Initial	0.001	0.014	mg/L	H
250620S184	20	Room 1711 Station 4-SPY, Initial	0.001	0.012	mg/L	H
250620S185	21	Room 1711 Station 5-SK, Initial	0.001	0.001	mg/L	
250620S186	22	Room 1711 Station 5-SPY, Initial	0.001	<0.001	mg/L	
250620S187	23	Room 1711 Station 6-SK, Initial	0.001	<0.001	mg/L	
250620S188	24	Room 1711 Station 6-SPY, Initial	0.001	<0.001	mg/L	
250620S189	25	Room 1713 Teachers Station-SK, Initial	0.001	<0.001	mg/L	
250620S190	26	Room 1713 Counter @ A-SK, Initial	0.001	0.003	mg/L	
250620S191	27	Room 1713 Counter @ B-SK, Initial	0.001	0.002	mg/L	



Date Collected:	18 Jun 2025
Date Received:	20 Jun 2025
Date Analyzed:	23 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250620S192	28	Room 1713 Counter @ C-SK, Initial	0.001	0.001	mg/L	
250620S193	29	Room 1713 Counter @ D-SK, Initial	0.001	0.003	mg/L	
250620S194	30	Kitchen 2 3-Bay @ A-SK, Initial	0.001	0.003	mg/L	
250620S195	31	Kitchen 2 3-Bay @ B-SK, Initial	0.001	0.004	mg/L	
250620S196	32	Kitchen 2 Island-SK, Initial	0.001	0.004	mg/L	
250620S197	33	Teachers Center Kitchen-SK, Initial	0.001	0.003	mg/L	
250620S198	34	Teachers Center Cafeteria-BF, Initial	0.001	<0.001	mg/L	
250620S199	35	Shop Room 1803-WF, Initial	0.001	0.023	mg/L	H
250620S200	36	Main Office Kitchenette-SK, Initial	0.001	0.001	mg/L	
250620S202	38	Nurses Office Exam Room 2 - Right-SK, Initial	0.001	0.002	mg/L	
250620S203	39	Physical Education Offices Kitchenette-SK, Initial	0.001	0.002	mg/L	
250620S204	40	Physical Education Offices Kitchenette-SPY, Initial	0.001	<0.001	mg/L	
250620S205	41	Hall By 1604-BF, Initial	0.001	<0.001	mg/L	
250620S206	42	Hall By 1604-WF, Initial	0.001	<0.001	mg/L	
250620S207	43	Hall By 1614-WF, Initial	0.001	0.022	mg/L	H
250620S208	44	Department of Physical Office Handwash-SK, Initial	0.001	0.005	mg/L	
250620S209	45	Athletic Trainer-IM, Initial	0.001	<0.001	mg/L	
250620S210	46	Hall By 1628-WF, Initial	0.001	0.003	mg/L	
250620S211	47	Hall By 1646 (Left)-WF, Initial	0.001	0.002	mg/L	
250620S212	48	Hall By 1646 (Right)-WF, Initial	0.001	0.001	mg/L	
250620S213	49	Room 2101 Kitchenette-SK, Initial	0.001	0.001	mg/L	
250620S214	50	Hall by 2104-BF, Initial	0.001	<0.001	mg/L	
250620S215	51	Hall by 2104-WF, Initial	0.001	<0.001	mg/L	
250620S216	52	Room 2107 Kitchenette-SK, Initial	0.001	0.003	mg/L	
250620S217	53	Hall by 2623 (Left)-WF, Initial	0.001	0.005	mg/L	
250620S218	54	Hall by 2623 (Right)-WF, Initial	0.001	0.004	mg/L	
250620S219	55	Hall by Room 2613-BF, Initial	0.001	<0.001	mg/L	
250620S220	56	Hall by Room 2613-WF, Initial	0.001	<0.001	mg/L	



Date Collected:	18 Jun 2025
Date Received:	20 Jun 2025
Date Analyzed:	23 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
250620S221	57	Field Concession Stand Kitchen-SK, Initial	0.001	0.007	mg/L	H

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Revision History:

Report revised on 6/30/2025, replaces report generated on 6/24/2025.

- Lab Sample ID 250620S201 removed as per client request.