



**MOUNT OLIVE TOWNSHIP
SCHOOL DISTRICT**

227 US Route 206, Suite 10
Flanders, NJ 07836
973.691.4000
MOTSD.org
@MOTSD

BOARD OF EDUCATION

- Lisa Narcise
President
- Lisa Fenton
Vice-President
- Jennifer Aquino
- BethAnn Figueira
- Lauren Fitzgerald
- Dr. Anthony Giordano
- Louisa Melendez
- Jeannie O'Neill
- Marc Orzillo

ADMINISTRATION

- Dr. Sumit Bangia
Superintendent of Schools
- Elizabeth McDermond
Assistant Superintendent
- Nicole Schoening, CPA, SFO
Business Administrator/ Board Secretary
- Kevin Moore
Director of Human Resources
- Luisa Rodriguez, MBA
Assistant Business Administrator/ Assistant Board Secretary

June 30, 2025

Mount Olive Township School District
227 Route 206, Suite 10
Flanders, NJ 07836

Dear Mount Olive Township School District Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community, in accordance with the Department of Education regulations at N.J.A.C. 6A:26-12.4, Mount Olive Township School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Mount Olive Township School District will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within Mount Olive Township School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the # 219 of Outlets Sampled] outlets sampled, #19 of first draw samples above the action level first draw samples tested above the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]). tested above the lead action level.

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead with the associated first draw and follow-up flush sample lead levels, as well as what temporary remedial action Mount Olive Township School District has taken or plans to take to reduce the levels of lead at these locations.

Sample Location	Sample ID	Sample Description	First Draw Result in µg/l (ppb)	Re
Chester M Stephens	CMS-S-NO	NURSE OFFICE SINK	19.3	Sink ha: "Hand \ Off Lin
Chester M Stephens	CMS-S4-K	KITCHEN SINK	29.6	Sink ha: "Hand \ Off Lin

Mt. Olive High School	HS-S-SA	SNACK BAR LEFT SINK	49	Sink has been labeled "Hand Washing Off Line for remed
Mt. Olive Middle School	MS-S3-HE	B142 SINK	20.2	Sink has been labeled "Hand Washing Off Line for remed
Mt. Olive Middle School	MS-S4-HE	B142 SINK	26.5	Sink has been labeled "Hand Washing Off Line for remed
Mt. Olive Middle School	MS-S1-WS	KITCHEN WASH STATION SINK	61.2	Sink has been labeled "Hand Washing Off Line for remed
Mt. Olive Middle School	MS-S5-K	KITCHEN SINK	41.1	Sink has been labeled "Hand Washing Off Line for remed
Mt. Olive Middle School	MS-S7-K	KITCHEN DISH WASH SINK	128	Sink has been labeled "Hand Washing Off Line for remed
Mt. Olive Middle School	MS-S8-K	KITCHEN SERVICE AREA LEFT SINK	28.3	Sink has been labeled "Hand Washing Off Line for remed
Mt. Olive Middle School	MS-S9-K	KITCHEN SERVICE AREA CENTER SINK	20.6	Sink has been labeled "Hand Washing Off Line for remed
Mt. Olive Middle School	MS-S10-K	KITCHEN SERVICE AREA RIGHT SINK	63.4	Sink has been labeled "Hand Washing Off Line for remed
Mt. Olive Middle School	MS-S11-K	KITCHEN SINK	258	Sink has been labeled "Hand Washing Off Line for remed
Mt. Olive Middle School	MS-S-SS	SNACK SHACK SINK	25.2	Sink has been labeled "Hand Washing Off Line for remed
Mt. Olive Middle School	MS-S-LIB	LIBRARY SINK	15.7	Sink has been labeled "Hand Washing Off Line for remed
Mt. Olive Middle School	MS-S-149	MAIN OFFICE 149 SINK	15.2	Sink has been labeled "Hand Washing Off Line for remed
Mt. Olive Middle School	MS-S-E134	E134 PREP SINK	76.6	Sink has been labeled "Hand Washing Off Line for remed
Mt. View	MV-S3-NO	NURSE EXAM RM SINK	55.5	Sink has been labeled "Hand Washing Off Line for remed
Sandshore	SS-S1-WS	KITCHEN SINK	43	Sink has been labeled "Hand Washing Off Line for remed
Tinc	TR-S-TL	TEACHERS LOUNGE SINK	30.5	Sink has been labeled "Hand Washing Off Line for remed

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers, and lakes. Lead enters drinking water primarily because of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes, and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at <https://www.motsd.org/about/buildings-and-grounds>. For more information about water quality in our schools, contact Mr. Michael Cimmino, Director of Buildings and Grounds at the Board of Education office, 973-691-4008.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

Nicole C Schoening

Nicole C Schoening, CPA, SFO
Business Administrator/Board Secretary
Mount Olive Township School District