

Results

First draw samples were collected from 48 fixtures and delivered under chain of custody to Apex Laboratories in Tigard, Oregon, for lead analysis using EPA Method 200.8 ICPMS. Samples above the action level of 15 ppb are shown in bold. The following table lists the results of the analysis.

Table 1: Franklin High School - Sample Results

Fixture Number	Sample Number	Location / Room No.	Results (ppb)
1	DF-5632	Hallway (Conference 017)	ND
2	DF-5634	Hallway (Girls Locker)	ND
3	DF-5635	Girls Locker	ND
4	DF-5636	Boys Locker	ND
5	DF-5637	Hallway (Exercise)	ND
6	DF-5639	Hallway (Gen Ed Classroom 137)	ND
7	DF-5642	Hallway (Computer 117)	ND
8	DF-5649-A	Student Learning Center, right bottle filler	ND
9	DF-5649-D	Student Learning Center, left bottle filler	3.01
10	DF-5650	Main Gym, North	ND
11	DF-5651	Main Gym, South	ND
12	DF-5653	Hallway (Extended Learning)	ND
13	DF-5656	Hallway (Flex Classroom 219)	ND
14	DF-5660	Upper Gymnasium	ND
15	DF-6452	Special Ed Classroom	ND
16	DF-6453	Life Skill 025	0.902
17	DF-6454	Life Skill 024	0.638
18	DF-6455	Teacher Cubicle Area	1.03
19	DF-6456	Teachers Office S 154	0.790
20	DF-6458	Choir Room 131	ND
21	DF-6459	Hallway (Elevator A)	ND
22	DF-6460	Theater Concession 108	ND
23	DF-6461-A	Student Store M118	ND
24	DF-6461-B	Student Store M118 (INSTAHOT)	ND
25	DF-6462	Work Room	1.10
26	DF-6463	Staff Room 126	0.403
27	DF-6465	Toddler M 108	ND
28	DF-6466	Kitchen M 107A	ND
29	DF-6467	Changing M107B	ND
30	DF-6468	Toddler M 107	ND
31	DF-6469	Infant M 105 A	ND
32	DF-6470	Nurse Room	0.439

Fixture Number	Sample Number	Location / Room No.	Results (ppb)
33	DF-6471	Break Room	0.359
34	DF-6472	Staff Room M137	0.787
35	DF-6473	Kitchen 102	0.250
36	DF-6474	Teacher's Office 239	1.17
37	DF-6476	Teacher's Office 217	ND
38	DF-6477	Teacher's Office 201	ND
39	DF-6478	Teacher's Office 239	ND
40	DF-6479	Hallway (Gen Ed Classroom 224)	ND
41	DF-6480	Student Coffee Shop	ND
42	DF-6481	Break Room	ND
43	DF-6482	Training 021	ND
44	DF-6485	Gym Concession (Field)	ND
45	DF-6486	Teacher Office 112	ND
46	DF-6487	Culinary Arts 114	ND
47	DF-6489	Hallway (Classroom 016)	ND
48	DF-6588	Concessions Building (Next to field)	ND

ND = no lead detected

Lead action level: 15 ppb

All tested outlets were dispensing water with concentrations of lead below action levels. PBS is available to assist with further investigation and corrective actions upon request.