

Table 1: Franklin High School - Sample Results

Fixture Number	Sample Number	Location / Room No.	Results (ppb)
DF-5632	215-DF-5632-NA-004-A	Hallway (Conference 017)	ND
DF-5634	215-DF-5634-NA-004-A	Hallway (Girls Locker)	ND
DF-5635	215-DF-5635-NA-004-A	Girls Locker	ND
DF-5636	215-DF-5636-NA-004-A	Boys Locker	ND
DF-5637	215-DF-5637-NA-004-A	Hallway (Exercise)	ND
DF-5639	215-DF-5639-NA-004-A	Hallway (Gen Ed Classroom 137)	ND
DF-5642	215-DF-5642-NA-004-A	Hallway (Computer 117)	ND
DF-5649	215-DF-5649-NA-004-A	Student Learning Center	ND
DF-5650	215-DF-5650-NA-004-A	Main Gym	ND
DF-5651	215-DF-5651-NA-004-A	Main Gym	ND
DF-5653	215-DF-5653-NA-004-A	Hallway (Extended Learning)	ND
DF-5656	215-DF-5656-NA-004-A	Hallway (Flex Classroom 219)	ND
DF-5660	215-DF-5660-NA-004-A	Upper Gymnasium	0.296
DF-6452	215-DF-6452-NA-004-A	Special Ed Classroom	0.395
DF-6453	215-DF-6453-NA-004-A	Life Skill 025	ND
DF-6454	215-DF-6454-NA-004-A	Life Skill 024	0.244
DF-6455	215-DF-6455-NA-004-A	Teacher Cubicle Area	2.48
DF-6456	215-DF-6456-NA-004-A	Teachers Office S 154	1.04
DF-6458	215-DF-6458-B-004-A	Choir Room 131	ND
DF-6459	215-DF-6459-NA-004-A	Hallway (Elevator A)	ND
DF-6460	215-DF-6460-NA-004-A	Theater Concession 108	0.649
DF-6461	215-DF-6461-NA-004-A	Student Store M118	1.88
DF-6462	215-DF-6462-NA-004-A	Work Room	1.51
DF-6463	215-DF-6463-NA-004-A	Staff Room 126	0.696
DF-6465	215-DF-6465-NA-004-A	Toddler M 108	0.414
DF-6466	215-DF-6466-NA-004-A	Kitchen M 107A	ND
DF-6467	215-DF-6467-NA-004-A	Changing M107B	0.212
DF-6468	215-DF-6468-NA-004-A	Toddler M 107	0.349
DF-6469	215-DF-6469-NA-004-A	Infant M 105 A	ND
DF-6470	215-DF-6470-NA-004-A	Nurse Room	1.07
DF-6471	215-DF-6471-NA-004-A	Break Room	0.368
DF-6473	215-DF-6473-NA-004-A	Kitchen 102	0.247
DF-6474	215-DF-6474-NA-004-A	Teacher's Office 239	1.02
DF-6476	215-DF-6476-NA-004-A	Teacher's Office 217	1.28
DF-6477	215-DF-6477-NA-004-A	Teacher's Office 201	0.326
DF-6478	215-DF-6478-NA-004-A	Teacher's Office 239	0.597

Fixture Number	Sample Number	Location / Room No.	Results (ppb)
DF-6479	215-DF-6479-NA-004-A	Hallway (Gen Ed Classroom 224)	ND
DF-6480	215-DF-6480-NA-004-A	Student Coffee Shop	ND
DF-6481	215-DF-6481-NA-004-A	Break Room	1.09
DF-6482	215-DF-6482-NA-004-A	Training 021	0.236
DF-6485	215-DF-6485-NA-004-A	Gym Concession	0.266
DF-6486	215-DF-6486-NA-004-A	Teacher Office 112	ND
DF-6487	215-DF-6487-NA-004-A	Culinary Arts 114	ND
DF-6489	215-DF-6489-NA-004-A	Hallway (Classroom 016)	ND
DF-6588	N/A	Concessions (not functioning)	N/A

ND = no lead detected