

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Abernethy Elementary - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
131-DF-6003-N/A-005-A	Health Room	8/27/2021	8/31/2021	A1H0917-08	Lead	0.759	0.2	15	ppb
131-DF-1038-N/A-005-A	SES Classroom (1A)	8/27/2021	8/31/2021	A1H0917-09	Lead	0.963	0.2	15	ppb
131-DF-1037-N/A-005-A	SES Classroom (2A)	8/27/2021	8/31/2021	A1H0917-10	Lead	1.24	0.2	15	ppb
131-DF-1040-N/A-005-A	SES Classroom (3A)	8/27/2021	8/31/2021	A1H0917-11	Lead	1.15	0.2	15	ppb
131-DF-1043-N/A-005-A	Kindergarten (4A)	8/27/2021	8/31/2021	A1H0917-12	Lead	1.08	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb