

Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Alameda Elementary School - Test 5

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
230-DF-3871-A-005-A	Hallway (B-44)	05/25/2021	05/27/2021	A1E0984-01	Lead	ND	0.2	15	ppb
230-DF-3904-A-005-A	Hallway (148)	05/25/2021	05/27/2021	A1E0984-02	Lead	ND	0.2	15	ppb
230-DF-3895-A-005-A	Hallway (136)	05/25/2021	05/27/2021	A1E0984-03	Lead	0.292	0.2	15	ppb
230-DF-3912-A-005-A	Hallway (131)	05/25/2021	05/26/2021	A1E0984-04	Lead	0.236	0.2	15	ppb
230-DF-3897-A-005-A	Cafetorium	05/25/2021	05/27/2021	A1E0984-05	Lead	ND	0.2	15	ppb
230-DF-3896-A-005-A	Hallway (201)	05/25/2021	05/27/2021	A1E0984-06	Lead	ND	0.2	15	ppb
230-DF-3889-A-005-A	Hallway (103)	05/25/2021	05/27/2021	A1E0984-07	Lead	ND	0.2	15	ppb
230-DF-3891-A-005-A	Hallway (110)	05/25/2021	05/27/2021	A1E0984-08	Lead	ND	0.2	15	ppb
230-DF-5822-NA-005-A	Kitchen	05/25/2021	05/27/2021	A1E0984-09	Lead	ND	0.2	15	ppb
230-DF-5823-NA-005-A	Health Room	05/25/2021	05/26/2021	A1E0984-10	Lead	0.772	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb

Page 1 of 1