

Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Beach Elementary School - Test 6

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
140-DF-3110-A-006-A	Hallway (Main Office)	9/30/2020	10/2/2020	A0I0814-01	Lead	ND	0.2	15	ppb
140-DF-3086-A-006-A	Cafeteria	9/30/2020	10/2/2020	A0I0814-02	Lead	0.317	0.2	15	ppb
140-DF-5798-N/A-006-A	Kitchen	9/30/2020	10/2/2020	A0I0814-03	Lead	0.228	0.2	15	ppb
140-DF-3101-A-006-A	Hallway (B21)	9/30/2020	10/2/2020	A0I0814-04	Lead	ND	0.2	15	ppb
140-DF-5781-A-006-A	Hallway Annex (105)	9/30/2020	10/2/2020	A0I0814-05	Lead	0.733	0.2	15	ppb
140-DF-5780-A-006-A	Hallway (A6)	9/30/2020	10/2/2020	A0I0814-06	Lead	ND	0.2	15	ppb
140-DF-3108-A-006-A	Hallway (2C2)	9/30/2020	10/2/2020	A0I0814-07	Lead	0.338	0.2	15	ppb
140-DF-3111-A-006-A	Halway (2C21)	9/30/2020	10/2/2020	A0I0814-08	Lead	ND	0.2	15	ppb
140-DF-5912-N/A-006-A	Health Room	9/30/2020	10/2/2020	A0I0814-09	Lead	0.802	0.2	15	ppb
140-DF-5779-N/A-006-A	Staff Room	9/30/2020	10/2/2020	A0I0814-10	Lead	0.519	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb