

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Beaumont Middle School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
235-DF-5825-N/A-005-A	Health Room	10/1/2021	10/5/2021	A1J0022-07	Lead	0.776	0.2	15	ppb
235-DF-5824-N/A-005-A	Kitchen	10/1/2021	10/5/2021	A1J0022-08	Lead	1.92	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb