

Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
BC Hollyrood Elementary School - Test 3

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
256-DF-3888-A-003-A	Staff Room	05/26/2021	06/08/2021	A1E1233-08	Lead	ND	0.2	15	ppb
256-DF-3876-A-003-A	Hallway (5)	05/26/2021	06/08/2021	A1E1233-09	Lead	ND	0.2	15	ppb
256-DF-3865-A-003-A	Cafeteria	05/26/2021	06/08/2021	A1E1233-10	Lead	0.594	0.2	15	ppb
256-DF-5832-NA-003-A	Health Room	05/26/2021	06/08/2021	A1E1233-11	Lead	0.560	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb