

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Buckman Elementary School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
143-DF-4580-A-005-A	Hallway (Classroom 109)	11/4/2021	11/18/2021	A1K0323-07RE1	Lead	ND	0.2	15	ppb
143-DF-4562-A-005-A	South Gym	11/4/2021	11/18/2021	A1K0323-08RE1	Lead	ND	0.2	15	ppb
143-DF-4566-A-005-A	Hallway (Classroom 210)	11/4/2021	11/18/2021	A1K0323-09	Lead	4.22	0.2	15	ppb
143-DF-4567-A-005-A	Hallway (Classroom 207)	11/4/2021	11/18/2021	A1K0323-10RE1	Lead	ND	0.2	15	ppb
143-DF-4541-A-005-A	North Gym	11/4/2021	11/18/2021	A1K0323-11RE1	Lead	ND	0.2	15	ppb
143-DF-4598-A-005-A	Hallway (Classroom 103)	11/4/2021	11/18/2021	A1K0323-12RE1	Lead	ND	0.2	15	ppb
143-DF-4556-A-005-A	Cafeteria	11/4/2021	11/18/2021	A1K0323-13RE1	Lead	ND	0.2	15	ppb
143-DF-4568-A-005-A	Hallway (Classroom 112)	11/4/2021	11/18/2021	A1K0323-14RE1	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb