

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Cesar Chavez K-8 School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
182-DF-5807-N/A-005-A	Health Room	8/25/2021	08/26/2021	A1H0836-16	Lead	1.29	0.2	15	ppb
182-DF-2929-A-005-A	Hallway (024)	8/25/2021	08/26/2021	A1H0836-17	Lead	ND	0.2	15	ppb
182-DF-2938-A-005-A	Hallway (248)	8/25/2021	08/26/2021	A1H0836-18	Lead	0.221	0.2	15	ppb
182-DF-5808-N/A-005-A	Faculty Resource 148	8/25/2021	08/26/2021	A1H0836-19	Lead	0.896	0.2	15	ppb
182-DF-5806-N/A-005-A	Kitchen	8/25/2021	08/26/2021	A1H0836-20	Lead	ND	0.2	15	ppb
182-DF-2928-A-005-A	Hallway (131)	8/25/2021	08/26/2021	A1H0836-21	Lead	ND	0.2	15	ppb
182-DF-2944-A-005-A	Hallway (224)	8/25/2021	08/26/2021	A1H0836-22	Lead	ND	0.2	15	ppb
182-DF-2930-A-005-A	Hallway (154)	8/25/2021	08/26/2021	A1H0836-23	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb