

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Clarendon Head Start - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
150-DF-2952-N/A-005-A	Classroom	08/12/2021	08/23/2021	A1H0403-10	Lead	3.06	0.2	15	ppb
150-DF-2955-N/A-005-A	Classroom	08/12/2021	08/23/2021	A1H0403-11	Lead	0.936	0.2	15	ppb
150-DF-2958-N/A-005-A	Classroom	08/12/2021	08/23/2021	A1H0403-12	Lead	1.20	0.2	15	ppb
150-DF-2961-A-005-A	Hallway	08/12/2021	08/23/2021	A1H0403-13	Lead	0.259	0.2	15	ppb
150-DF-2964-N/A-005-A	Classroom	08/12/2021	08/23/2021	A1H0403-14	Lead	0.901	0.2	15	ppb
150-DF-5796-N/A-005-A	Classroom	08/12/2021	08/23/2021	A1H0403-15	Lead	ND	0.2	15	ppb
150-DF-2948-N/A-005-A	Classroom	08/12/2021	08/23/2021	A1H0403-16	Lead	1.75	0.2	15	ppb
150-DF-2951-N/A-005-A	Gym	08/12/2021	08/23/2021	A1H0403-17	Lead	0.296	0.2	15	ppb
150-DF-2954-N/A-005-A	Classroom	08/12/2021	08/23/2021	A1H0403-18	Lead	1.42	0.2	15	ppb
150-DF-2957-N/A-005-A	Classroom	08/12/2021	08/24/2021	A1H0403-19	Lead	1.44	0.2	15	ppb
150-DF-2960-N/A-005-A	Classroom	08/12/2021	08/24/2021	A1H0403-20	Lead	0.913	0.2	15	ppb
150-DF-2963-N/A-005-A	Classroom	08/12/2021	08/24/2021	A1H0403-21	Lead	1.55	0.2	15	ppb
150-DF-2966-N/A-005-A	Classroom	08/12/2021	08/24/2021	A1H0403-22	Lead	1.06	0.2	15	ppb
150-DF-2969-N/A-005-A	Classroom	08/12/2021	08/24/2021	A1H0403-23	Lead	2.87	0.2	15	ppb
150-DF-2949-N/A-005-A	Classroom	08/12/2021	08/24/2021	A1H0403-24	Lead	0.899	0.2	15	ppb
150-DF-5797-N/A-005-A	Staff	08/12/2021	08/24/2021	A1H0403-25	Lead	0.730	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb