

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Cleveland Site - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
213-DF1107-A-005-A	Cafeteria	9/2/2022	9/7/2022	A2I0060-01	Lead	ND	0.200	0.200	ppb
213-DF1113-A-005-A	Hallway (238)	9/2/2022	9/7/2022	A2I0060-02	Lead	ND	0.200	0.200	ppb
213-DF1114-A-005-A	Hallway (281)	9/2/2022	9/7/2022	A2I0060-03	Lead	ND	0.200	0.200	ppb
213-DF1118-A-005-A	Hallway (238)	9/2/2022	9/7/2022	A2I0060-04	Lead	ND	0.200	0.200	ppb
213-DF1120-NA-005-A	Life Skill Room	9/2/2022	9/7/2022	A2I0060-15	Lead	1.98	0.200	0.200	ppb
213-DF1121-A-005-A	Hallway (125)	9/2/2022	9/7/2022	A2I0060-05	Lead	ND	0.200	0.200	ppb
213-DF1123-A-005-A	Hallway (238)	9/2/2022	9/7/2022	A2I0060-06	Lead	ND	0.200	0.200	ppb
213-DF1126-A-005-A	Hallway (308)	9/2/2022	9/7/2022	A2I0060-07	Lead	ND	0.200	0.200	ppb
213-DF1131-A-005-A	Hallway (231/233)	9/2/2022	9/7/2022	A2I0060-08	Lead	ND	0.200	0.200	ppb
213-DF1132-A-005-A	Hallway (325)	9/2/2022	9/7/2022	A2I0060-09	Lead	ND	0.200	0.200	ppb
213-DF1135-A-005-A	Hallway (225)	9/2/2022	9/7/2022	A2I0060-10	Lead	ND	0.200	0.200	ppb
213-DF1190-A-005-A	Hallway (325)	9/2/2022	9/7/2022	A2I0060-11	Lead	ND	0.200	0.200	ppb
213-DF1193-A-005-A	Hallway (308)	9/2/2022	9/7/2022	A2I0060-12	Lead	ND	0.200	0.200	ppb
213-DF5871-A-005-A	Gymnasium	9/2/2022	9/7/2022	A2I0060-13	Lead	ND	0.200	0.200	ppb
213-DF5878-A-005-A	Hallway (218 B)	9/2/2022	9/7/2022	A2I0060-14	Lead	ND	0.200	0.200	ppb
213-DF5883-NA-005-A	Culinary Arts	9/2/2022	9/7/2022	A2I0060-16	Lead	0.249	0.200	0.200	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental

Page 1 of 1