

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Creston Elementary School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
243-DF-5778-N/A-005-A	Classroom 6 (Annex)	9/11/2020	9/15/2020	A0I0302-29	Lead	0.622	0.2	15	ppb
243-DF-5777-N/A-005-A	Classroom 5 (Annex)	9/11/2020	9/16/2020	A0I0302-30	Lead	0.369	0.2	15	ppb
243-DF-5776-N/A-005-A	Classroom 4 (Annex)	9/11/2020	9/17/2020	A0I0302-31	Lead	0.345	0.2	15	ppb
243-DF-5775-N/A-005-A	Classroom 3 (Annex)	9/11/2020	9/18/2020	A0I0302-32	Lead	ND	0.2	15	ppb
243-DF-5774-N/A-005-A	Classroom 2 (Annex)	9/11/2020	9/19/2020	A0I0302-33	Lead	0.461	0.2	15	ppb
243-DF-5365-A-005-A	Hallway (Gym)	9/11/2020	9/20/2020	A0I0302-34	Lead	ND	0.2	15	ppb
243-DF-5370-A-005-A	Hallway (113)	9/11/2020	9/21/2020	A0I0302-35	Lead	0.792	0.2	15	ppb
243-DF-5372-A-005-A	Hallway (Annex)	9/11/2020	9/22/2020	A0I0302-36	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb